



December 2010

CELEBRATING
50
YEARS
in 2010

REPORT

Noise Impact Assessment Moore Solar Farm, St. Clair, Ontario

Submitted to:

First Solar Development Canada
Attn: Peter Carrie, Vice President
5115 Blackwell Sideroad
Sarnia, ON
N7T 7H3

REPORT



A world of
capabilities
delivered locally

Report Number: 08-1112-0185 (1021)

Distribution:

- 1 electronic copy - Mr. Peter Carrie, First Solar
- 1 electronic copy - Mr. Rick Pennycooke, Lakeshore Group
- 1 electronic copy - Mr. Paul Barrette, Lakeshore Group
- 1 electronic copy - Mr. Mike Palladino, First Solar
- 2 copies - Golder Associates Ltd.





Table of Contents

1.0 INTRODUCTION.....	1
1.1 Background	1
2.0 SITE OPERATIONS	2
3.0 NOISE SOURCE SUMMARY	3
4.0 POINT(S) OF RECEPTION.....	5
5.0 ASSESSMENT CRITERIA (PERFORMANCE LIMITS)	6
6.0 IMPACT ASSESSMENT.....	7
6.1 Methodology	7
6.2 Results.....	7
7.0 CONCLUSIONS.....	11

TABLES

Table 1: Noise Source Summary	4
Table 2: Point of Reception Summary.....	5
Table 3: Performance Limits for All Points of Reception (PORs)	6
Table 4: Point of Reception Noise Impact – Scenario #1 (Xantrex Inverters).....	8
Table 5: Point of Reception Noise Impact – Scenario #2 (SMA Inverters)	8
Table 6: Acoustic Assessment Summary – Scenario #1 (Xantrex Inverters)	9
Table 7: Acoustic Assessment Summary – Scenario #2 (SMA Inverters).....	10

FIGURES

Figure 1: Area Plan showing Site Location and Points of Reception.....	13
Figure 2: Site Plan showing Source Locations	13
Figure 3: Results showing Predicted Equivalent Sound Level Contours – Scenario#1	13
Figure 4: Results showing Predicted Equivalent Sound Level Contours – Scenario#2.....	13



NOISE IMPACT ASSESSMENT MOORE SOLAR FARM

APPENDICES

APPENDIX A

Land Use Zoning Plan

APPENDIX B

Description of Technical Terms

APPENDIX C

System Operation Diagram

APPENDIX D

Concrete Enclosure Details

APPENDIX E

Source Sound Levels

APPENDIX F

Equipment Calibration

APPENDIX G

Measurements

APPENDIX H

Weather Data



1.0 INTRODUCTION

Golder Associates Ltd. (Golder) was retained by First Solar Development Canada Inc. (First Solar) to carry out a Noise Impact Assessment (NIA) in support of the Renewable Energy Approval (REA) application for the Moore Solar Farm Facility located in St. Clair, Ontario. First Solar, proposes to develop (construct, and operate) the Moore Solar Farm (Moore Farm), a renewable energy generation facility with a name plate capacity of up to 20 megawatts (MW).

The Moore Farm is composed of one (1) 20 MW solar farm that will supply electricity to the local electric grid. Noise sources associated with the solar farm include the transformers, inverters and exhaust fans installed on-site.

An area plan showing the site location and most sensitive Point(s) of Reception (POR(s)) is provided in Figure 1. A site layout plan showing the source locations is provided in Figure 2. A zoning map is provided in Appendix A.

The immediate surroundings of the site include agricultural land uses with isolated dwellings and a small community to the northwest. This area can be best described as Class 3 (Rural) in accordance with MOE guideline publication NPC-232.

For the purpose of this assessment, fifty-one (51) PORs were selected as being representative of the sensitive receptors in all directions around the site. These receptors are identified as POR001 through POR051. The nearest POR (POR043) is located to the south-west of the site, approximately 590 m from the nearest source.

For easy comprehension and understanding of this report, acoustical technical terms used in this report are explained in Appendix B.

1.1 Background

On September 24, 2009, Ontario Regulation 359/09 of the Environmental Protection Act received Royal Assent and on October 1, 2009 was filed and came into force. In Ontario, all solar farms were previously assessed using Ontario Ministry of Environment's Noise Pollution Control (NPC) guidelines. O. Reg. 359/09 now contains the current requirements for approval of renewable energy projects under the Renewable Energy Approval (REA) process.

According to the project classification scheme outlined in Part II (Classes of Renewable Energy Generation Facilities), Section 4 of O. Reg. 359/09; the Moore Solar Farm can be categorized as a Class 3 solar facility. A Class 3 solar facility is defined as a facility of solar panels situated at any location other than mounted on the roof or wall of a building with a name plate capacity greater than 10 kW. Also, O. Reg. 359/09 indicates that a Class 3 solar facility requires a Noise Study Report prepared in accordance with Appendix A of the MOE publication entitled "Basic Comprehensive Certificates of Approval" dated April 2004 and subsequent amendments.

This report has been prepared following the guidelines given in the above noted MOE documentation.



2.0 SITE OPERATIONS

The proposed site is located on the northwest corner of Rokeby Line and King's Highway No. 40, in St. Clair, Lambton County, Ontario. Upon final commissioning, the solar farm is expected to supply up to twenty (20) MW of power to the local grid. Noise sources associated with this facility include transformers, inverters and exhaust fans.

Two different scenarios have been considered in this report as described below:

Scenario#1: The Moore Farm will consist of 20 different transformer stations. Associated with each of transformer stations will be a concrete enclosure. Each enclosure will contain two (2) 500 kW Xantrex inverters with a cooling coil and exhaust opening on the wall for each inverter. There are also two room cooling intakes and two exhausts per enclosure. This scenario provides 9 different sources per transformer station location.

Scenario#2: The Moore farm will consist of 20 different transformer stations (same location and the same model transformers as above). The two Xantrex model inverters will be replaced by two (2) 500 kW SMA model inverters. There are also two room intakes and two exhausts per enclosure. There are no cooling coil and exhaust openings for the inverters. This scenario provides 5 different sources per transformer station location.

The solar farm will operate year-round during daylight hours. Due to the extended daylight hours during the summer season, it is expected that the facility will also be operating outside of typical daytime hours (i.e., 07:00 hours – 19:00 hours). These noise sources will be situated within the property boundary as shown in Figure 2. For the purpose of this assessment, Golder has conservatively assumed that the equipment will operate at 100% of rated capacity during a predictable worst case hour. A system operation diagram is provided in Appendix C.

The immediate surroundings of the site include agricultural lands with isolated dwellings. Golder has considered this area as Class 3 (Rural) in accordance with MOE publication NPC-232.



3.0 NOISE SOURCE SUMMARY

As discussed, the noise sources of concern associated with this site are the transformers, inverters and exhaust fans. The transformers will be on concrete pads. The inverters will be located inside concrete enclosures as described in Section 2 of this report (i.e., Scenarios #1 and #2). Drawings showing details of the concrete enclosure for both the Xantrex Inverters and the SMA inverters are attached in Appendix D. The Xantrex enclosures will be oriented such that the air intake for the enclosure and openings (intake and exhaust) for the inverters will be on north and south façades and exhaust openings for the enclosure will be on the east façade of each enclosure building. The SMA enclosures will be oriented such that the enclosure intake will be on the east façade and enclosure exhaust openings will be on the north and south façades. Thus the noise sources for each scenario are as follows:

Scenario #1: Xantrex Inverters

- Transformer – point source at each transformer station (1 point source per station)
- Inverter cooling openings - north and south façades (4 vertical area sources per station)
- Room intake openings - north and south façades (2 vertical area sources per station)
- Room exhaust fans – two on east façade (2 point sources per station)

Scenario #2: SMA Inverters

- Transformer – point source at each transformer station (1 point source per station)
- Room exhaust openings – north and south façades (2 vertical area sources per station)
- Room intake openings – two on east façade (2 vertical area sources per station)
- Noise associated with the inverters are included in the intake and exhaust openings of the enclosure.

In accordance with MOE guidelines, the resulting noise emissions associated with the transformers have been penalised by +5 dB to account for the distinct hum from the transformer coils. Also, based on Golder's noise measurements of the Xantrex inverters, a similar +5 dB penalty has been applied to the noise emissions from the inverters which displayed a tonal character. The same penalty was considered appropriate for the SMA inverters as well. Thus all sources associated with this farm include a tonal penalty of +5 dB.

All sources are summarized in Table 3. All source-specific sound pressure levels are summarized in Appendix E.



NOISE IMPACT ASSESSMENT MOORE SOLAR FARM

Table 1: Noise Source Summary

Source ID	Source Description	Overall Sound Power Level (dBA)	Source Location	Sound Characteristics	Noise Control Measures
T 0001 – T 020	Transformers	71	O	S,T ¹	U
Scenario #1 – Xantrex Inverters					
C1_001 – C1_020 and C2_001 – C2_020	Enclosure Exhaust Opening for Inverter Cooling	81	O	S,T ¹	U
C3_001 – C3_020 and C4_001 – C4_020	Enclosure Intake Opening for Inverter Cooling	82	O	S,T ¹	U
I1_001 – I1_020 and I2_001 – I2_020	Enclosure Inlet	77	O	S,T ¹	U
E1_001 – E1_020 and E2_001 – E2_020	Exhaust fan	80	O	S	U
Scenario #2 – SMA Inverters					
E1_001 – E1_020 and E2_001 – E2_020	Enclosure Exhaust Opening ²	75	O	S,T ¹	U
I1_001 – I1_020 and I2_001 – I2_020	Enclosure Inlet ²	67	O	S,T ¹	U

¹ As per MOE guidelines, for tonal sources, the resulting receptor levels have been penalised by 5 dB

² Noise from the inverters is included in the intake and exhaust numbers.

Source Location

O – located/installed outside the building, including on the roof
I – located/installed inside the building

Sound Characteristics

S – Steady
Q – Quasi Steady Impulsive
I – Impulsive
B – Buzzing
T – Tonal
C – Cyclic

Noise Control Measures

S – Silencer, acoustic louver, muffler
A – Acoustic lining, plenum
B – Barrier, berm, or screening
L – Lagging
E – Acoustic enclosure
O – Other
U – Uncontrolled



4.0 POINT(S) OF RECEPTION

As discussed previously, a total of 51 PORs were identified, as being potentially impacted by the noise emissions from the proposed Moore Farm. Among them POR043 has the highest overall levels and is considered in this assessment as the most critical POR.

Table 2: Point of Reception Summary

POR ID	POR Description	Location
POR001 – POR 039	Residential	Residences to the Northwest of the Solar Farm
POR040 – POR 044	Residential	Residences to the Southwest of the Solar Farm
POR045 – POR 051	Residential	Residences to the Southeast of the Solar Farm



5.0 ASSESSMENT CRITERIA (PERFORMANCE LIMITS)

The proposed solar farm is located in St. Clair, Ontario. The site is surrounded generally by agricultural and industrial lands with isolated dwellings all around and community settlement to the northwest. It is considered that all PORs are located in Class 3 areas.

In predicting the sound level at each POR due to the proposed solar farm, MOE publication NPC-232 requires the application of the principle of “predictable worst case” noise impact. The predictable worst case impact is defined as the largest noise excess produced by the facility over the applicable limit.

The background sound level is considered as traffic noise and other sounds in the area excluding the sound from the facility under assessment. The sound level limit for the residential receptors in a Class 3 area can be described as follows:

The energy averaged sound level (Leq) produced by a source at a receptor location in any one hour period should not exceed the greater of; the energy averaged background sound level in the same hour period, or 45 dBA in the daytime period of 07:00-19:00, or 40 dBA in the evening period of 19:00-23:00 and 40 dBA in the night-time period of 23:00-07:00.

Based on Golder’s experience of similar sites, the applicable sound level limits for this site are determined to be the exclusionary minimum sound levels for Class 3 areas as given in table 3.

Table 3: Performance Limits for All Points of Reception (PORs)

Time Period	Sound Level Limit for POR in Class 3 Area [dBA]
Day-time (07:00 – 19:00)	45
Evening (19:00 – 23:00)	40
Night-time (23:00 – 07:00)	40



6.0 IMPACT ASSESSMENT

6.1 Methodology

Sound intensity measurements for the sources were carried out on August 6, 2010 at a solar farm with similar equipment using a Larson Davis 3000+ sound level meter/realtime analyzer equipped with Larson and Davis intensity probe (model 2260). The calibration of the instrumentation was verified before and after the measurements. All measuring equipment used in this study meets the MOE requirements, and calibration certificates are provided in Appendix F.

All relevant sound level measurements taken during the site visit have been documented in 1/3 octave band level format and are summarized in Appendix G. Weather during the August, 2010 site visit included clear conditions with temperatures ranging between 20°C and 24°C. Winds were predominantly from the West at 7 to 17 km/h. Weather data can be found in Appendix H.

The predictions were made using the commercially available software package CadnaA V 4.0.135. Geometrical spreading, attenuation from barriers (if any), ground effect and air absorption were included in the analysis as determined from ISO 9613 (part 2), which is the current standard used for outdoor sound propagation predictions. It should be noted that this standard makes provisions to include a correction to address for downwind or ground based temperature inversion conditions. Conservatively, noise predictions have been made assuming a downwind or moderate temperature inversion conditions for all PORs, a design condition consistent with the accepted practice of the MOE.

All transformers were modelled as point sources. In scenario #1 all inverter related sources were modelled as point sources and vertical area sources, while in scenario #2 the inverter related sources were modelled as vertical area sources only.

All source-specific sound power levels are summarized in Appendix E.

6.2 Results

Tables 4 and 5 summarize the predicted sound pressure levels of Scenario #1 and #2 for each source at the PORs and the distance from each source to the identified PORs. The format for Table 4 and Table 5 are shown below, and the complete tables can be found on the attached CD. Sample calculations are also provided in the attached CD. The predicted results indicate that the sound emissions from the Moore Farm will meet the MOE noise level limits for Class 3 areas during night-time hours (i.e., 40 dBA).

Figure 3 and 4 show the noise contours for the study area for each scenario considered. Similarly, Tables 6 and 7 provide a summary of the overall predicted noise levels at the identified PORs for each scenario.



NOISE IMPACT ASSESSMENT MOORE SOLAR FARM

Table 4: Point of Reception Noise Impact – Scenario #1 (Xantrex Inverters)

Source ID	POR001		POR002		POR003		POR004		POR005	
	Distance (m)	Overall Sound Pressure Level (dBA)	Distance (m)	Overall Sound Pressure Level (dBA)	Distance (m)	Overall Sound Pressure Level (dBA)	Distance (m)	Overall Sound Pressure Level (dBA)	Distance (m)	Overall Sound Pressure Level (dBA)
T0001	Refer to attached CD for Table 4.									
T0002										
T0003										
T0004										
T0005										

Table 5: Point of Reception Noise Impact – Scenario #2 (SMA Inverters)

Source ID	POR001		POR002		POR003		POR004		POR005	
	Distance (m)	Overall Sound Pressure Level (dBA)	Distance (m)	Overall Sound Pressure Level (dBA)	Distance (m)	Overall Sound Pressure Level (dBA)	Distance (m)	Overall Sound Pressure Level (dBA)	Distance (m)	Overall Sound Pressure Level (dBA)
T0001	Refer to attached CD for Table 5.									
T0002										
T0003										
T0004										
T0005										



NOISE IMPACT ASSESSMENT MOORE SOLAR FARM

Table 6: Acoustic Assessment Summary – Scenario #1 (Xantrex Inverters)

Point of reception ID	Point of Reception (POR) Description	Overall SPL at POR (dBA)	Verified by Acoustic Audit (Yes/No)	Performance Limit (dBA)	Compliance with Performance Limit (Yes/No)
POR001 – POR 039	Residences to the Northwest of the Solar Farm	19 – 21	N/A	40	Yes
POR040 – POR 044	Residences to the Southwest of the Solar Farm	22 – 28	N/A	40	Yes
POR045 – POR 051	Residences to the Southeast of the Solar Farm	15 - 26	N/A	40	Yes



NOISE IMPACT ASSESSMENT MOORE SOLAR FARM

Table 7: Acoustic Assessment Summary – Scenario #2 (SMA Inverters)

Point of reception ID	Point of Reception (POR) Description	Overall SPL at POR (dBA)	Verified by Acoustic Audit (Yes/No)	Performance Limit (dBA)	Compliance with Performance Limit (Yes/No)
POR001 – POR 039	Residences to the Northwest of the Solar Farm	12 – 14	N/A	40	Yes
POR040 – POR 044	Residences to the Southwest of the Solar Farm	15 – 21	N/A	40	Yes
POR045 – POR 051	Residences to the Southeast of the Solar Farm	7 - 18	N/A	40	Yes

For both scenarios, the overall predicted noise levels for all identified PORs, based on site operations, comply with the performance limits for daytime and night-time operations. As a result, no additional mitigation will be required to ensure compliance with MOE noise guidelines.



7.0 CONCLUSIONS

Golder was retained by First Solar Development Canada Inc. to carry out a Noise Impact Assessment for the proposed Moore Solar Farm located in St. Clair, Ontario. As requested, Golder considered two different scenarios; one with all Xantrex model inverters (2 per station) and the other with all SMA model inverters (two per station). Based on the results presented in this report, it is concluded that the Moore Solar Farm will operate in compliance with MOE noise guidelines using either Xantrex or SMA inverters.



NOISE IMPACT ASSESSMENT MOORE SOLAR FARM

Report Signature Page

Samuel Isono M.A.Sc., P.Eng
Acoustics, Noise, and Vibration Engineer

Joe Tomaselli M.Eng., P.Eng
Associate

SI/JT/ng

n:\active\2008\1112\08-1112-0185 opti solar-noise assessments-ontario\report\final\1021 st clair moore - rea\08-1112-0185 rpt dec10 first solar noise impact assessment st clair moore.docx



NOISE IMPACT ASSESSMENT MOORE SOLAR FARM

LIST OF FIGURES


Figure 1: Area Plan showing Site Location and Points of Reception

Figure 2: Site Plan showing Source Locations

Figure 3: Results showing Predicted Equivalent Sound Level Contours – Scenario#1


Figure 4: Results showing Predicted Equivalent Sound Level Contours – Scenario#2

G:\Projects\2008\08-1112-0185_OptiSolar\GIS\MXDs\Draft\Updates_Jan2010\StClair_Moore_SiteLocation.mxd



LEGEND

- Point of Reception (POR)
- Principal Highway
- Major Road
- Local Road
- Lot and Concessions
- Wooded Area
- Property Boundary



REFERENCE

Base Data - MNR NRVIS, obtained 2004, CANMAP v2006.4
Produced by Golder Associates Ltd under licence from
Ontario Ministry of Natural Resources, © Queens Printer 2009
Projection: Transverse Mercator Datum: NAD 83 Coordinate System: UTM Zone 17

100 50 0 100 200 300
METRES



PROJECT		FIRST SOLAR - ST CLAIR MOORE	
TITLE		AREA PLAN SHOWING SITE LOCATION AND POINTS OF RECEPTION	
 Mississauga, Ontario	PROJECT No. 08-1112-0185	SCALE AS SHOWN	REV. 0.0
	DESIGN	JO	23 Jan. 2009
	GIS	ME	08 Jan. 2010
	CHECK		08 Jan. 2010
REVIEW		08 Jan. 2010	

FIGURE: 1


G:\Projects\2008\08-1112-0185_OptiSolar\GIS\MXDs\Draft\Updates_Jan2010\StClair_Moore_SourceLocations.mxd



G:\Projects\2008\08-1112-0185_OptiSolar\GIS\MXDs\Draft\Updates_Jan2010\StClair_Moore_ResultsShowingPredictedEquivalentSoundLevelContoursScenario1.mxd



G:\Projects\2008\08-1112-0185_OptiSolar\GIS\MXDs\Draft\Updates_Jan2010\StClair_Moore_ResultsShowingPredictedEquivalentSoundLevelContoursScenario2.mxd




LEGEND


- Source Location
- Point of Reception (POR)
- > 56.0 dB
- > 54.0 dB
- > 52.0 dB
- > 50.0 dB
- > 48.0 dB
- > 46.0 dB
- > 44.0 dB
- > 42.0 dB
- > 40.0 dB
- > 38.0 dB
- > 36.0 dB
- > 0.0 dB
- Principal Highway
- Major Road
- Local Road
- Lot and Concessions
- Wooded Area
- Property Boundary



REFERENCE

Base Data - MNR NRVIS, obtained 2004, CANMAP v2006.4
Produced by Golder Associates Ltd under licence from
Ontario Ministry of Natural Resources, © Queens Printer 2009
Projection: Transverse Mercator Datum: NAD 83 Coordinate System: UTM Zone 17




PROJECT			
FIRST SOLAR - ST CLAIR MOORE			
TITLE			
RESULTS SHOWING PREDICTED EQUIVALENT SOULD LEVEL CONTOURS - SCENARIO #2			
 Mississauga, Ontario	PROJECT No.08-1112-0185		SCALE AS SHOWN
	DESIGN	JO	23 Jan. 2009
	GIS	ME	22 Feb. 2010
	CHECK		22 Feb. 2010
	REVIEW		22 Feb. 2010
FIGURE: 4			



APPENDIX A

Land Use Zoning Plan

G:\Projects\2008\08-1112-0185_OptiSolar\GIS\MXDs\Draft\Updates_Jan2010\StClair_Moore_Zoning.mxd




LEGEND


- Principal Highway
 - Major Road
 - Local Road
 - Property Boundary
- Zoning**
- A1: Agricultural 1
 - A1-4: Agricultural Exception
 - C5: Neighbourhood Commercial
 - EP-H: Environmental Protection - Hazard
 - EP-WD: Environmental Protection - Woodlot
 - I1: Institutional
 - M2: Industrial - Type 2
 - M3: Industrial - Type 3
 - M3-2: Industrial - Type 3 Exception
 - OS1: Open Space
 - R1: Residential 1
 - R1-h2: Residential 1 Holding



REFERENCE

Base Data - MNR NRVIS, obtained 2004, CANMAP v2006.4
Produced by Golder Associates Ltd under licence from
Ontario Ministry of Natural Resources, © Queens Printer 2009
Imagery Source: County of Lambton, 2006 30cm Orthophotography; © 2009
Zoning: County of Lambton, obtained Jan. 2009
Projection: Transverse Mercator Datum: NAD 83 Coordinate System: UTM Zone 17



PROJECT		FIRST SOLAR - ST CLAIR MOORE			
TITLE		ZONING PLAN			
 Golder Associates Mississauga, Ontario	PROJECT No. 08-1112-0185			SCALE AS SHOWN	REV. 0.0
	DESIGN	JO	23 Jan. 2009	APPENDIX A	
	GIS	JO	08 Jan. 2010		
	CHECK		08 Jan. 2010		
		REVIEW	08 Jan. 2010		



APPENDIX B

Description of Technical Terms



DESCRIPTION OF TECHNICAL TERMS

To help understand the analysis and recommendations made in this report, the following is a brief discussion of technical terms.

The strength of a sound source is described in terms of either sound pressure level (SPL) or sound power level (PWL) and are expressed on a logarithmic scale with reference to the lowest possible sound pressure (2×10^{-5} Pa) or power (10^{-12} W) level that human ear can hear. With this appropriate reference parameter the resulting logarithmic scale is referred to as “decibel” (dB). The SPL is thus represented as dB re 2×10^{-5} Pa and PWL as dB re 10^{-12} W.

Since the scale is logarithmic, a source that is twice the strength as another will have a level three decibels (3 dB) higher sound power. SPL attenuates at a rate of 6 dB per doubling of distance.

The sound data and analysis in this report have been given in terms of octave band frequency distribution. Typically, each octave band is expressed in terms of its centre frequency, namely 31.5, 63, 125, 250, 500, 1000, 2000, 4000 and 8000 Hertz (Hz.).

Human ears are most sensitive in the 500 to 4000 Hz frequency range, above and below this range; the ear is progressively less sensitive to sound. Therefore in order to express sound level more representative of the human hearing response, a weighting is typically applied to each octave band. The most commonly used weighting is called “A-weighting”.


It is common practice to express the sound levels over the entire audible spectrum (i. e., 20 Hz to 20 kHz) as an overall sound level (a single number). The overall A-weighted sound level is often used as a criterion to indicate a maximum allowable sound level.

Environmental noise levels vary over time, and are described in terms of one hour energy equivalent sound level, L_{eq} [1 hour]. The L_{eq} is the energy equivalent continuous sound level, which has the same energy as the time varying noise over a prescribed one hour period.



APPENDIX C

System Operation Diagram



- NOTES:**
KIRK KEY INTERLOCKS TO BE INSTALLED ACCORDING TO THE FOLLOWING SCHEME:
1. 3 POSITION MV SWITCH IN PVCS1 W/GROUNDING OPTION MUST BE LOCKED OPEN TO ACCESS TRANSFORMER ENCLOSURES T-1 --> T5
2. ISOLATION SWITCH IN PVCS2 BE LOCKED OPEN TO ACCESS TRANSFORMER ENCLOSURES T6 --> T10
3. DISCONNECT IN MAIN SWITCHGEAR MUST BE LOCKED OPEN TO ACCESS PVCS 1 & PVCS 2 ENCLOSURES
4. MAIN LOAD BREAK SWITCH MUST BE LOCKED OPEN TO ACCESS MAIN SWITCHGEAR
5. THE TRANSFORMER HV COMPARTMENT SHALL BE PROVIDED WITH AN INTERLOCKED DOOR WHICH CAN ONLY BE OPENED AFTER THE LV COMPARTMENT DOOR HAS BEEN OPENED. THE HIGH VOLTAGE DOOR SHALL HAVE PROVISIONS FOR MOUNTING A KIRK KEY INTERLOCK. THE INTENTION OF THE KIRK LOCK PROVISIONS IS NOT TO ALLOW ACCESS INTO THE HIGH VOLTAGE COMPARTMENT WITHOUT THE KEY.
6. KIRK KEY LOCK MUST BE TURNED BEFORE THE HV DOOR CAN BE OPENED.
7. K12 IS REQUIRED TO ACCESS T-1 TO T-5
8. K13 IS REQUIRED TO ACCESS T-6 TO T-10.

THIS PUBLICATION CONTAINS VALUABLE PROPRIETARY AND CONFIDENTIAL INFORMATION OF FIRST SOLAR, INC. ("FIRST SOLAR") AND RETAINS ALL COPYRIGHT RIGHTS TO IT UNDER U.S. & CANADIAN LAW AND IS PROTECTED BY U.S. AND INTERNATIONAL LAW. ANY REPRODUCTION, PREPARATION OF DERIVATIVE WORKS, DISTRIBUTION, PUBLIC PERFORMANCE OR DISPLAY, DISCLOSURE, AND/OR USE OF ALL OR ANY PORTION OF THIS PUBLICATION IN ANY FORM OR MEDIUM WITHOUT SPECIFIC WRITTEN AUTHORIZATION FROM FIRST SOLAR IS STRICTLY PROHIBITED.

CABLE SCHEDULE:

- (A1) (3)-1/C #2/0 TRXLPE AL (28KV) DIRECT BURIAL CABLE WITH CONCENTRIC CU GND WIRE.
(A3) (A4) 4 SETS OF CU. (3)-1/C #500kcmil & (1) #350kcmil CU BONDING CABLE FOR EACH 500 KW INVERTER.
(C) 2 SETS OF (3)-1/C #2/0 TRXLPE AL (28KV) DIRECT BURIAL CABLE WITH CONCENTRIC CU GND WIRE.
(D) 600V 3/C #500MCM CU. CABLE WITH #2 CU. GND DIRECT BURIAL CABLE.

NOTES:

1. THIS DRAWING REPRESENTS ONE PROPOSED ARRANGEMENT AND IS SUBJECT TO CHANGE BASED UPON THE DETAILED DESIGN.

LEGEND:

- 500KW
DUAL WINDING TRANSFORMER
MEDIUM VOLTAGE FUSED DISCONNECT
SURGE ARRESTER
VACUUM FAULT INTERRUPTER OR CIRCUIT BREAKER
M METER (REVENUE) WITH REMOTE COMMUNICATION CAPABILITIES
POTENTIAL TRANSFORMER (REVENUE)
CURRENT TRANSFORMER (METERING)
CURRENT TRANSFORMER (REVENUE)
LA LIGHTNING ARRESTOR, DISTRIBUTION CLASS
FLOATING WYE
GROUNDED WYE
DEAD FRONT ELBOW CONNECTIONS
MEDIUM VOLTAGE DEAD FRONT STRESS RELIEF TERMINATION
3 POSITION MV SWITCH W/GROUNDING OPTION
52 SF6 1200A CIRCUIT BREAKER
27 UNDERVOLTAGE RELAY
59 OVERVOLTAGE RELAY
32 DIRECTIONAL POWER RELAY
67 AC DIRECTIONAL OVERCURRENT
50 INSTANTANEOUS OVERCURRENT
51 TIME OVERCURRENT
81 FREQUENCY RELAY
85 REMOTE TRIP RECIEVED FROM HYDRO ONE, AND L.E.O. SENT TO HYDRO ONE

PCS = POWER CONVERSION STATION
PVCS = PHOTOVOLTAIC SYSTEM COMBINING SWITCHGEAR
PVS = PHOTOVOLTAIC SYSTEM INTERCONNECTION SWITCHGEAR

FIRST SOLAR DEVELOPMENT (CANADA)
5115 BLACKWELL SIDEROAD
SARNIA, ONTARIO
N7T 7H3

elecor
Elecor Engineering Co. Limited
1149 Vanier Rd., Suite 1001
Sarnia, Ontario
N7T 3Y6

SARNIA SOLAR PHOTOVOLTAIC POWER PLANT SITE PLAN CONTROL AGREEMENT

REV	DATE	DESCRIPTION
1	7-15-09	ISSUED FOR CONSTRUCTION
0	7-08-09	ISSUED FOR CONSTRUCTION
A	6-25-09	IFB ISSUED FOR BID
ISSUE: Z-28-08		


PROJ NO: 5025-0106-22
CAD DWG FILE: E-100-1
DRAWN BY: RICK BRADY
CHECKED BY: KC
SCALE: NTS
COPYRIGHT BY: FIRST SOLAR
SHEET TITLE

**BLOCK-1
M.V. ONE LINE
DIAGRAM**

E-100-1

SHEET OF

Confidential Information: The contents of this document are subject to a Non-Disclosure Agreement and shall not be disclosed.



MEDIUM VOLTAGE COLLECTION NETWORK FOR A 10MW AC PHOTOVOLTAIC SYSTEM ONE LINE DIAGRAM

SCALE: NOT TO SCALE

NOTES:

1. THIS DRAWING REPRESENTS ONE PROPOSED ARRANGEMENT AND IS SUBJECT TO CHANGE BASED UPON THE DETAILED DESIGN.

LEGEND:

- EQUIPMENT ENCLOSURE - METAL ENCLOSED OR METAL CLAD
- TYPICAL 500KW SOLAR PHOTOVOLTAIC INVERTER W/SHORT CIRCUIT & O/C PROTECTION CONFORMS TO UL-1741
- DUAL WINDING TRANSFORMER
- MEDIUM VOLTAGE FUSED DISCONNECT
- SURGE ARRESTER
- VACUUM FAULT INTERRUPTER OR CIRCUIT BREAKER
- METER (REVENUE) WITH REMOTE COMMUNICATION CAPABILITIES
- POTENTIAL TRANSFORMER (REVENUE)
- CURRENT TRANSFORMER (METERING)
- CURRENT TRANSFORMER (REVENUE)
- LIGHTNING ARRESTOR, DISTRIBUTION CLASS
- FLOATING WYE
- GROUNDING WYE
- DEAD FRONT ELBOW CONNECTIONS
- MEDIUM VOLTAGE DEAD FRONT STRESS RELIEF TERMINATION
- 3 POSITION MV SWITCH W/GROUNDING OPTION
- SF6 1200A CIRCUIT BREAKER
- UNDERVOLTAGE RELAY
- OVERVOLTAGE RELAY
- DIRECTIONAL POWER RELAY
- AC DIRECTIONAL OVERCURRENT
- INSTANTANEOUS OVERCURRENT
- TIME OVERCURRENT
- FREQUENCY RELAY
- REMOTE TRIP RECEIVED FROM HYDRO ONE, AND L.E.O. SENT TO HYDRO ONE

PCS = POWER CONVERSION STATION
PVCS = PHOTOVOLTAIC SYSTEM COMBINING SWITCHGEAR
PVS = PHOTOVOLTAIC SYSTEM INTERCONNECTION SWITCHGEAR

REV	DATE	DESCRIPTION	ISSUED FOR CONSTRUCTION
0	7-08-09	ISSUED FOR CONSTRUCTION	
E	6-25-09	IFB- ISSUED FOR BID	
D	6-22-09	ISSUED EISA PERMIT	
C	6-5-09	UPDATED PER ELECSAR COMMENTS	
B	5-29-09	ISSUED - EISA PERMIT	
A	5-21-09	ISSUED FOR EISA REVIEW	
1	7-15-09	ISSUED FOR CONSTRUCTION	

PROJ NO: 5025-0106-22
CAD DWG FILE: E-100-2
DRAWN BY: RICK BRADY
CHECKED BY: KC
SCALE: NTS
COPYRIGHT BY: FIRST SOLAR
SHEET TITLE

BLOCK 2
M.V. ONE LINE
DIAGRAM

E-100-2
SHEET OF

FIRST SOLAR DEVELOPMENT
(CANADA)
5115 BLACKWELL SIDEROAD
SARNIA, ONTARIO
N7T 7H3

elecsar
Elecsar Engineering Co. Limited
1149 Vanier Rd., Suite 1001
Sarnia, Ontario
N7T 5Y6

SARNIA SOLAR
PHOTOVOLTAIC
POWER PLANT
SITE PLAN CONTROL
AGREEMENT



Confidential Information: The contents of this document are subject to a Non-Disclosure Agreement and shall not be disclosed.



APPENDIX D

Concrete Enclosure Details

CONDUIT FILL TOP TO BOTTOM
SPARE
SPARE
#2/C#18 TSP TO 'TT-X-X'
12PR-2/C#18 TSP TO 'MP-X-X' SEE NOTE 6
8 TRIADS-3/C#18 TS TO 'MP-X-X' SEE NOTE 6
2PR-2/C#18 TSP TO 'RM-X-X' SEE NOTE 5
2#12+1#12G TO 'RM-X-X' SEE NOTE 5
TO 'DAS' 3PR-2/C#18 TSP
TO 'DAS' 5PR-2/C#18 TSP




TYPICAL PCS BLDG. ELECTRICAL FLOOR PLAN

SCALE: 1/2" = 1'-0"

POWER PANEL/UDS TAG. NO.: PP-PCS"XX"
MANUFACTURER: CUTLER-HAMMER
MODEL/CAT. NO.: MINI POWER CENTER
TRANSFORMER RATING: 22.5KVA, 3ø
PANELBOARD RATING: MAIN BREAKER SIZE: 100A

CKT. NO.	BKR. SIZE	LOAD	LOAD (VA)	TOTAL (VA)	LOAD (VA)	TOTAL (VA)	LOAD	BKR. SIZE	CKT. NO.
1				1200		320	LIGHTS - INTERIOR	20A	2
3	20A 3P	INVERTER 'A'	6000	1200	43	360	LIGHTS - EXTERIOR & INT. EXIT	20A	4
5				1200		700	CONV. RECEPT. (INT. & ROOF)	20A	6
7				1200		50	DAS PANEL	20A	8
9	20A 3P	INVERTER 'B'	6000	1200		100	HVAC CONTROL RELAY	20A	10
11				1200			SMOKE DETECTOR	20A	12
13	20A	EXH. FAN-1		500			SPARE	20A	14
15	20A	LOUVER-1		600			SPACE		16
17	20A	EXH. FAN-2		500			SPACE		18
19	20A	LOUVER-2		600			SPACE		20

LOADS (VA):	LOADS (A):
PHASE A (VA): 4620	PHASE A (AMPS): 38.50
PHASE B (VA): 3853	PHASE B (AMPS): 29.53
PHASE C (VA): 3840	PHASE C (AMPS): 29.00



TYPICAL PCS BLDG. ELECTRICAL UNDERGROUND PLAN

SCALE: 1/2" = 1'-0"

REFERENCE STANDARD SPECIFICATION:

- DWG NO. E-001
ELECTRICAL TYPICAL NOTES, SYMBOLS & ABBREVIATIONS
- DWG NOS. S-301 THRU S-304
TYPICAL PCS BUILDING PLANS AND DETAILS

NOTES:

- WORK THIS DWG. WITH THE STANDARD SPECIFICATION SS-17000 AND ALL OTHER DRAWINGS LISTED UNDER ATTACHMENTS.
- FOR EQUIPMENT WIRING AND INTERCONNECTION DIAGRAM, SEE THE BLOCK WIRING DIAGRAM ON DWG NO. E-710.
- DISTANCE OF UNDERGROUND CONDUIT TO EXTEND BEYOND PAD EDGE.
- ALL ELECTRICAL WORK ON THIS DWG IS TYPICAL FOR ALL PCS SHELTERS, UNLESS OTHERWISE NOTED.
- ALL CABLES ASSOCIATED WITH 'RM-X-X' IS ONLY TYPICAL FOR PCS SHELTER #S AS FOLLOWS:
PCS-01, PCS-03, PCS-05, PCS-11, PCS-13 AND PCS-15,
PCS-03 & PCS-13
- ALL CABLES ASSOCIATED WITH 'MP-X-X' IS ONLY TYPICAL FOR PCS SHELTER #S AS FOLLOWS:
PCS-03 & PCS-13
- ALL DAS EQUIPMENT CABLES ARE ENTERING VIA CONDUITS TO PCS SHELTER BLDG..
- REFER TO STRUCTURAL DWGS. FOR EXACT LOCATION OF PCS SHELTER AND TRANSFORMER.
- REFER TO THE FOLLOWING DRAWINGS FOR THE DC CABLING FROM DC COMBINER BOX TO DC FUSE BOX:
A) PV ONE LINE DIAGRAMS
DWGS. NOS. E-102-1 & E-102-2.
- REFER TO PANEL SCHEDULE IN THIS DWG. FOR CIRCUITS.

FIRST SOLAR DEVELOPMENT
(CANADA)
5115 BLACKWELL SIDEROAD
SARNIA, ONTARIO
N7T 7H3

elecsar
Elecsar Engineering Co. Limited
1149 Vanier Rd., Suite 1001
Sarnia, Ontario
N7T 3Y6

SARNIA SOLAR
PHOTOVOLTAIC
POWER PLANT
SITE PLAN CONTROL
AGREEMENT


REV	DATE	DESCRIPTION
0	7-15-09	ISSUED FOR CONSTRUCTION
D	6-25-09	ISSUED FOR BID
C	6-22-09	ISSUED FOR E&A PERMIT
B	5-29-09	ISSUED FOR E&A PERMIT
A	5-29-09	ISSUED FOR E&A PERMIT

PROJ NO: 5025-0106-22
CAD DWG FILE: E-500
DRAWN BY: RICK BRADY
CHECKED BY: AP
SCALE: NTS
COPYRIGHT BY: FIRST SOLAR
SHEET TITLE

TYP. PCS BLDG.
ELECTRICAL PLAN


E-500

SHEET OF




TYPICAL PCS BLDG. ELECTRICAL EQUIPMENT ARRANGEMENT PLAN

SCALE: 1/2" = 1'-0"




SECTION A
E-501
PCS BUILDING ELEVATION

SCALE: NTS



SECTION B
E-501
PCS BUILDING ELEVATION

SCALE: NTS



SECTION C
E-501
PCS BUILDING ELEVATION

SCALE: NTS

REFERENCE STANDARD SPECIFICATION:

- DRAWING NO. E-100
ELECTRICAL TYPICAL NOTES, SYMBOLS & ABBREVIATIONS
- DRAWING NOS. S-301 THRU S-304
TYPICAL PCS BUILDING PLANS AND DETAILS

NOTES:

- WORK THIS DWG. WITH THE STANDARD SPECIFICATION SS-17000 AND ALL OTHER DRAWINGS LISTED UNDER ATTACHMENTS.
- FOR EQUIPMENT WIRING AND INTERCONNECTION DIAGRAM, SEE THE BLOCK WIRING DIAGRAM ON DWG. NO. E-711.
- DISTANCE OF UNDERGROUND CONDUIT TO EXTEND BEYOND PAD EDGE.
- ALL ELECTRICAL WORK ON THIS DWG. IS TYPICAL FOR ALL PCS SHELTERS, UNLESS OTHERWISE NOTED.
- ALL CABLES ASSOCIATED WITH 'RM-X-X' IS ONLY TYPICAL FOR PCS SHELTER #s AS FOLLOWS:
PCS-01, PCS-03, PCS-05, PCS-16, PCS-18, PCS-20, PCS-21, PCS-23, PCS-25, PCS-31, PCS-35, PCS-40, PCS-41, PCS-43 & PCS-45
- ALL CABLES ASSOCIATED WITH 'MP-X-X' IS ONLY TYPICAL FOR PCS SHELTER #s AS FOLLOWS:
PCS-03, PCS-16, PCS-21, PCS-40 & PCS-45
- ALL CABLEING TO ENTER EQUIPMENT THROUGH EXISTING PCS SHELTER CONDUITS AS INDICATED.
- REFER TO STRUCTURAL DWGS. FOR EXACT LOCATION OF PCS SHELTER AND TRANSFORMER.
- REFER TO THE FOLLOWING DRAWINGS FOR THE DC CABLEING FROM DC COMBINER BOX TO DC FUSE BOX:
A) PV ONE LINE DIAGRAMS
DWGS. NO. E-101 THROUGH E-108
B) UTILITY PLANS
DWGS. NO. E-111 THROUGH E-123 AND DWGS. NO. E-132 THROUGH E-144

SECTION D
E-501
PCS BUILDING ELEVATION

SCALE: NTS

FIRST SOLAR DEVELOPMENT
(CANADA)
5115 BLACKWELL SIDEROAD
SARNIA, ONTARIO
N7T 7H3

elecsar
Elecsar Engineering Co. Limited
1149 Vanier Rd., Suite 1001
Sarnia, Ontario
N7T 3Y6

SARNIA SOLAR
PHOTOVOLTAIC
POWER PLANT
SITE PLAN CONTROL
AGREEMENT

REV	DATE	DESCRIPTION
1	8-5-09	REVISED FOR CONSTRUCTION
0	7-15-09	ISSUED FOR CONSTRUCTION


PROJ NO: 5025-0106-22
CAD DWG FILE: E-501
DRAWN BY: GC
CHECKED BY: GN
SCALE: AS SHOWN
COPYRIGHT BY: FIRST SOLAR

SHEET TITLE
TYP. PCS BLDG.
ELECTRICAL EQUIP.
ARRANGEMENT PLAN

E-501

SHEET OF

THIS PUBLICATION CONTAINS VALUABLE PROPRIETARY AND CONFIDENTIAL INFORMATION OF FIRST SOLAR, INC. ("FIRST SOLAR") WHO RESERVES ALL COPYRIGHT RIGHTS TO IT UNDER U.S. AND INTERNATIONAL LAW. ANY REPRODUCTION, PREPARATION OF DERIVATIVE WORKS, DISTRIBUTION, PUBLIC PERFORMANCE OR DISPLAY, DISCLOSURE, AND/OR USE OF ALL OR ANY PORTION OF THIS PUBLICATION IN ANY FORM OR MEDIUM WITHOUT SPECIFIC WRITTEN AUTHORIZATION FROM FIRST SOLAR IS STRICTLY PROHIBITED.



TRANSFORMER & PCS BUILDING ELEVATION VIEW
(SHOWING INVERTER "B")

SCALE: 1/2" = 1'-0"



REFERENCE STANDARD SPECIFICATION:

- DWG NO. E-001
ELECTRICAL TYPICAL NOTES, SYMBOLS & ABBREVIATIONS
- DWG NOS. S-301 THRU S-304
TYPICAL PCS BUILDING PLANS AND DETAILS
- DWG NO. E-503
TYP. PCS BLDG. ELECTRICAL EQUIP. ARRANGEMENT PLAN

FIRST SOLAR DEVELOPMENT
(CANADA)
5115 BLACKWELL SIDEROAD
SARNIA, ONTARIO
N7T 7H3

elecsar
Elecsar Engineering Co. Limited
1149 Vanier Rd., Suite 1001
Sarnia, Ontario
N7T 3Y6

SARNIA SOLAR
PHOTOVOLTAIC
POWER PLANT
SITE PLAN CONTROL
AGREEMENT

REV	DATE	DESCRIPTION
0	7-15-09	REISSUED FOR CONSTRUCTION
A	7-10-09	ISSUED FOR REVIEW
ISSUE: 2-28-08		


PROJ NO: 5025-0106-22
CAD DWG FILE: E-504
DRAWN BY: GC
CHECKED BY: RF
SCALE: AS NOTED
COPYRIGHT BY: FIRST SOLAR
SHEET TITLE

TYPICAL PCS
BUILDING
SECTION & DETAIL

E-504


SHEET OF

Confidential Information: The contents of this document are subject to a Non-Disclosure Agreement and shall not be disclosed.




TYPICAL FRONT ELEVATION/VAULT PLAN

- NOTES:**
- A1.** PCS VAULT/FOUNDATION SHALL BE OF PRECAST CONCRETE, THICKNESS OF SLAB AND WALLS SHALL BE DESIGNED BY THE VENDOR. ASSUME MIN. BEARING CAPACITY AT 2,000 PSF.
 - A2.** 16"x48"x7" THK CONCRETE STEP SHALL BE ATTACHED TO THE VAULT MONOLITHICALLY OR APPROVED METHOD
 - A3.** GRAVEL BASE AND OTHER SITEWORKS SHALL BE PERFORMED BY OTHERS.
 - A4.** SEE DRAWING E-501 FOR FOUNDATION WALL OPENINGS.



TYPICAL PCS ROOF FRAMING PLAN

- NOTE:**
- E1.** ROOF CONSTRUCTION: ROOF OF THE SHELTER SHALL BE OF PRECAST CONCRETE, THICKNESS SHALL BE DESIGNED BY THE VENDOR BASED FROM THE SPECIFIED DESIGN CRITERIA.
 - E2.** TAPER ROOF TO MAINTAIN A SLOPE OF 12 FT. (H): 2" (V) FROM NORTH DRAINING TO SOUTH SIDE.
 - E3.** PROVIDE REGLET 3/4" X 3/4" X BUILDING LENGTH AT THE UNDERSIDE OF THE 3" OVERHANG AT SOUTH SIDE ONLY.
 - E4.** PROVIDE OPENING AT ROOF AS NEEDED.



TYPICAL FLOOR PLAN

- NOTES:**
- B1.** FLOOR CONSTRUCTION: FLOOR OF THE SHELTER SHALL BE OF PRECAST CONCRETE, THICKNESS SHALL BE DESIGNED BY THE VENDOR BASED FROM THE SPECIFIED DESIGN CRITERIA.
 - B2.** PROVIDE OPENING ON FLOOR AS INDICATED.

- REFERENCE NOTES:**
- 1. DWS NO. E-501
PCS ELECTRICAL EQUIPMENT PLAN.


- GENERAL NOTES:**
- 1. WORK THIS DWG. WITH THE STANDARD SPECIFICATION.
 - 2. VENDOR TO COORDINATE OPENING LOCATIONS WITH ELECTRICAL DRAWINGS.
 - 3. VAULT EXTERIOR MEASUREMENTS SHALL MATCH WITH PCS BUILDING EXTERIOR MEASUREMENTS.
 - 4. VENDOR SHALL PRE-FIT/PRE-ASSEMBLE VAULT AND PCS SHELTER AND PROVIDE MATCH MARKINGS TO ASSURE PERFECT ALIGNMENT OF VAULT AND PCS SHELTER ONCE DELIVERED AND ERECTED AT THE JOBSITE.
 - 5. VENDOR SHALL BE RESPONSIBLE FOR THE LOADING, TRUCKING TO THE JOBSITE, AND COORDINATION WITH THE OWNER DURING THE DELIVERY OF VAULTS AND PCS SHELTER TO THE JOBSITE.
 - 6. OWNER SHALL BE RESPONSIBLE FOR THE SUPPLY OF LIFTING EQUIPMENT, LABOR AND MISCELLANEOUS TOOLS AND MATERIALS DURING THE UNLOADING AND ERECTION OF THE VAULTS AND PCS SHELTER.
 - 7. VENDOR SHALL BE RESPONSIBLE FOR THE FOLLOWING EQUIPMENT AND ACCESSORIES AFTER THE ERECTION OF THE VAULTS AND PCS SHELTER BY THE OWNER, AS FOLLOWS:
 - A. INSTALLATION OF SEISMIC/CONNECTING PLATES FOR VAULTS AND SHELTER.
 - B. ENGINEER/DESIGN, SUPPLY AND ERECT HVAC UNITS INCLUDING ELECTRICAL HOOK-UPS.
 - C. ENGINEER/DESIGN, SUPPLY AND INSTALLATION OF AIR TERMINALS.
 - D. SUPPLY AND INSTALL PATCHING AT DEPRESSIONS FOR ALL LIFTING LUG LOCATIONS IN ANY PART OF THE VAULT OR PCS SHELTER AND APPLY FINAL COATINGS OR FINISH SURFACE WITH MATERIAL SIMILAR TO THE ADJACENT AREA.
 - E. SUPPLY AND APPLY SEALANT/MASTIC/CAULKS AT ALL POSSIBLE ENTRY POINTS OF WATER INCLUDING BUT NOT LIMITED TO THE JOINTS BETWEEN THE VAULTS AND THE PCS SHELTER, ATTACHMENT OF EXTERNAL EQUIPMENT AND ACCESSORIES, ETC.

STRUCTURAL DESIGN CRITERIA:

- CODE EDITIONS USED - OBC 2006, CAN/CSA-S16-01, CAN/CSA-S136-01
- OCCUPANCY GROUP - S-2
- OCCUPANCY CATEGORY: III
- TYPE CONSTRUCTION - VB
- LAND USE ZONE - RENEWABLE ENERGY
- SQUARE FOOTAGE/ALLOWABLE AREA - 224.25 SF
- HEIGHT - 11'-6" (APPROX.) ABOVE GRADE
- OCCUPANT LOAD (PCS) - 1
- FLOOR LIVE LOAD - 150 PSF (7.18 kPa) MAXIMUM
- FLOOR EQUIPMENT LOAD - 6,000 LBS
- WIND REFERENCE PRESSURES - q50 = 11.5 PSF (0.55 kPa) MAXIMUM
lw = 1.25
- NET SPECIFIED WIND LOAD - P = 11.8 kN ACTING PERPENDICULAR TO LONG WALL
P = 9.7 kN ACTING PERPENDICULAR TO SHORT WALL
- GROUND SNOW LOADS - 39.2 PSF (1.875 kPa) MAXIMUM
BASED ON - Ss = 1.1 kPa, Sr = 0.4 kPa, Is = 1.25
- ROOF LIVE LOAD (REDUCEABLE) - 20 PSF
- SEISMIC DESIGN CRITERIA -
SITE CLASSIFICATION "C"
Ta = 0.2 ± IN EACH DIRECTION
Fo = 1.0; Fv = 1.0
FOR ONTARIO: Sa(0.2) = 0.36, Sa(0.5) = 0.18, Sa(1.0) = 0.063, Sa(2.0) = 0.02
S(T) = 0.36
Ie = 1.5, Mv = 1.0, Rd = 2.0, Ro = 1.3
- CONCRETE: F'c = 5,000 PSI @ 28 DAYS
- REINFORCING STEEL: ASTM A-615, GRADE 60
- WIRE MESH: ASTM A-496 OR A-497


0	07-15-2009	ISSUED FOR CONSTRUCTION	G.C	KDK	TZ
B	06-04-2009	UPDATED DRAWING NUMBER	G.C	KDK	TZ
A	05-19-2009	ISSUED FOR PROPOSAL	G.C	KDK	TZ
REV	DATE	REVISION DESCRIPTION	BY	CHK	APP

	FIRST SOLAR 480 GOWENLOCK CORPORATE BLVD. SUITE 801 BIRMINGHAM, NEW JERSEY 08007 PHONE: 800-885-4888 FAX: 800-885-4888
FIRST SOLAR DEVELOPMENT (CANADA) 5115 BLACKWELL SIDEROAD SARNIA, ONTARIO N7T 7H3 SARNIA SOLAR PHOTOVOLTAIC POWER PLANT	
PROJECT: SARNIA SOLAR 2	
DRAWING: PCS SHELTER FLOOR AND VAULT PLANS	
PROJ. MGR. KEITH SYMERS PROJ. DIRECTOR MARK LANGDON FS ELEC. JOB No: 5025-0106-22	PROJ. ENGR. PHIL WONGMAKER DRAWING NO. S-301
DR. BY G.C CHK. KDK SCALE: 1/2"=1'-0"	REV. 0
THIS PRINT IS NOT TO BE USED FOR CONSTRUCTION UNLESS NOTED AND SIGNED OK FOR CONSTRUCTION ABOVE LAST REVISION.	



NOTES:

1. SEE DWG S-301 FOR ADDITIONAL NOTES.




TYPICAL FRONT ELEVATION




NOTES:

- D1. WALL CONSTRUCTION:
WALL OF THE SHELTER SHALL BE OF PRECAST CONCRETE, THICKNESS SHALL BE DESIGNED BY THE VENDOR BASED FROM THE SPECIFIED DESIGN CRITERIA.
- D2. EXTERIOR WALL SHALL BE PLAIN CEMENT FINISHED PAINTED WHITE.
- D3. PROVIDE OPENING ON WALLS AS INDICATED.
- D4. PROVIDE SEALANT AT ALL JOINTS/CONNECTIONS.



TYPICAL LEFT ELEVATION



NOTES:

- D1. WALL CONSTRUCTION:
WALL OF THE SHELTER SHALL BE OF PRECAST CONCRETE, THICKNESS SHALL BE DESIGNED BY THE VENDOR BASED FROM THE SPECIFIED DESIGN CRITERIA.
- D2. EXTERIOR WALL SHALL BE PLAIN CEMENT FINISHED PAINTED WHITE.
- D3. PROVIDE OPENING ON WALLS AS INDICATED.
- D4. PROVIDE SEALANT AT ALL JOINTS/CONNECTIONS.

0	07-15-2009	ISSUED FOR CONSTRUCTION	G.C	KDK	TZ
B	06-04-2009	UPDATED DRAWING NUMBER	G.C	KDK	TZ
A	05-19-2009	ISSUED FOR PROPOSAL	G.C	KDK	TZ
REV	DATE	REVISION DESCRIPTION	BY	CHK	APP
		<div>FIRST SOLAR 480 SOMERSET CORPORATE BLVD. SUITE 801 BIRMINGHAM, NEW JERSEY 08007 PHONE: 205-992-4500 FAX: 205-992-4500</div>			
<div>FIRST SOLAR DEVELOPMENT (CANADA) 5115 BLACKWELL SIDEROAD SARNIA, ONTARIO N7T 7H3 SARNIA SOLAR PHOTOVOLTAIC POWER PLANT</div>					
PROJECT: SARNIA SOLAR 2					
DRAWING: PCS SHELTER EXTERIOR ELEVATIONS					
PROJ. MGR. KEITH SYMMERS	PROJ. ENGR. PHIL WONGMAKER	DR. BY G.C	CHK. BY KDK	SCALE: AS NOTED	REV.
PROJ. DIRECTOR MARK LANGDON	DRAWING NO.	S-302		0	
FS ELEC. JOB No:					
5025-0106-22					
THIS PRINT IS NOT TO BE USED FOR CONSTRUCTION UNLESS NOTED AND SIGNED OK FOR CONSTRUCTION ABOVE LAST REVISION.					



1 WALL INTERIOR ELEVATION



NOTES:

1. SEE DWG SS-17000-SK-S01 FOR ADDITIONAL NOTES.

0	07-15-2009	ISSUED FOR CONSTRUCTION		RTE	KDK
B	06-04-2009	UPDATED DRAWING NUMBER		G.C	KDK
A	05-19-2009	ISSUED FOR PROPOSAL		G.C	KDK
REV	DATE	REVISION DESCRIPTION		BY	CHK/A



FIRST SOLAR
400 SCHMIDT CORPORATE BLVD
SUITE 501
SPRINGWATER, NEW JERSEY 07081
PHONE: (908) 922-4000
FAX: (908) 922-4000







**FIRST SOLAR DEVELOPMENT (CANADA)
5115 BLACKWELL SIDEROAD
SARNIA, ONTARIO N7T 7H3
SARNIA SOLAR PHOTOVOLTAIC POWER PLANT**

PROJECT:	SARNIA SOLAR 2
----------	-----------------------

PCS SHELTER INTERIOR ELEVATIONS

PROJ. MGR. KEITH SYMMERS	PROJ. ENGR. PHIL NONENMAKER	DR. BY G.C	CHK. BY KDK	SCALE: 1/2"=1'-0"	REV
PROJ. DIRECTOR MARK LANGDON	DRAWING NO.	S-303			0
FS ELEC. JOB No:					
5025-0108-22					


THIS PRINT IS NOT TO BE USED FOR CONSTRUCTION UNLESS NOTED
AND SIGNED OK FOR CONSTRUCTION ABOVE LAST REVISION.



1. SEE DWG S-301 FOR ADDITIONAL NOTES.





		FIRST SOLAR 488 GOSWORTHY CORPORATE BLVD. SUITE 501 BRIDGEWATER, NEW JERSEY 08807 PHONE: (908) 595-4555 FAX: (908) 595-4555			
FIRST SOLAR DEVELOPMENT (CANADA) 5115 BLACKWELL SIDERoad SARNIA, ONTARIO N7T 7T5 SARNIA SOLAR PHOTOVOLTAIC POWER PLANT					
PROJECT:		SARNIA SOLAR 2			
DRAWING:					
PCS SHELTER DETAILS AND SECTIONS					
PROJ. MGR. KEITH SUMMERS	PROJ. ENGR. PHIL. NOMEKMER	DR. BY CC	CHK. BY KOK	SCALE: AS NOTED	REV.
PROJ. DIRECTOR MARK LANGDON	DRAWING NO.	S-304			0
FS ELEC. JOB No: 5025-0106-22					
THIS PRINT IS NOT TO BE USED FOR CONSTRUCTION UNLESS NOTED AND SIGNED OK FOR CONSTRUCTION ABOVE. LAST REVISION					

THIS PUBLICATION CONTAINS VALUABLE PROPRIETARY AND CONFIDENTIAL INFORMATION OF FIRST SOLAR, INC. ("FIRST SOLAR") WHO RETAINS ALL COPYRIGHT RIGHTS TO IT UNDER 17 U.S.C. SECTION 106 AND IS PROTECTED BY U.S. AND INTERNATIONAL LAW. ANY REPRODUCTION, PREPARATION OF DERIVATIVE WORKS, DISTRIBUTION, PUBLIC PERFORMANCE OR DISPLAY, DISCLOSURE, AND/OR USE OF ALL, OR ANY PORTION, OF THIS PUBLICATION IN ANY FORM OR MEDIUM WITHOUT SPECIFIC WRITTEN AUTHORIZATION FROM FIRST SOLAR IS STRICTLY PROHIBITED.




GROUND BUSHING/LOCKNUT LAYOUT

(6) 4" PER WIREWAY



- Enclosure Options:
1. Pueblo Tan Stucco Embossed Aluminum Siding w/ Painted Siding Screws.
 2. 1" Black Skid Guard Floors
 3. Purchased Metal Doors.
 4. Pueblo Tan Stucco Embossed Aluminum Standing Seam Roof.
 5. Insulated Walls & Ceiling (R4.2) .
 6. All Siding Seams To Be Caulked.
 7. Floor To Be Covered w/ Removable Vinyl/Masonite Type Material For Protection During Installation.
 8. (8) 1/4" Painted Anchor Plates to Ship Loose with each unit.



(8) 1/4" ANCHOR PLATES #100729 TO BE PAINTED GRAY AND TO SHIP LOOSE WITH EACH UNIT.

SHIPPING DIMS:
30'-1"L X 11'-8 1/2"W X 10'-2"H
APPROX WGT: 37,800 LBS



PROJECT	PROJECT # 5032-0101-23	PROJECT NAME
LOCATION	TILBURY, ONTARIO, CANADA	TILBURY 5
PRODUCT	# S-T-M-1-CEC-3-1-SS-0-0-1.0	
PCS-M4		
DRAWING TITLE		DRAWING #
PCS SHELTER SKID OUTLINE DRAWING		HP-S-100
FIRST SOLAR		DRAWN BY:
PCS - POWER CONVERSION STATION		GC
		ENG. APPROVAL:
Hill PHOENIX EXCELLENCE® 709 SIGMAN ROAD CONYERS, GA 30013 PHONE (770) 285-3100 FAX (770) 285-3076 A DOVER COMPANY		DATE: 20 APR 2010
		SCALE: NONE
		JOB NUMBER 58820-ED
CAD FILE NAME: G:\EDP\JOB FILES\58820-58825 TILBURY FIRST SOLAR\STRUCTURAL DRAWINGS\58820-ED\HP-S-100.M REV 1.DWG LAYOUT1		SHEET: 1 OF 5

REVISION RECORD			
REV	DATE	BY	DESCRIPTION
0	20 APR 2010	GC	RELEASED FOR PRODUCTION
1	30 JUL 2010	GC	REMOVED RAILING & LIGHTNING PROTECT. ADDED SPLICE BOX & XFMR LOCK. CHGD XFMR SIZE & WW LAYOUT
2	18 AUG 2010	GC	ADDED NOTE FOR IPLASTIC INSULATION BUSHINGS.




MANHOLE PARTS LIST		
QTY.	1/4" STEEL SMOOTH PLATE	ITEM
1	3'-11 5/8" X 3'-11"	M1
4	13 3/4"x13 3/4" CORNER PC	M2
1	3'-2 3/4" DIA.	M3

↳ PART #100894





ITEM	DESCRIPTION	WT/FT.	REQ.	FT.	IN.	DWG #
A	10" CHANNEL	15.3	2	28	8 3/4	
B	10" CHANNEL	15.3	3	11	3	
C	6" WIDE FLANGE IBEAM	9	13	11	3	
D	6" WIDE FLANGE IBEAM	9	2	9	9 9/16	
E	6" WIDE FLANGE IBEAM	9	2	7	5	
F	6" WIDE FLANGE IBEAM	9	1	10	1 5/8	
MM	6" WIDE FLANGE IBEAM	9	1	7	2 3/4	
AA	STD. 4" CHANNEL	5.4	2	1	11	
FF	STD. 4" CHANNEL	5.4	1	2	6	
LL	STD. 4" CHANNEL	5.4	2	8	10 1/2	
UU	STD. 4" CHANNEL	5.4	2	3	0	
G	STD. 6" CHANNEL	8.2	1	2	5 7/8	
H	STD. 6" CHANNEL	8.2	1	2	9 13/16	
J	STD. 6" CHANNEL	8.2	1	3	9 3/4	
L	STD. 6" CHANNEL	8.2	1	3	3 9/16	
M	STD. 6" CHANNEL	8.2	1	1	5 1/2	
BB	STD. 6" CHANNEL	8.2	6	1	0 5/16	
CC	STD. 6" CHANNEL	8.2	2	0	10 3/4	
RR	STD. 6" CHANNEL	8.2	1	3	3 11/16	
KK	STD. 6" CHANNEL	8.2	2	1	4	
P	3"X 3"X 1/4" ANGLE	4.9	1	10	10	
Q	3"X 3"X 1/4" ANGLE	4.9	1	10	0	
N	2" X 2" X 3/16" ANGLE	2.44	2	0	11 1/2	
GG	2" X 2" X 3/16" ANGLE	2.44	1	2	10	
HH	2" X 2" X 3/16" ANGLE	2.44	1	2	6	
R	2" X 2" X 3/16" ANGLE	2.44	1	1	3 3/16	
S	2" X 2" X 3/16" ANGLE	2.44	2	0	11 1/16	
T	2" X 2" X 3/16" ANGLE	2.44	3	1	0 15/16	
V	2" X 2" X 3/16" ANGLE	2.44	1	0	10 3/4	
W	2" X 2" X 3/16" ANGLE	2.44	2	0	11 1/2	
DD	2" X 2" X 3/16" ANGLE	2.44	1	0	4 7/8	
EE	2" X 2" X 3/16" ANGLE	2.44	1	0	3 3/4	
X	2 7/8 X 4 7/16 HAT SECTION	11 GA.	1	4	2 1/2	100692
Y	2 7/8 X 4 7/16 HAT SECTION	11 GA.	1	7	5	100693
Z	2 7/8 X 4 7/16 HAT SECTION	11 GA.	1	6	9 1/2	100694
ZZ	2 7/8 X 4 7/16 HAT SECTION	11 GA.	1	7	8	100695
	ANCHOR PLATE, PAINTED GRAY	1/4	8		8"x13"x1/4"	100729
	LIFT LUGS		8			
	1" SKID GUARD FLOORING					

SHIP LOOSE





PROJECT	PROJECT # 5032-0101-23	PROJECT NAME
LOCATION	TILBURY, ONTARIO, CANADA	TILBURY 5
PRODUCT	# S-T-M-1-CEC-3-1-SS-0-0-1.0	
PCS-M4		
DRAWING TITLE	PCS SHELTER BASE FRAME LAYOUT DRAWING	DRAWING # HP-S-100
FIRST SOLAR PCS - POWER CONVERSION STATION		DRAWN BY: GC ENG. APPROVAL:
Hill PHOENIX E X C E L L E N C E [®] 709 SIGMAN ROAD CONYERS, GA 30013 PHONE (770) 285-3100 FAX (770) 285-3076 		DATE: 20 APR 2010 SCALE: NONE JOB NUMBER 58820-ED SHEET: 2 OF 5
CAD FILE NAME: G:\EXP\JOB FILES\58820-58825\TILBURY FIRST SOLAR\STRUCTURAL DRAWINGS\58820-ED-HP-S-100 MM REV 1.DWG\LAYOUT1		

REVISION RECORD			
REV	DATE	BY	DESCRIPTION
0	20 APR 2010	GC	RELEASED FOR PRODUCTION
1	30 JUL 2010	GC	REMOVED RAILING & LIGHTNING PROTECT. ADDED SPLICE BOX & XFMR LOCK. CHGD XFMR SIZE & WW LAYOUT
2	18 AUG 2010	GC	ADDED NOTE FOR IPLASTIC INSULATION BUSHINGS.


WALL/ROOF FRAME CUT LIST		
DESCRIPTION	QTY.	LENGTH
6" X 14 GA. Z-BRACKET	4	106 1/4
6" X 14 GA END Z-BRACKET	2	135 3/8
6" Z-BRACKET SPLICE PLATE	2	10
3 1/2" X 5 1/8" 16GA C-ROOF BOW	10	135 1/4
3" X 16 GA STRIPS	3	120
3" X 16 GA STRIPS	3	92 1/4
4 1/2" WALL POST X 14 GA	11	112 7/8
4 1/2" WALL POST X 14 GA	2	50 1/2"
4 1/2" WALL POST X 14 GA	2	99 5/16"
4 1/2" WALL POST X 14 GA	2	98 5/16"
4 1/2" WALL POST X 14 GA	12	111 7/8
4 1/2" WALL POST X 14 GA	4	24 1/4
4 1/2" WALL POST X 14 GA	1	8 1/4
4 1/2" WALL POST X 14 GA	2	46 3/8
2 1/8" X 4 1/2" WALL POST X 14 GA	1	13 5/8
4 1/2" WALL POST X 14 GA	2	112 1/2
4 1/2" WALL POST X 14 GA	1	8 7/8
3" X 4 1/2" WALL POST X 14 GA	1	112 1/8
3" X 4 1/2" WALL POST X 14 GA	1	112 5/16
2 3/8" x 4 1/2" WALL POST X 14 GA	2	111 7/8
7 3/16" WALL POST X 14 GA	1	111 7/8
7 3/16" WALL POST X 14 GA	1	112 5/8
4" WALL POST X 14 GA	1	99 5/16"
4" WALL POST X 14 GA	1	98 5/16"
3" WALL POST X 14 GA	2	50 1/2"
2 7/8" WALL POST X 14 GA	1	111 7/8
2 7/8" WALL POST X 14 GA	1	112 7/16
3 1/2" WALL POST X 14 GA	1	111 7/8
3 1/2" WALL POST X 14 GA	1	112 7/16
4 1/2" X 2 1/8" DOOR POST	1	112 1/16
4 1/2" X 2 1/8" DOOR POST	1	112 7/16
4 1/2"X2 1/8" DOOR HEADER-14 GA	1	44"
EXHAUST PLENUMS, INVERTER BTM REAR-14 GA	2	5 7/8 X 50 7/16
PAN, SP-1 & FIBER OPTIC CHASE FILLER	1	26 15/16X49 6/16
20 X 32 7/8 RAIN HOOD TOP W/BIRD SCREEN	2	32 7/8
20 X 32 7/8 RAIN HOOD BTM W/BIRD SCREEN	4	32 7/8
12 X 57 1/2 RAIN HOOD W/BUG SCREEN	2	57 1/2
FILTER FRAME PANEL, 14 GA.	2	24 1/16 X 51 1/4
Z-BRKT, FILTER FRAME, 14 GA.	4	23 3/8
HAT-SHAPED BRKT, FILTER FRAME, 14 GA.	2	23 13/16
FILTER END COVER, 14 GA.	2	50 1/2
17X3X16 WIREWAY W/(3) CUTOUTS	1	17X3X16
17X12X55 7/8 WIREWAY W/CUTOUT	1	55 7/8
16X15X73 7/8 WIREWAY W/(3) CO	1	73 7/8
SUPPORT, EXT. WIREWAY	1	36X31 7/16
STD 1" WALL & ROOF INSULATION W/SOLID LINERS		
PUEBLO TAN EMBOSSED ALUM. WALL & ROOF SKINS		
STD. 5/8" OSB WAFFERBOARD ROOF UNDERLAYMENT		



WAFFERBOARD FASTENING DETAILS
(SCREW HEADS TO BE FLUSH OR
BELOW SURFACE OF WAFFERBOARD)
USE #8 MINIMUM SCREWS.



ROOF FRAME LAYOUT





WALL POST LAYOUT

PROJECT	PROJECT # 5032-0101-23	PROJECT NAME
LOCATION	TILBURY, ONTARIO, CANADA	TILBURY 5
PRODUCT	# S-T-M-1-CEC-3-1-SS-0-0-1.0	
PCS-M4		
DRAWING TITLE		DRAWING #
PCS SHELTER WALL & ROOF DETAILS		HP-S-100


REVISION RECORD			
REV	DATE	BY	DESCRIPTION
0	20 APR 2010	GC	RELEASED FOR PRODUCTION
1	30 JUL 2010	GC	REMOVED RAILING & LIGHTNING PROTECT. ADDED SPLICE BOX & XFMR LOCK. CHGD XFMR SIZE & WW LAYOUT
2	18 AUG 2010	GC	ADDED NOTE FOR IPLASTIC INSULATION BUSHINGS.

FIRST SOLAR PCS - POWER CONVERSION STATION		DRAWN BY: GC
Hill PHOENIX EXCELLENCE® 709 SIGMAN ROAD CONYERS, GA 30013 PHONE (770) 285-3100 FAX (770) 285-3076		ENG. APPROVAL:
CAD FILE NAME: G:\EDP JOB FILES\58820-58825 TILBURY FIRST SOLAR\STRUCTURAL DRAWINGS\58820-ED\HP-S-100.M REV 1.DWG LAYOUT 1		DATE: 20 APR 2010
		SCALE: NONE
		JOB NUMBER 58820-ED
		SHEET: 3 OF 5





INSTALL EXHAUST
PLENUM #100705 IN
OPENING. PUSH
FLANGES AGAINST
REAR OF INVERTER
AND SCREW IT TO
WALL POSTS.

EXTERIOR VIEW 'A'
(FRONT)




(ADD DRIP ANGLE ABOVE DOOR)

EXTERIOR VIEW 'B'
(RIGHT END)



INSTALL EXHAUST
PLENUM #100705 IN
OPENING. PUSH
FLANGES AGAINST
REAR OF INVERTER
AND SCREW IT TO
WALL POSTS.

EXTERIOR VIEW 'C'
(REAR)



EXTERIOR VIEW 'D'
(LEFT END)

PROJECT	PROJECT # 5032-0101-23	PROJECT NAME
LOCATION	TILBURY, ONTARIO, CANADA	TILBURY 5
PRODUCT	# S-T-M-1-CEC-3-1-SS-0-0-1.0	
PCS-M4		
DRAWING TITLE		DRAWING #
PCS SHELTER WALL EXTERIOR VIEWS		HP-S-100

REVISION RECORD			
REV	DATE	BY	DESCRIPTION
0	20 APR 2010	GC	RELEASED FOR PRODUCTION
1	30 JUL 2010	GC	REMOVED RAILING & LIGHTNING PROTECT. ADDED SPLICE BOX & XFMR LOCK. CHGD XFMR SIZE & WW LAYOUT
2	18 AUG 2010	GC	ADDED NOTE FOR IPLASTIC INSULATION BUSHINGS.


FIRST SOLAR PCS - POWER CONVERSION STATION		DRAWN BY: GC
Hill PHOENIX EXCELLENCE® 709 SIGMAN ROAD CONYERS, GA 30013 PHONE (770) 285-3100 FAX (770) 285-3076		ENG. APPROVAL:
CAD FILE NAME: G:\EDP\JOB FILES\58820-58825 TILBURY FIRST SOLAR\STRUCTURAL DRAWINGS\58820-ED\HP-S-100.M4 REV 1.DWG LAYOUT 1		DATE: 20 APR 2010
		SCALE: NONE
		JOB NUMBER 58820-ED
		SHEET: 4 OF 5

AT THE TOP & BOTTOM
OF FRAME, POP-RIVET
A Z-SHAPED FILTER FRAME
BRKT #100665 TO THE
INSIDE. 2 PL.

ATTACH (2) PCS OF $\frac{1}{8}$ "x1"
NEOPRENE GASKET TO COVER
ANGLE #100670 BEFORE
INSTALLING IT ON FILTER FRAME
HALF WITH (6) #10 HEX WH HD
SELF-TAPPING SCREWS.

AT THE MIDDLE OF THE
FRAME, POP-RIVET A
HAT SHAPED FILTER FRAME
BRKT #100668 TO THE INSIDE.


ATTACH (2) PCS OF $\frac{1}{8}$ "x1"
NEOPRENE GASKET TO
INSIDE WALL OF THE
FILTER FRAME HALF.
2 PL.



FILTER FRAME
#100727.

FILTER FRAME ASSY

ASSY'S NEEDED: 2




ATTACH $\frac{1}{4}$ -20 EYE
BOLT INTO BASE FRAME

ATTACH $\frac{3}{16}$ " DOOR CHAIN
ASSEMBLY TO $\frac{1}{4}$ -20 EYE
BOLT AND CLASP.
TYP BOTH DOORS

ATTACH $\frac{1}{4}$ -20 EYE BOLT
THROUGH DOOR

DETAIL A



ATTACH $\frac{3}{16}$ " DOOR CHAIN
ASSEMBLY TO OUTSIDE
OF DOOR AND AT
BASEFRAME.
TYP BOTH DOORS

DETAIL B

REVISION RECORD			
REV	DATE	BY	DESCRIPTION
$\triangle 0$	20 APR 2010	GC	RELEASED FOR PRODUCTION
$\triangle 1$	30 JUL 2010	GC	REMOVED RAILING & LIGHTNING PROTECT. ADDED SPLICE BOX & XFMR LOCK. CHGD XFMR SIZE & WW LAYOUT
$\triangle 2$	18 AUG 2010	GC	ADDED NOTE FOR IPLASTIC INSULATION BUSHINGS.
\triangle			

PROJECT	PROJECT # 5032-0101-23	PROJECT NAME
LOCATION	TILBURY, ONTARIO, CANADA	TILBURY 5
PRODUCT	# S-T-M-1-CEC-3-1-SS-0-0-1.0	
PCS-M4		
DRAWING TITLE	DRAWING #	
PCS SHELTER FILTER FRAME ASSEMBLY	HP-S-100	
FIRST SOLAR PCS - POWER CONVERSION STATION		DRAWN BY: GC
Hill PHOENIX EXCELLENCE [®] 709 SIGMAN ROAD CONYERS, GA 30013 PHONE (770) 285-3100 FAX (770) 285-3076 A DOVER COMPANY		ENG. APPROVAL:
CAD FILE NAME: G:\EDP\JOB FILES\58820-58820-ED\TILBURY FIRST SOLAR\STRUCTURAL DRAWINGS\58820-ED\HP-S-100.MA REV 1.DWG LAYOUT1		DATE: 20 APR 2010
		SCALE: NONE
		JOB NUMBER 58820-ED
		SHEET: 5 OF 5



APPENDIX E

Source Sound Levels

Estimated Source PWL from Measurement data, dB re. 20×10^{-12} W



Description	Data Source	31.5	63	125	250	500	1000	2000	4000	8000	dBA
Pauwels 1000 kVA 27600Y/15935 2X 208Y/120 Transformer	Measured (Appendix G)	71	74	72	71	68	64	60	61	57	70
Xantrex Inverter Enclosure	Measured (Appendix G)	84	81	84	85	85	84	80	75	85	89
SMA Inverter	Measured (Appendix G)	80	81	75	79	79	73	75	77	72	83



APPENDIX F

Equipment Calibration

CERTIFICATE of CALIBRATION

Make : PCB Piezotronics

Reference # : 88771

Model : 377A60A

Customer : Golder Associates Ltd
Mississauga, ON

Descr. : Microphone

Serial # : 1022

P. Order : Stefan

Asset # : MS000008

Cal. status : Received in spec's, no adjustment made.
Tested with L&D LS3000+ s# 182

JOLA Instruments Inc. certifies that the above listed instrument was calibrated on date noted and was released from this laboratory performing in accordance with the specifications set forth by the manufacturer.

Unless otherwise noted in the calibration report a 4:1 accuracy ratio was maintained for this calibration.

Our calibration system complies with the requirements of ISO-17025 standard, working standards used for calibration are certified by or traceable to the National Research Council of Canada or the National Institute of Standards and Technology.

Calibrated : Jan 06, 2009

By :



Cal. Due : Jan 06, 2010

J. Raposo

Temperature : 23 °C ± 2 °C Relative Humidity : 45 % ± 20 %

Standards used : J-129 J-163 J-216

JOLA Instruments Inc.

REPAIR AND CALIBRATION TRACEABLE TO NRC AND NIST

88 Judge Rd. Toronto, ON, M8Z 5B4
Phone : 416 234 0354

Fax: 416 234 9562

<http://www.jola.com>
e-Mail: jola@jola.com

The copyright of this document is the property of JOLA Instruments Inc.
Any reproduction other than in full requires written approval!

CERTIFICATE of CALIBRATION

Make : Larson Davis

Reference # : 88581

Model : 3000+

Customer : Golder Associates Ltd
Mississauga, ON

Descr. : Analyzer FFT 2ch, SLM type 1

Serial # : 182

P. Order : Stefan

Asset # : MS000009

Cal. status : Received in spec's, no adjustment made.
With PRM902s#3553 and PCB 377A60 s#1022

JOLA Instruments Inc. certifies that the above listed instrument was calibrated on date noted and was released from this laboratory performing in accordance with the specifications set forth by the manufacturer.

Unless otherwise noted in the calibration report a 4:1 accuracy ratio was maintained for this calibration.

Our calibration system complies with the requirements of ISO-17025 standard, working standards used for calibration are certified by or traceable to the National Research Council of Canada or the National Institute of Standards and Technology.

Calibrated : Jan 05, 2009

By :



J. Raposo

Cal. Due : Jan 05, 2010

Temperature : 23 °C ± 2 °C Relative Humidity : 45 % ± 20 %

Standards used : J-203 J-215 J-216

JOLA Instruments Inc.

REPAIR AND CALIBRATION TRACEABLE TO NRC AND NIST

88 Judge Rd. Toronto, ON, M8Z 5B4
Phone : 416 234 0354

Fax: 416 234 9562

[http:// www.jola.com](http://www.jola.com)
e-Mail: jola@jola.com

The copyright of this document is the property of JOLA Instruments Inc.
Any reproduction other than in full requires written approval!

West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

CALIBRATOR

Manufactured By: **BRUEL & KJAER**
Model No.: **4230**
Serial No.: **565639**
Calibration Recall No.: **C6270**

Submitted by:

Customer:

Company: **Golder Associates Ltd.**
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Specification No. **4230 B&K** (see attached)

Upon receipt for Calibration, the instrument was found to be:

Within (**X**) see attached Report of Calibration

the tolerance of the indicated specification.


West Caldwell Calibration Laboratories' calibration control system meets the following requirements, ISO 10012-1 MIL-STD- 45662A, ANSI/NCSL, Z540-1, IEC Guide 25, ISO 9001:2000 and ISO/IEC 17025:2005

Note: With this Certificate, Report of Calibration is included.

Calibration Date: **08 March 2007**

Certificate No: **C6270 -4**

Approved by:


Stanley Christopher
Quality Manager

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

West Caldwell Calibration Laboratories, Inc.
uncompromised calibration
220 Rutherford Rd. S., Unit 210, Brampton, Ontario L6W 3J6 Canada

ISO 9001:2000
Registered Company

Calibration Traceable
To N. I. S. T.

Phone: (905) 595-1107

Fax: (905) 595-1108



Certificate of Calibration and Conformance

Certificate Number 2009-120808

Instrument Model 2260, Serial Number 0263, was calibrated on 04AUG2009. The instrument meets factory specifications per Procedure D0001.8089.

New Instrument

Date Calibrated: 04AUG2009

Calibration due:

Calibration Standards Used

MANUFACTURER	MODEL	SERIAL NUMBER	INTERVAL	CAL. DUE	TRACEABILITY NO.
Hewlett Packard	34401A	US36015216	12 Months	06MAY2010	4342531
Larson Davis	LDSigGn / 2209	0097 / 0118	12 Months	20JUL2010	2009-120295

Reference Standards are traceable to the National Institute of Standards and Technology (NIST)

Calibration Environmental Conditions

Temperature: 24 ° Centigrade


Relative Humidity: 29 %

Affirmations

This Certificate attests that this instrument has been calibrated under the stated conditions with Measurement and Test Equipment (M&TE) Standards traceable to the U.S. National Institute of Standards and Technology (NIST). All of the Measurement Standards have been calibrated to their manufacturers' specified accuracy / uncertainty. Evidence of traceability and accuracy is on file at Provo Engineering & Manufacturing Center. An acceptable accuracy ratio between the Standard(s) and the item calibrated has been maintained. This instrument meets or exceeds the manufacturer's published specification unless noted.


This calibration complies with the requirements of ISO 17025 and ANSI Z540. The collective uncertainty of the Measurement Standard used does not exceed 25% of the applicable tolerance for each characteristic calibrated unless otherwise noted.

The results documented in this certificate relate only to the item(s) calibrated or tested. A one year calibration is recommended, however calibration interval assignment and adjustment are the responsibility of the end user. This certificate may not be reproduced, except in full, without the written approval of the issuer.

Signed: 
Technician: Jason Grace

Preamplifier Model: 2260-Low Serial Number: 0263
Certificate of Electrical Conformance

Frequency response of this model 2260-Low preamplifier was tested at a level of 1 Vrms with 18pF microphone capacitance and driving a short cable. Output level at 1kHz is 0.8914 Vrms (-0.999 dBV), uncertainty 0.033 dB. Results are displayed relative to the level at 1kHz.



Freq (Hz)	Measured (dB)	Uncert (dB)	Tolerance (dB)		Freq (Hz)	Measured (dB)	Uncert (dB)	Tolerance (dB)	
2.51	-16.84	0.075	n/a	n/a	630.96	-0.01	0.016	+0.10, -0.11	
3.16	-15.07	0.058	n/a	n/a	794.33	-0.00	0.016	+0.10, -0.11	
3.98	-13.28	0.058	n/a	n/a	1000.00	0.00	0.016	+0.11, -0.10	
5.01	-11.47	0.036	n/a	n/a	1258.90	0.00	0.016	+0.11, -0.10	
6.31	-9.71	0.036	n/a	n/a	1584.90	0.01	0.016	+0.12, -0.10	
7.94	-8.01	0.036	n/a	n/a	1995.30	0.01	0.016	+0.12, -0.10	
10.00	-6.42	0.016	n/a	n/a	2511.90	0.01	0.016	+0.12, -0.10	
12.59	-4.99	0.016	n/a	n/a	3162.30	0.01	0.016	+0.13, -0.10	
15.85	-3.75	0.016	n/a	n/a	3981.10	0.01	0.016	+0.13, -0.10	
19.95	-2.73	0.016	-1.20, -5.00		5011.90	0.00	0.016	+0.14, -0.10	
25.12	-1.93	0.016	-0.73, -3.30		6309.60	-0.01	0.016	+0.14, -0.11	
31.62	-1.34	0.016	-0.50, -2.20		7943.30	-0.03	0.016	+0.14, -0.13	
39.81	-0.92	0.016	-0.32, -1.50		10000.00	-0.07	0.016	+0.14, -0.16	
50.12	-0.62	0.016	-0.21, -1.05		12589.00	-0.11	0.016	n/a	n/a
63.10	-0.43	0.016	-0.11, -0.75		15849.00	-0.20	0.016	n/a	n/a
79.43	-0.29	0.016	-0.05, -0.52		19953.00	-0.33	0.016	n/a	n/a
100.00	-0.20	0.016	+0.00, -0.37		25250.00	-0.54	0.022	n/a	n/a
125.89	-0.14	0.016	+0.03, -0.30		31500.00	-0.84	0.022	n/a	n/a
158.49	-0.10	0.016	+0.05, -0.25		39750.00	-1.32	0.022	n/a	n/a
199.53	-0.07	0.016	+0.07, -0.21		50000.00	-2.00	0.022	n/a	n/a
251.19	-0.05	0.016	+0.08, -0.18		63000.00	-2.93	0.047	n/a	n/a
316.23	-0.04	0.016	+0.09, -0.16		79500.00	-4.12	0.047	n/a	n/a
398.11	-0.03	0.016	+0.09, -0.14		100000.00	-5.51	0.047	n/a	n/a
501.19	-0.02	0.016	+0.10, -0.12		126000.00	-7.10	0.063	n/a	n/a


Noise floor data: 1kHz (1/3 Octave) = 0.60 μ V, -4.4 dBuV, uncertainty = 0.47 dB
 Flat (20Hz-20kHz) = 5.0 μ V, 13.9 dBuV, uncertainty = 0.47 dB
 Awt = 2.7 μ V, 8.7 dBuV, uncertainty = 0.46 dB

Uncertainties are given as expanded uncertainty at ~95% confidence interval (k = 2).

Technician: Jason Grace Test Date: 04AUG2009

Preamplifier Model: 2260-High Serial Number: 0263
Certificate of Electrical Conformance

Frequency response of this model 2260-High preamplifier was tested at a level of 1 Vrms with 18pF microphone capacitance and driving a short cable. Output level at 1kHz is 0.9005 Vrms (-0.910 dBV), uncertainty 0.033 dB. Results are displayed relative to the level at 1kHz.



Freq (Hz)	Measured (dB)	Uncert (dB)	Tolerance (dB)		Freq (Hz)	Measured (dB)	Uncert (dB)	Tolerance (dB)	
2.51	-16.94	0.075	n/a	n/a	630.96	-0.01	0.016	+0.10,	-0.11
3.16	-15.12	0.058	n/a	n/a	794.33	-0.01	0.016	+0.10,	-0.11
3.98	-13.29	0.058	n/a	n/a	1000.00	0.00	0.016	+0.11,	-0.10
5.01	-11.46	0.036	n/a	n/a	1258.90	0.00	0.016	+0.11,	-0.10
6.31	-9.67	0.036	n/a	n/a	1584.90	0.01	0.016	+0.12,	-0.10
7.94	-7.96	0.036	n/a	n/a	1995.30	0.01	0.016	+0.12,	-0.10
10.00	-6.37	0.016	n/a	n/a	2511.90	0.01	0.016	+0.12,	-0.10
12.59	-4.94	0.016	n/a	n/a	3162.30	0.01	0.016	+0.13,	-0.10
15.85	-3.70	0.016	n/a	n/a	3981.10	0.01	0.016	+0.13,	-0.10
19.95	-2.69	0.016	-1.20,	-5.00	5011.90	0.00	0.016	+0.14,	-0.10
25.12	-1.90	0.016	-0.73,	-3.30	6309.60	-0.01	0.016	+0.14,	-0.11
31.62	-1.32	0.016	-0.50,	-2.20	7943.30	-0.03	0.016	+0.14,	-0.13
39.81	-0.90	0.016	-0.32,	-1.50	10000.00	-0.06	0.016	+0.14,	-0.16
50.12	-0.61	0.016	-0.21,	-1.05	12589.00	-0.11	0.016	n/a	n/a
63.10	-0.42	0.016	-0.11,	-0.75	15849.00	-0.20	0.016	n/a	n/a
79.43	-0.29	0.016	-0.05,	-0.52	19953.00	-0.32	0.016	n/a	n/a
100.00	-0.20	0.016	+0.00,	-0.37	25250.00	-0.53	0.022	n/a	n/a
125.89	-0.14	0.016	+0.03,	-0.30	31500.00	-0.83	0.022	n/a	n/a
158.49	-0.10	0.016	+0.05,	-0.25	39750.00	-1.29	0.022	n/a	n/a
199.53	-0.07	0.016	+0.07,	-0.21	50000.00	-1.96	0.022	n/a	n/a
251.19	-0.05	0.016	+0.08,	-0.18	63000.00	-2.88	0.047	n/a	n/a
316.23	-0.04	0.016	+0.09,	-0.16	79500.00	-4.05	0.047	n/a	n/a
398.11	-0.03	0.016	+0.09,	-0.14	100000.00	-5.43	0.047	n/a	n/a
501.19	-0.02	0.016	+0.10,	-0.12	126000.00	-7.01	0.063	n/a	n/a

Noise floor data: 1kHz (1/3 Octave) = 0.62 μ V, -4.1 dBuV, uncertainty = 0.47 dB
 Flat (20Hz-20kHz) = 5.2 μ V, 14.3 dBuV, uncertainty = 0.47 dB
 Awt = 2.8 μ V, 9.0 dBuV, uncertainty = 0.46 dB

Uncertainties are given as expanded uncertainty at ~95% confidence interval ($k = 2$).


Technician: Jason Grace Test Date: 04AUG2009

Model: 2260-Phase Serial Number: 0263

CH 1 Mic: 2640 1436

CH 2 Mic: 2640 1345

Phase errors for the probe. This Class 1 Intensity Probe was tested with a Residual-intensity calibrator model CAL 291. This data was taken after the probe was adjusted for phase with the two adjustors on the side of the probe handle.



Freq (Hz)	Measured (degree)	LD Tolerance (degree)	Spacer (mm)	Freq (Hz)	Measured (degree)	LD Tolerance (degree)	Spacer (mm)
50.12	0.0000	+0.1047, -0.1047	50	631.00	0.0200	+0.1711, -0.1711	12
63.10	-0.0100	+0.1318, -0.1318	50	794.30	0.0350	+0.2153, -0.2153	12
79.43	-0.0150	+0.1660, -0.1660	50	1000.00	0.0500	+0.2711, -0.2711	12
100.00	-0.0200	+0.2089, -0.2089	50	1259.00	0.0550	+0.3413, -0.3413	12
125.90	-0.0250	+0.0631, -0.0631	12	1585.00	0.1000	+0.4297, -0.4297	12
158.50	-0.0200	+0.0681, -0.0681	12	1995.00	0.1000	+0.5409, -0.5409	12
199.50	-0.0100	+0.0681, -0.0681	12	2512.00	0.1500	+0.6810, -0.6810	12
251.20	-0.0100	+0.0681, -0.0681	12	3162.00	0.2000	+0.8574, -0.8574	12
316.20	-0.0100	+0.0857, -0.0857	12	3981.00	0.2500	+1.0800, -1.0800	12
398.10	0.0000	+0.1079, -0.1079	12	5012.00	0.3050	+1.3590, -1.3590	12
501.20	0.0100	+0.1359, -0.1359	12				

Limits are the smallest of ANSI S1.9-1996 table 7 or IEC 1043-1993 table 2 Class 1.

Technician: Jason Grace Test Date: 04AUG2009



APPENDIX G

Measurements

(Measured sound pressure level (L_{EQ}) in one third octave band format is given in this appendix. The data are given in dB re 20×10^{-6} Pa. The measurements were taken as a scan of the surface)

Frequency (Hz)	Transformer	Transformer	Transformer	Xantrex Intake	Xantrex Exhaust	Xantrex Cooling1	Xantrex Cooling2	SMA intake	SMA exhaust
25	51	52	51	72	75	68	70	55	69
31.5	52	55	52	66	72	63	68	55	69
40	50	51	50	62	70	65	68	59	76
50	50	53	51	59	69	64	67	62	75
63	56	58	58	65	67	67	70	58	74
80	51	48	45	65	66	69	71	55	73
100	53	50	44	66	65	69	71	55	71
125	56	55	58	73	73	72	73	61	66
160	46	41	37	68	70	70	70	55	65
200	55	45	39	70	65	72	73	51	63
250	53	54	51	74	66	71	75	56	69
315	51	48	45	74	74	72	78	64	76
400	51	50	47	72	78	70	73	57	74
500	52	51	44	70	69	68	70	61	70
630	46	47	41	69	69	68	70	56	71
800	47	46	37	74	69	74	76	52	66
1000	50	40	36	65	66	67	70	53	63
1250	44	38	35	69	67	68	73	54	68
1600	45	38	35	69	67	67	72	54	67
2000	41	35	34	63	66	64	71	52	63
2500	45	37	39	60	64	62	69	54	71
3150	48	37	44	58	63	59	67	55	75
4000	32	33	28	56	61	57	65	46	59
5000	36	42	40	61	58	59	66	45	57
6300	43	39	40	78	62	76	81	55	70
8000	34	34	34	59	52	59	66	42	56
10000	34	31	29	50	44	51	55	41	55



APPENDIX H

Weather Data

Weather DataSource: Environment Canada, Climate Data Online, www.climate.weatheroffice.ec.gc.ca/climateData/canada_e.html

Station: LONDON INT'L AIRPORT

Latitude: 43° 1.8' N Longitude: 82° 9' W

Date/Time	Time	Temp (°C)	Dew Point Temp (°C)	Rel Hum (%)	Wind Dir (10's deg)	Wind Spd (km/h)	Visibility (km)	Stn Press (kPa)	Wind Chill	Weather
8/6/2010	0:00	19	15	78	34	13	24	97.61		Clear
8/6/2010	1:00	18	15	81	29	6	24	97.65		Clear
8/6/2010	2:00	17	14	84	32	4	24	97.67		Mainly Clear
8/6/2010	3:00	17	14	81	29	7	24	97.67		Mostly Cloudy
8/6/2010	4:00	18	12	68	32	7	24	97.68		Mainly Clear
8/6/2010	5:00	17	12	71	34	6	24	97.74		Mostly Cloudy
8/6/2010	6:00	17	12	73	32	4	24	97.76		Mostly Cloudy
8/6/2010	7:00	18	13	71	31	6	24	97.81		Mainly Clear
8/6/2010	8:00	19	12	62	35	9	24	97.85		Mostly Cloudy
8/6/2010	9:00	20	12	60	28	7	24	97.90		Mainly Clear
8/6/2010	10:00	22	12	52	28	7	24	97.90		Mostly Cloudy
8/6/2010	11:00	22	12	53	29	13	24	97.92		Mostly Cloudy
8/6/2010	12:00	23	15	62	26	15	24	97.91		Mostly Cloudy
8/6/2010	13:00	23	13	52	27	17	24	97.86		Mostly Cloudy
8/6/2010	14:00	24	13	50	27	17	24	97.82		Mostly Cloudy
8/6/2010	15:00	24	14	53	28	24	24	97.81		Mostly Cloudy
8/6/2010	16:00	24	14	54	31	15	24	97.81		Mostly Cloudy
8/6/2010	17:00	24	14	54	31	15	24	97.86		Mostly Cloudy
8/6/2010	18:00	22	13	55	31	13	24	97.87		Mainly Clear
8/6/2010	19:00	21	12	58	33	17	24	97.92		Mainly Clear
8/6/2010	20:00	19	11	62	26	11	24	97.99		Mainly Clear
8/6/2010	21:00	17	11	67	1	7	24	98.10		Mainly Clear
8/6/2010	22:00	16	11	71	36	6	24	98.12		Clear
8/6/2010	23:00	14	11	78	3	9	24	98.15		Clear

At Golder Associates we strive to be the most respected global group of companies specializing in ground engineering and environmental services. Employee owned since our formation in 1960, we have created a unique culture with pride in ownership, resulting in long-term organizational stability. Golder professionals take the time to build an understanding of client needs and of the specific environments in which they operate. We continue to expand our technical capabilities and have experienced steady growth with employees now operating from offices located throughout Africa, Asia, Australasia, Europe, North America and South America.

Africa	+ 27 11 254 4800
Asia	+ 852 2562 3658
Australasia	+ 61 3 8862 3500
Europe	+ 356 21 42 30 20
North America	+ 1 800 275 3281
South America	+ 55 21 3095 9500

solutions@golder.com
www.golder.com

Golder Associates Ltd.
2390 Argentia Road
Mississauga, Ontario, L5N 5Z7
Canada
T: +1 (905) 567 4444

