

Legend

Wind Energy Centre Study Area	Natural Feature
120m Area of Investigation	Watercourse (ABCA, SCRCA)
Municipal Division	Watercourse (MNR)
Freeway	Provincially Significant Life Science ANSI
Expressway / Highway	Regionally Significant Life Science ANSI
Major Road	Provincially Significant Earth Science ANSI
Local Road	Regionally Significant Earth Science ANSI
Ramp	ESA (ABCA)
Railway	Provincial Significant Wetland
Existing 500kV Transmission Line	Locally Significant Wetland
MOE Waterwell	Waterbody
GE Turbine	Cartographic Wetland
Permanent Meteorological Tower	ABCA Woodland
Access Road	Wooded Area
Collection Line	
Crane Path	
Transmission Line	
Substation & Laydown Area	
Disturbance Areas	

Produced by AECOM under license from Ontario Ministry of Natural Resources, Copyright © Queens Printer 2012

0 500 1,000 2,000 3,000
Metres


1:50,000
UTM Zone 17N, NAD 83

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent.

Jericho Wind Energy Centre
Construction Report

**Project Location and
Natural Heritage Features**

September 2013
Project 60155032



Legend

<ul style="list-style-type: none"> Wind Energy Centre Study Area Transmission Line Study Area Parcel Boundary 120m Area of Investigation Municipal Division Setback Distances <ul style="list-style-type: none"> 60 m Road/Rail Buffer 80 m Property Boundary Buffer 500 m Substation Footprint Buffer 550 m Noise Receptor Buffer 75 m Petroleum Resources Buffer 2 km Boundary from Project Location 	<ul style="list-style-type: none"> Other Resources <ul style="list-style-type: none"> Petroleum Well Authorized Aggregate Site Closed Landfill Roads <ul style="list-style-type: none"> Freeway Expressway / Highway Major Road Local Road Ramp Railway Existing 500kV Transmission Line Receptor <ul style="list-style-type: none"> Participating Receptor Non-participating Receptor Vacant Lot Participating Receptor Vacant Lot Non-participating Receptor 	<ul style="list-style-type: none"> Project Location <ul style="list-style-type: none"> GE Turbine Permanent Meteorological Tower Access Road Collection Line Crane Path Transmission Line Substation & Laydown Area Disturbance Areas Natural Feature <ul style="list-style-type: none"> Watercourse (ABCA, SCRCA) Watercourse (MNR) Waterbody Cartographic Wetland Woodlots
---	---	---

Refer to Parkhill Interconnect Project Appendix from Original REA Submission

Produced by AECOM under licence from Ontario Ministry of Natural Resources. Copyright © Queens Printer 2012

Metres
 0 200K00 800 1,200 1,600
 1:50,000
 UTM Zone 17N, NAD 83

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent.

Jericho Wind Energy Centre
 Construction Report

Project Location and Socio-Economic Features

September 2013
 Project 60155032

Appendix D

Revised Hydrogeological Calculations for Dewatering Activities

Appendix D-1 Hydrogeological Calculations for Dewatering Activities for Turbine

1. Introduction

As described in the *Technical Guide to Renewable Energy Approvals (MOE, 2011)*, an important environmental effect to consider in the Construction Plan report is the potential for the Project to interfere with existing uses of a water resource.

Section 3.3.3 (Geology and Groundwater) of the Construction Plan Report determines that the extraction of groundwater for construction dewatering purposes will be less than 50,000 litres per day (L/day) for all turbines with the exception of turbines 8, 25, and 32 – 34, where dewatering has the potential to be greater than 50,000 L/day. At these turbines available geotechnical and geological information indicate permeable sediments (i.e. sand) within 4 mbgs. Daily groundwater inflow rates and resulting radii of influence are attributable to the following:

- A short duration of dewatering activities (3-4 days per turbine base);
- The number of turbine foundations / collection line trenches installed at one time;
- The amount of precipitation that occurs directly before or during construction; and
- The surficial material being excavated.

2. Calculation of Water Takings

Conservative estimates of groundwater inflow rates for a turbine foundation were calculated based on an assumed excavation of 21 x 21 m and a required excavation depth of 4 mbgs. The required water table drawdown varies for each turbine and is dependent on results of the geotechnical investigation and the depth and/or thickness of permeable sediments at the turbine location. The hydraulic conductivity assumed for turbines 8, 25, 32, 33 and 34 ranges between 1.0×10^{-4} to 5.0×10^{-4} m/s and is estimated based on available geotechnical borehole information and geological mapping.

In addition, the calculated radii of influence for the construction dewatering were calculated to range between 131 and 278 m.

The analytical calculations used to determine the predicted groundwater inflow and radii of influence were based upon Powers *et al.* (2007)¹ and Sichart *et al.* (1930)².

Table 1 summarizes the predicted groundwater inflow, radii of influence and applied hydraulic conductivity.

Table 2 shows an example calculation used to determine the radius of influence and groundwater inflow for a sand and gravel unit.

1. Powers, J.P., Corwin, A.B., Schmall, P.C., Kaeck, W.E., and Herridge, C.J., 2007. *Construction Dewatering and Groundwater Control: New Methods and Applications*, 3rd Ed. John Wiley and Sons Inc.

2. Sichart, W. and Kyrieleis, W., 1930. *Grundwasser Absekungen bei Fundierungsarbeiten*. Berlin, Germany.

Table 1. Summary of Predicted Groundwater Inflow and Radii of Influence

Turbine ID:	8	25	32	33	34
Area:	Excavation for base of single turbine				
Initial Head:	4 m	4 m	4 m	4 m	4 m
Final Head:	0 m				
Excavation Length:	21 m				
Side Slope Wall Ratio:	Varies, but assume 1H : 1V for calculation				
Trench Width:	21 m				
Number of Sides:	4				
Hydraulic Conductivity (m/s):	5.0e ⁻⁴	5.0e ⁻⁴	5.0e ⁻⁴	5.0e ⁻⁴	1.0e ⁻⁴
Q (L/day):	214,350	214,350	214,350	214,350	95,860
ROI (m):	278	278	278	278	131

Notes: Q – Flow rate (L/day)
 ROI – Radius of Influence (m)

Radius of Influence and Groundwater Inflow Rate Calculations - Turbine Foundation

Spreadsheet Instructions

TURBINE No: 8

After: Powers et al, 2007 & Sichart and Kryieleis, 1930.
 USE FOR BOX SHAPED EXCAVATIONS, WHERE x/a IS SMALL (I.E. <1.5)

Edit
 Results

x/a 1

Radius of Influence

Ro = 3000(H-h)K^{1/2}

Sichardt's empirical relationship

Radius of Influence	Ro =	872.07 ft
Saturated Thickness before Dewatering	H =	13 ft
Saturated Thickness after Dewatering	h =	0 ft
Hydraulic Conductivity	K =	5.00E-04 m/s
Number of Sides	n =	4

Groundwater Seepage Rate

Jacob's modified non-equilibrium equation**

Q = [(xK(H²-h²)/2L)]*n

Radius of Influence	Ro =	265.81 m
Equiv Radius of Influence	r _e =	11.8 m
Saturated Thickness before Dewatering	H =	3.9624 m
Saturated Thickness after Dewatering	h =	0 m
Hydraulic Conductivity	K =	5.00E-04 m/s
Length of Trench	x =	21 m
Line Source Distance*	L =	132.9029363 m
Pi		3.141593
Groundwater Inflow Rate	Q =	2.48E-03 m ³ /s
	Q =	214,346 L/day
Sheet Pile % reduction	%	0 %
Revised Total Groundwater Inflow Rate	Q' =	214,346 L/day

Equivalent Radius of Influence for Square or rectangular shaped areas

r_e = (ax/Pi)^{1/2}

Width of Trench	a =	21 m
Length of Trench	x =	21 m
Pi		3.141593
Equiv Radius of Influence	r _e =	11.85 m

Therefore, the Total Radius of Influence equals **R_T = Ro + r_e**
 R_T = 277.65 m

Notes:

- ** Only good for horizontal flow, need to use darcy for vertical flow
- **First Term is for Gravity Flow
- **Second Term is for artesian flow (confined aquifer)
- *Line source distance is the distance where the confined aquifer is drained (i.e., under gravity flow conditions), but the confining unit is still flowing under pressure

References:

Powers, J.P., Corwin, A.B., Schmall, P.C., Kaeck, W.E., and Herridge, C.J., 2007. Construction Dewatering and Groundwater Control: New Methods and Applications, 3rd Ed. John Wiley and Sons Inc
 Sichart, W. and Kyrieleis, W., 1930. Grundwasser Absekungen bei Fundierungsarbeiten. Berlin, Germany.

References:

Appendix B-2 Hydrogeological Calculations for Dewatering Activities for Collection Line

3. Introduction

As described in the *Technical Guide to Renewable Energy Approvals (MOE, 2011)*, an important environmental effect to consider in the Construction Plan report is the potential for the Project to interfere with existing uses of a water resource.

Section 3.3.3 (Geology and Groundwater) of the Construction Plan Report determines that the extraction of groundwater for construction dewatering purposes will be less than 50,000 litres per day (L/day) for all collection lines installed in surficial material with relatively impermeable aquifer properties (i.e. St. Joseph till). Where collection lines are installed in permeable surficial materials, such as sand and gravel, dewatering has the potential to be greater than 50,000 L/day. Daily groundwater inflow rates and resulting radii of influence are attributable to the following:

- A short duration of dewatering activities (1 day per 50 m length of collection line);
- The number of turbine foundations / collection line trenches installed at one time;
- The amount of precipitation that occurs directly before or during construction; and
- The surficial material being excavated.

4. Calculation of Water Takings

Conservative estimates of groundwater inflow rates for a collection line were calculated based on an assumed excavation of 1 m wide by 50 m long, a required excavation depth of 2 mbgs with a required water table drawdown of 1 m. The hydraulic conductivity assumed for all collection lines encountering permeable surficial sediments is estimated to 5.0×10^{-4} m/s. Based on the same excavation dimensions, conservative estimates for groundwater inflow rate to excavations within sand and gravel deposits were calculated to be 174,300 L/day.

In addition, the calculated radii of influence for the construction dewatering were calculated to be 77 m.

The analytical calculations used to determine the predicted groundwater inflow and radii of influence were based upon Powers *et al.* (2007)³ and Sichart *et al.* (1930)⁴ equation for long thin trenches.

Table 1 summarizes the predicted groundwater inflow, radii of influence and applied hydraulic conductivity.

Table 2 shows an example calculation used to determine the radius of influence and groundwater inflow for a sand and gravel unit.

3. Powers, J.P., Corwin, A.B., Schmall, P.C., Kaeck, W.E., and Herridge, C.J., 2007. *Construction Dewatering and Groundwater Control: New Methods and Applications*, 3rd Ed. John Wiley and Sons Inc.

4. Sichart, W. and Kyrieleis, W., 1930. *Grundwasser Absekungen bei Fundierungsarbeiten*. Berlin, Germany.

Table 2. Summary of Predicted Groundwater Inflow and Radii of Influence

Area	Excavation for collection line
Initial Head:	1
Final Head:	0
Excavation Length:	50
Side Slope Wall Ratio:	Varies, assume 1H :1V for calculation
Trench Width:	1 m
Number of Sides:	4
Hydraulic Conductivity (m/s):	$5.0e^{-4}$ m/s
Q (L/day):	174,300
ROI (m):	77

Notes: Q – Flow rate (L/day)
ROI – Radius of Influence (m)

Radius of Influence Calculation - Collection Line Trench

Powers et al. 1992 - Dewatering Design using Analytical Methods

USE FOR LONG THIN TRENCHES WHERE x/a IS LARGE

Radius of Influence

$R_o = 3000(H-h)K^{1/2}$ (Ro, H, h all in feet and K in m/s)

Sichardt's empirical relationship

Radius of Influence	$R_o =$	199.23 ft
Saturated Thickness before Dewatering	$H =$	3.30 ft
Saturated Thickness after Dewatering	$h =$	0.33 ft
Hydraulic Conductivity	$K =$	5.00E-04 m/s

Equivalent Radius of Influence for Square or rectangular shaped areas

$$r_e = (ax/\pi)^{1/2}$$

Width of Trench	$a =$	1 m
Length of Trench	$x =$	50 m
Pi		3.14159
Equiv Radius of Influence	$r_e =$	16.23 m

Therefore, the Total Radius of Influence equals $R_T = R_o + r_e$

$R_T = 76.96$ m

References:

Powers, J.P., Corwin, A.B., Schmall, P.C., Kaeck, W.E., and Herridge, C.J., 2007. Construction Dewatering and Groundwater Control: New Methods and Applications, 3rd Ed. John Wiley and Sons Inc

Sichart, W. and Kyrieleis, W., 1930. Grundwasser Abseukungen bei Fundierungsarbeiten. Berlin, Germany.

Groundwater Seepage Rate

Jacob's modified non-equilibrium equation**

$$Q = [(\pi K(H^2 - h^2))/\ln(R_o/r_e)] + 2[(xK(H^2 - h^2))/2L]$$

Radius of Influence	$R_o =$	60.73 m
Equiv Radius of Influence	$r_e =$	16.2 m
Saturated Thickness before Dewatering	$H =$	1.01 m
Saturated Thickness after Dewatering	$h =$	0.10 m
Hydraulic Conductivity	$K =$	5.00E-04 m/s
Length of Trench	$x =$	50 m
Line Source Distance	$L =$	30.36 m
Pi		3.14159
Groundwater Inflow Rate	$Q =$	2.02E-03 m ³ /s
	$Q =$	174,288 L/day
Sheet Pile % reduction	%	0 %
Revised Total Groundwater Inflow Rate	$Q' =$	174,288 L/day

Notes:

** Only good for horizontal flow, need to use darcy for vertical flow

**First Term is for Gravity Flow

**Second Term is for artesian flow (confined aquifer)

*Line source distance is the distance where the confined aquifer is drained (i.e., under gravity flow conditions), but the confining unit is still flowing under pressure