

REPORT ID: **13259.00.T24.RP3**

---

## **Summerhaven Wind Energy Centre – Turbine T24 IEC 61400-11 Edition 3.0 Measurement Report**

---

Prepared for:


**Nextera Energy Canada**  
179 Norpark Ave, Unit #20-21  
Mount Forest, Ontario, N0G-1A0

Prepared by:

*A. Munro*

---

**Allan Munro, B.A.Sc.**



---

**Payam Ashtiani, B.A.Sc., P.Eng.**

07 November 2017 – Revision #3



## Revision History

Revision Number	Description	Date
1	Issued Edition 3.0 test report	November 20, 2013
2	Issued Edition 2.1 test report	March 26, 2015
3	Issued revised Edition 3.0 test [13 and 13.5m/s wind bins]	November 07, 2017

**This report in its entirety, including appendices contains 88 pages.**

## Statement Qualifications and Limitations

This report was prepared by Aercoustics Engineering Limited in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to the Wind Turbine identified in this report.

Aercoustics Engineering Limited shall not be responsible for any events or circumstances that may have occurred since the date on which the Wind Turbine was tested and/or this report was prepared, or for any inaccuracies contained in information that was provided to Aercoustics Engineering Limited. Further, Aercoustics Engineering Limited agrees that this report represents test data analysed as per the above described standard for the specific Wind Turbine described in this report, but Aercoustics Engineering Limited makes no other representations with respect to this report or any part thereof.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Aercoustics Engineering Limited accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Any use of this report is subject to this Statement of Qualifications and Limitations. Any damages arising from improper use of this report or parts thereof shall be borne by the party making such use.

This Statement of Qualifications and Limitations is attached to and forms part of this report.

## Table of Contents

<b>Revision History</b>	<b>2</b>
<b>Statement Qualifications and Limitations</b>	<b>2</b>
<b>List of Appendices</b>	<b>6</b>
<b>1 Introduction</b>	<b>8</b>
<b>2 Wind Turbine Information</b>	<b>8</b>
2.1 Wind turbine equipment specific information.....	8
2.2 Wind Turbine Location.....	9
<b>3 Measurement Details</b>	<b>10</b>
3.1 Measurement Equipment.....	10
3.1.1 Acoustic Measurement Equipment.....	10
3.1.2 Meteorological Equipment.....	10
3.2 Measurement Setup.....	10
3.2.1 Microphone Placement.....	10
3.2.2 Double Windscreen Setup.....	11
3.3 Measurement Schedule.....	11
3.4 Meteorological Conditions.....	11
3.5 Turbine operational information.....	12
<b>4 Measurement Results</b>	<b>12</b>
4.1 Deviations from IEC-61400-11 Edition 3.0.....	12
4.2 Special Notes & Considerations.....	12
4.3 Analysis Details.....	12
4.3.1 Double Windscreen Adjustment.....	12
4.3.2 Wind Speed Correction.....	12
4.4 Type B uncertainties.....	12
4.5 Sound Pressure Level Measurements.....	13
4.6 Sound Power Level of Turbine.....	13
4.7 Tonality Analysis.....	14
<b>5 Closure</b>	<b>15</b>
<b>6 References</b>	<b>15</b>

## List of Figures

Figure A.01 – Site plan.....	Appendix A
Figure A.02 – Site photos .....	Appendix A
Figure B.01 – Power Curve.....	Appendix B
Figure B.02 – Rotor RPM vs. Wind Speed.....	Appendix B
Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON &Background).....	Appendix C
Figure C.02 – Plot of measured total noise vs electrical power output.....	Appendix C
Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer.....	Appendix C
Figure C.04 - Plot of rotor RPM vs. electrical power output.....	Appendix C
Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 8 m/s.....	Appendix C
Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s.....	Appendix C
Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s.....	Appendix C
Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s.....	Appendix C
Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s.....	Appendix C
Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s.....	Appendix C
Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s.....	Appendix C
Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s.....	Appendix C
Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 12 m/s.....	Appendix C
Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s.....	Appendix C
Figure C.15 – Plot of sound pressure spectrum in 1/3 Octave at 13 m/s.....	Appendix C
Figure C.16 – Plot of sound pressure spectrum in 1/3 Octave at 13.5 m/s.....	Appendix C
Figure C.17 – Plot of secondary windscreen influence.....	Appendix C
Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s.....	Appendix D
Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s...Appendix D	Appendix D
Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s.....Appendix D	Appendix D
Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s...Appendix D	Appendix D
Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s.....Appendix D	Appendix D
Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s...Appendix D	Appendix D
Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s...Appendix D	Appendix D
Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s...Appendix D	Appendix D
Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 12 m/s...Appendix D	Appendix D
Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 12.5 m/s...Appendix D	Appendix D
Figure D.11 – Plot of narrow band spectra – Turbine ON vs. Background at 13 m/s...Appendix D	Appendix D

## List of Tables

Table 1 - Wind Turbine Details .....	8
Table 2 - Operating Details.....	8
Table 3 - Rotor Details.....	9
Table 4 - Gearbox Details.....	9
Table 5 - Generator Details .....	9
Table 6 - Acoustic Measurement Equipment.....	10
Table 7 – Meteorological Measurement Equipment.....	10
Table 8 - Measurement Schedule Summary .....	11
Table 9 - Summary of Type B uncertainties .....	13
Table 10 - Summary of Sound Pressure Level Measurements.....	13
Table 11 - $L_{WA 10m, K}$ at each integer wind speed .....	14
Table 12 - Tonality Assessment Summary.....	15
Table C.01 – Detailed apparent sound power level data at hub height.....	Appendix C
Table C.02 – Detailed apparent sound power level data at 10m height.....	Appendix C
Table C.03 – Type B measurement uncertainty summary.....	Appendix C
Table C.04 – Detailed measurement uncertainty at hub height.....	Appendix C
Table C.05 – Secondary windscreen influence.....	Appendix C
Table E.01 – Measurement data –Turbine ON.....	Appendix E
Table E.02 – Measurement data – Background.....	Appendix E

## List of Appendices

### Appendix A – Site Details

- Figure A.01 – Site plan
- Figure A.02 – Site photos

### Appendix B – Turbine Information

- Figure B.01 – Power curve
- Figure B.02 – Rotor RPM vs. wind speed

### Appendix C – Apparent Sound Power Level

- Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)
- Figure C.02 – Plot of measured total noise vs electrical power output
- Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer
- Figure C.04 - Plot of rotor RPM vs. electrical power output
- Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 8 m/s
- Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s
- Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s
- Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s
- Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s
- Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s
- Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s
- Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s
- Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 12 m/s
- Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s
- Figure C.15 – Plot of sound pressure spectrum in 1/3 Octave at 13 m/s
- Figure C.16 – Plot of sound pressure spectrum in 1/3 Octave at 13.5 m/s
- Figure C.17 – Plot of secondary windscreen influence
- Table C.01 – Detailed apparent sound power level data at hub height
- Table C.02 – Detailed apparent sound power level data at 10m height
- Table C.03 – Type B measurement uncertainty summary
- Table C.04 – Detailed measurement uncertainty at hub height
- Table C.05 – Secondary windscreen influence

### Appendix D – Tonality Assessment

- Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s
- Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s
- Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s
- Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s
- Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s
- Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s
- Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s
- Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s
- Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 12 m/s
- Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 12.5 m/s
- Figure D.11 – Plot of narrow band spectra – Turbine ON vs. Background at 13 m/s
- Figure D.12 – Plot of narrow band spectra – Turbine ON vs. Background at 13.5 m/s
- Table D.01 – Tonality assessment table – 8 m/s

Table D.02 – Tonality assessment table – 8.5 m/s

Table D.03 – Tonality assessment table – 9 m/s

Table D.04 – Tonality assessment table – 9.5 m/s

Table D.05 – Tonality assessment table – 10 m/s

Table D.06 – Tonality assessment table – 10.5 m/s

Table D.07 – Tonality assessment table – 11 m/s

Table D.08 – Tonality assessment table – 11.5 m/s

Table D.09 – Tonality assessment table – 12 m/s

Table D.10 – Tonality assessment table – 12.5 m/s

Table D.11 – Tonality assessment table – 13 m/s

Table D.12 – Tonality assessment table – 13.5 m/s

Appendix E – Measurement Data

Table E.01 – Measurement data – Turbine ON

Table E.02 – Measurement data – Background

## 1 Introduction

Aercoustics Engineering Limited (Aercoustics) was retained by NextEra Energy Canada (“NextEra”) to conduct an acoustic measurement of turbine T24 at the Summerhaven Wind Energy Centre. The purpose of the measurement was to provide verification of the maximum noise emission of the turbine. The measurement was carried out in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to Turbine T24.

## 2 Wind Turbine Information

### 2.1 Wind turbine equipment specific information

Wind turbine specific equipment information for turbine T24 was provided by NextEra and is summarized in Tables 1 – 5.

Table 1 - Wind Turbine Details

Wind Turbine Details	
Manufacturer	Siemens
Model Number	2.3
Turbine ID	2306899

Table 2 - Operating Details

Operating Details	
Vertical or Horizontal axis wind turbine	Horizontal
Upwind or downwind rotor	Upwind
Hub height	80m
Horizontal distance from rotor centre to tower axis	3500mm
Diameter of rotor	9.3m
Tower type (lattice or tube)	Tube
Passive stall, active stall, or pitch controlled turbine	Pitch controlled
Constant or variable speed	Variable
Power curve	See Figure B.01
Rotational speed at each integer standardised wind speed	See Figure B.02 from measurement data
Rated power output	2221kW
Control software version	12.12.03

Table 3 - Rotor Details

Rotor Details	
Rotor control devices	Hydraulically actuated full span pitch system
Presence of vortex generators, stall strips, serrated trailing edges	Vortex Generator and Dino Tail
Blade type	Siemens Blade B45
Serial number	Set 2774, 450771802, 451156102, 450772302
Number of blades	3

Table 4 - Gearbox Details

Gearbox Details	
Manufacturer	Winergy
Model number	PEAB4456,6
Serial number	4832972-020-6

Table 5 - Generator Details

Generator Details	
Manufacturer	ABB
Model number	ABB C3 2300kW VS 690v
Serial number	4607851

## 2.2 Wind Turbine Location

Turbine T24 is located in the municipality Nanticoke, in Haldimand County, approximately 600m south of Concession Road 5 and 3,000m west of Regional Road 53. The area surrounding T24 is flat and consists primarily of farmland.

A general layout of the area in which the turbine is located is provided in the site plan (Figure A.01).

### 3 Measurement Details

#### 3.1 Measurement Equipment

##### 3.1.1 Acoustic Measurement Equipment

A summary of acoustic equipment utilized by Aercoustics for the measurement of turbine T24 is summarized in Table 6.

Table 6 - Acoustic Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Acoustic Data acquisition system	LMS SCADA Mobile	53103922
Microphone	B&K 4189	2625416
Pre-amplifier	B&K 2671	2369794
Acoustic calibrator	B&K 4231	2513182

Calibration of the measurement setup was carried out before and after Aercoustics set of measurements.

##### 3.1.2 Meteorological Equipment

Wind speed for Turbine ON was derived from the power curve (as per procedures outlined in IEC 61400-11). Wind direction for turbine ON measurements was utilized from the yaw position from turbine T24. Data for background measurements was obtained from a 10m high anemometer, which was placed as per guidelines outlined in IEC-61400-11.

The meteorological equipment is summarized in Table 7

Table 7 – Meteorological Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Anemometer	VAISALA WXT520	G4420002
Serial to Analog Converter	NOKEVAL 7470	19474

#### 3.2 Measurement Setup

##### 3.2.1 Microphone Placement

The measurement microphone was setup 126m from the base of the turbine in 'Position 1', (i.e. downwind of the turbine, as per IEC 61400-11) at an elevation of 0m relative to the base of T24. The microphone was placed in the centre of a circular, acoustically reflective board.

During the measurement period only data points for which the microphone was within 15 degrees of downwind from the turbine were used. The microphone position relative to downwind of the turbine was monitoring via the yaw angle output provided from the turbine

system (discussed further in Section 3.5). During placement of the microphone the turbine was parked and the reference yaw angle for that measurement logged.

When measurements of T24 were taken, the surrounding land was a mix of soil and small vegetation. The influence on the measurement was considered negligible. There were no nearby reflecting surfaces (houses, barns etc.); as such the influence from reflecting surfaces was considered to be negligible.

Photos of the measurement setup are provided in Figure A.02, Appendix A.

### 3.2.2 Double Windscreen Setup

A double windscreen setup was utilized. Documentation of how the secondary windscreen affects the overall sound pressure level and 1/3 Octave Band spectrum in comparison to a single windscreen setup is provided in Appendix C.

The secondary windscreen used meets the performance criterion specified in Annex E (Characterization of a secondary wind screen) of IEC-61400-11:2012.

### 3.3 Measurement Schedule

Table 8 provides a summary of the test date and times. Data was logged in 10 second intervals for post-processing (as per the measurement standard).

Table 8 - Measurement Schedule Summary

Date	Test Type	Start Time	Finish time
October 20, 2013	Turbine ON	10:06	10:50
	Turbine ON	12:25	12:46
	Background	15:12	15:44
	Turbine ON	17:08	17:44
October 21, 2013	Turbine ON	10:39	10:52
	Turbine ON	10:55	11:36
	Background	11:50	12:20

### 3.4 Meteorological Conditions

Detailed meteorological data relevant to the measurement is provided in Appendix E.

As previously mentioned, wind speed for Turbine ON was derived from T24's power curve (as per the standard), while wind direction was provided by T24's yaw position. Background data was obtained from an anemometer located 10m above ground level near T24.

Temperature and pressure readings during the measurement period were provided by the 10m anemometer, located near turbine T24 for the duration of Aercoustics measurements.

### 3.5 Turbine operational information

Output data from the turbine (Power, yaw, RPM, pitch angle, and nacelle wind speed) were obtained as analog output signals that were simultaneously acquired with the acoustic and anemometer measurement data using Aercoustics data acquisition system.

## 4 Measurement Results

### 4.1 Deviations from IEC-61400-11 Edition 3.0

No deviations.

### 4.2 Special Notes & Considerations

There were no other turbines in the immediate vicinity of T24.

### 4.3 Analysis Details

The following section outlines analysis of the measurement data acquired for T24. The data presented is exclusive of transient events such as vehicle traffic, wildlife, air traffic etc. The site has been assessed to have a roughness length of 0.05m, representative of farmland with some vegetation.

#### 4.3.1 Double Windscreen Adjustment

As previously mentioned, a double wind screen was used, as such; the measurement data was adjusted to account for its influence. All 1/3 Octave Band spectrum and overall level data presented in this report includes the adjustment for the influence of the secondary windscreen.

FFT spectral data used for the tonality assessment was not adjusted. However, it should be noted that the effect of the windscreen on the tonality assessment is considered to be negligible.

#### 4.3.2 Wind Speed Correction

The wind speed for each measurement data point for Turbine ON was derived through the power curve (as per Section 8.2.1.1 of IEC-61400-11). For data points during Turbine ON that were outside the allowed range of the power curve, the wind speed was derived from the nacelle anemometer wind speed (as specified in Section 8.2.1.2 of IEC-61400-11).

Background wind speed was derived utilizing data acquired with the 10m anemometer and normalizing the wind speed (as per Section 8.2.2 of IEC-61400-11).

### 4.4 Type B uncertainties

Type B uncertainties were obtained through interpretation of information provided in Annex C of IEC-61400-11, and instrument uncertainties obtained from the calibration certificate. A summary of Type B uncertainties is provided in Table 9, while detailed information (including data in 1/3 octave) is provided in Appendix C.

Table 9 - Summary of Type B uncertainties

Component	Typical (dB)	Used (dB)
Calibration	0.2	0.2
Board	0.3	0.3
Distance & direction	0.1	0.1
Air absorption	0	0
Weather conditions	0.5	0.5
Wind speed measured	0.7	0.7
Wind speed derived	0.2	0.2
Wind speed from power curve	0.2	0.2

#### 4.5 Sound Pressure Level Measurements

Sound pressure level measurements are summarized in Table 10. Detailed 1/3 Octave band spectrum data, respective uncertainties, and analysis plots are provided in Appendix C. A copy of the measurement data used for analysis is provided in Appendix E and includes meteorological and turbine operational data.

Table 10 - Summary of Sound Pressure Level Measurements

Wind Speed (m/s)	Turbine ON		Background		Turbine ON, Background adjusted $L_{eq}$ , (dBA)
	$L_{eq}$ , (dBA)	# of data pts	$L_{eq}$ , (dBA)	# of data pts	
8	54.5	25	46.1	22	53.9
8.5	55.1	31	47.3	20	54.4
9	55.5	43	48.2	17	54.7
9.5	56.3	28	48.7	35	55.5
10	56.9	20	49.1	24	56.2
10.5	57.2	13	50.5	31	56.2
11	57.4	30	49.5	24	56.7
11.5	57.5	25	49.8	26	56.7
12	57.5	37	50.6	21	56.5
12.5	57.6	36	49.9	19	56.8
13	57.8	19	50.9	15	56.8
13.5	58.0	23	50.1	11	57.2

#### 4.6 Sound Power Level of Turbine

The calculated sound power level of the turbine T24 (as per IEC 61400-11) is summarized in Table 11 (hub height) and Table 12 (10m height). Detailed 1/3 Octave band spectrum data and respective uncertainties are provided in Appendix C.

Table 11 -  $L_{WA, K}$  at each integer wind speed

Wind Speed (m/s)	Apparent $L_{WA}$ , (dBA)	Uncertainty (dB)
8	102.4	0.8
8.5	102.9	0.9
9	103.2	0.9
9.5	104.0	0.9
10	104.7	0.8
10.5	104.8	0.9
11	105.2	0.9
11.5	105.2	0.9
12	105.0	0.9
12.5	105.4	0.9
13	105.3	1.0
13.5	105.8	0.9

Table 12 -  $L_{WA 10m, K}$  at each integer wind speed

Wind Speed (m/s)	Apparent $L_{WA}$ , (dBA)	Uncertainty (dB)
5	99.4	0.8
6	102.7	0.9
7	104.1	0.9
8	105.1	0.9
9	105.2	0.9
10	105.5	0.9

#### 4.7 Tonality Analysis

The tonality analysis for Turbine T24 is summarized in Table 13, while plots of narrow band spectra at each wind speed are provided in Appendix D. The  $\Delta L_{tn}$  and  $\Delta L_a$  values reported represent the energy average of all data points with an identified tone that falls within the same frequency origin (as specified in Section 9.5.8 in IEC-61400-11).

The narrow band spectra provided in the plots represents an energy average of all data points in the given wind speed bin for both Turbine ON and Background.

Table 13 - Tonality Assessment Summary

Wind Speed (m/s)	Frequency (Hz)	Tonality, $\Delta L_{tn}$ (dB)	Tonal audibility, $\Delta L_a$ (dB)	FFT's with tones	Total # of FFT's	Presence (%)
8	531	-4.9	-2.6	25	25	100%
8.5	524	-2.3	0.0	31	31	100%
9	520	-1.0	1.3	43	43	100%
9.5	60	-3.4	-1.4	15	28	54%
	513	-0.3	2.0	20	28	71%
10	122	-2.7	-0.7	14	20	70%
	511	0.3	2.6	16	20	80%
10.5	519	0.7	3.0	13	13	100%
11	124	-3.3	-1.3	28	30	93%
	512	1.5	3.8	30	30	100%
11.5	124	-3.2	-1.2	24	25	96%
	514	2.4	4.7	24	25	96%
12	124	-2.2	-0.2	36	37	97%
	513	2.5	4.9	34	37	92%
12.5	124	-2.6	-0.6	36	36	100%
	516	2.5	4.8	35	36	97%
13	124	-3.6	-1.6	19	19	100%
	515	2.8	5.1	19	19	100%
13.5	124	-2.6	-0.5	23	23	100%
	517	2.0	4.4	23	23	100%

## 5 Closure

Measurements and analysis were carried on Turbine T24 of the Summerhaven Wind Energy Centre as per International IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”.

Should you have any questions or comments please do not hesitate to contact the authors of this report.


## 6 References

1. International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”.

---

## Appendix A Site Details

---



**LEGEND**

- |                               |                                  |                             |
|-------------------------------|----------------------------------|-----------------------------|
| Turbine Location              | Cable                            | Community                   |
| Point of Reception            | Transmission Line                | Hydro One Transmission Line |
| Participating Receptor        | Project Area                     | Highway                     |
| Vacant Point of Reception     | Substation                       | Regional Road               |
| Vacant Participating Receptor | Office                           | Local Road                  |
| Meteorological Tower          | Point Of Interconnect/Switchyard | Watercourse                 |
|                               | Access Road                      | Wetland                     |
|                               |                                  | Waterbody                   |

13259.00.T24.RP3

**Project Name**



Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1

Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

**Figure Title**

Site Plan

**Figure A.01**



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1

**Project Name**

Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

**Figure Title**


Site Photos

**Figure A.02**


---

## Appendix B Turbine Information

---



Power Curve	
Hub Wind Speed (m/s)	Power [kW]
0	0
1	0
2	0
3	0
4	98
5	212
6	385
7	625
8	941
9	1344
10	1803
11	2177
12	2219
13	2220
14	2221
15	2221
16	2221
17	2221
18	2221
19	2221
20	2221
21	2221
22	2221
23	2221
24	2221
25	2221




	<b>13259.00.T24.RP3</b>	<b>Project Name</b>	
	Scale: NTS Drawn by: AM Reviewed by: PA Date: Oct 11, 2017 Revision: 1	Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0	
		<b>Figure Title</b>	<b>Figure B.02</b>
		Rotor RPM vs. wind speed	

---

## Appendix C

### Apparent Sound Power Level

---



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1


**Project Name**

Summerhaven Wind Energy Centre - Turbine T16 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)

**Figure C.01**



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1


**Project Name**

Summerhaven Wind Energy Centre - Turbine T16 - IEC61400-11 Edition 3.0


**Figure Title**

Plot of measured total noise vs electrical power output

**Figure C.02**



### 8.0 m/s - Hub Height



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1

**Project Name**


Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 8 m/s

**Figure C.05**

8.5 m/s - Hub Height



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s

Figure C.06

9.0 m/s - Hub Height



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 9 m/s

**Figure C.07**

9.5 m/s - Hub Height



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s

Figure C.08

10.0 m/s - Hub Height




13259.00.T24.RP3  
 Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1


**Project Name**  
 Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

**Figure Title**  
 Plot of sound pressure spectrum in 1/3 Octave at 10 m/s

**Figure C.09**



	<b>13259.00.T24.RP3</b>	<b>Project Name</b> Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0	
	Scale: NTS Drawn by: AM Reviewed by: PA Date: Oct 11, 2017 Revision: 1	<b>Figure Title</b> Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s	



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1


**Project Name**

Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 11 m/s

**Figure C.11**




13259.00.T24.RP3  
 Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1

**Project Name**  
 Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0


**Figure Title**  
 Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s

**Figure C.12**



	<b>13259.00.T24.RP3</b>	<b>Project Name</b> Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0	<b>Figure C.13</b>
	Scale: NTS Drawn by: AM Reviewed by: PA Date: Oct 11, 2017 Revision: 1	<b>Figure Title</b> Plot of sound pressure spectrum in 1/3 Octave at 12 m/s	

### 12.5 m/s - Hub Height



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1


Project Name

Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0


Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s

**Figure C.14**



	13259.00.T24.RP3	<b>Project Name</b>	<b>Figure C.15</b>
	Scale: NTS Drawn by: AM Reviewed by: PA Date: Oct 11, 2017 Revision: 1	Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0  <b>Figure Title</b> Plot of sound pressure spectrum in 1/3 Octave at 13 m/s	



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1


**Project Name**

Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 13.5 m/s

**Figure C.16**



13259.00.T24.RP3

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 1, 2017  
 Revision: 1

Project Name

Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0

Figure Title

Plot of secondary windscreen influence

**Figure C.17**

# Table C.01 Detailed apparent sound power level data at hub height

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement

Report ID: 13259.00.T24.RP3

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																			Overall									
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250		1600	2000	2500	3150	4000	5000	6300	8000	10000
8.0	Turbine ON (dBA)	10.3	17.1	18.9	23.2	27.2	32.8	32.3	34.4	37.8	39.8	39.9	41.1	41.6	41.7	44.8	43.5	44.4	43.4	43.8	43.6	43.2	41.7	39.7	37.9	35.0	32.7	30.8	34.6	54.5
	Background (dBA)	-1.9	3.1	8.1	11.5	14.8	20.0	22.3	24.1	27.1	28.8	30.2	31.6	31.9	32.7	33.7	33.8	34.0	33.9	34.3	34.3	34.2	34.8	33.9	33.3	31.7	31.6	30.8	35.4	46.1
	Turbine ON - background adj (dBA)	10.1	16.9	18.5	22.9	26.9	32.5	31.8	34.0	37.5	39.4	39.4	40.5	41.1	41.1	44.4	43.0	44.0	42.8	43.2	43.0	42.6	40.8	38.4	36.0	32.2	[29.7]	[27.8]	[31.6]	53.9
	Signal to noise (dB)	12.2	14.0	10.7	11.7	12.4	12.8	10.0	10.3	10.8	11.0	9.7	9.4	9.7	9.0	11.1	9.7	10.4	9.5	9.2	8.9	7.0	5.8	4.6	3.3	1.0	0.1	-0.8	8.4	
	Uncertainty (dB)	1.1	1.1	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	1.0	1.1	1.3	1.7	1.8	1.8	3.6	0.8
8.5	PWL (dBA)	58.6	65.5	67.0	71.4	75.5	81.1	80.4	82.5	86.0	87.9	87.9	89.1	89.7	89.7	93.0	91.6	92.5	91.4	91.8	91.6	91.1	89.3	86.9	84.6	80.8	[78.2]	[76.4]	[80.1]	102.4
	Turbine ON (dBA)	9.8	17.1	18.5	22.9	27.3	33.0	32.2	34.5	38.4	40.0	40.3	41.3	42.0	42.3	46.1	44.1	44.9	43.9	44.4	44.1	43.9	42.4	40.3	38.5	35.6	33.2	31.3	35.1	55.1
	Background (dBA)	-1.0	3.8	9.3	12.4	16.4	21.2	23.6	25.4	28.6	30.1	31.7	33.0	33.2	34.0	34.5	35.1	35.0	35.5	35.9	35.9	35.7	36.4	35.4	34.4	32.4	32.1	30.9	35.1	47.3
	Turbine ON - background adj (dBA)	9.4	16.9	18.0	22.5	26.9	32.7	31.6	34.0	37.9	39.5	39.7	40.7	41.3	41.6	45.8	43.5	44.4	43.2	43.7	43.4	43.2	41.2	38.6	36.3	32.7	[30.2]	[28.3]	[32.1]	54.4
	Signal to noise (dB)	10.7	13.3	9.3	10.5	10.9	11.8	8.6	9.1	9.8	9.8	8.6	8.4	8.8	8.2	11.6	9.0	9.9	8.4	8.5	8.2	8.2	6.1	4.9	4.0	3.1	1.1	0.5	0.0	7.9
9.0	Uncertainty (dB)	1.1	1.1	1.0	0.9	0.9	0.9	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	1.1	1.3	1.5	1.8	1.8	1.8	3.4	0.9
	PWL (dBA)	57.9	65.4	66.5	71.0	75.5	81.2	80.1	82.5	86.4	88.0	88.2	89.2	89.9	90.1	94.3	92.0	93.0	91.7	92.2	91.9	91.8	89.8	87.2	84.8	81.2	[78.8]	[76.9]	[80.7]	102.9
	Turbine ON (dBA)	10.6	17.6	19.8	23.9	27.9	33.5	33.3	35.6	40.2	40.5	40.6	41.8	42.5	42.6	46.7	44.4	45.1	44.3	44.6	44.4	44.0	42.7	40.9	38.9	36.0	33.5	30.9	34.1	55.5
	Background (dBA)	0.5	5.2	10.1	13.2	17.1	21.4	23.6	25.9	29.2	30.3	31.9	33.2	33.9	34.9	35.8	36.4	36.5	36.9	37.5	37.5	37.3	37.7	36.5	35.2	33.0	32.4	30.5	33.6	48.2
	Turbine ON - background adj (dBA)	10.2	17.3	19.3	23.5	27.5	33.2	32.8	35.1	39.8	40.1	40.0	41.2	41.9	41.8	46.3	43.7	44.4	43.4	43.7	43.4	43.0	41.1	38.9	36.5	[33]	[30.5]	[27.9]	[31.1]	54.7
9.5	Signal to noise (dB)	10.1	12.4	9.7	10.7	10.8	12.1	9.7	9.7	11.0	10.2	8.7	8.7	8.6	7.7	10.9	8.0	8.6	7.3	7.2	6.9	6.8	5.1	4.4	3.7	3.0	1.1	0.5	0.5	7.3
	Uncertainty (dB)	1.2	1.1	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	1.2	1.4	1.6	1.8	1.8	3.8	0.9	
	PWL (dBA)	58.7	65.9	67.9	72.1	76.1	81.7	81.3	83.6	88.3	88.6	88.6	89.8	90.4	90.3	94.9	92.2	92.9	91.9	92.2	92.0	91.6	89.6	87.4	85.0	[81.5]	[79]	[76.4]	[79.6]	103.2
	Turbine ON (dBA)	11.8	18.5	21.4	25.4	29.3	35.0	34.8	37.1	42.9	41.4	41.2	42.6	43.2	43.3	47.5	44.9	45.3	45.1	45.3	45.0	44.4	43.4	41.8	39.8	36.8	34.2	30.6	32.2	56.3
	Background (dBA)	0.3	5.1	10.3	13.4	17.3	21.7	23.8	26.0	29.3	30.5	32.1	33.6	34.2	35.2	36.1	36.7	36.8	37.5	37.9	38.0	37.8	38.4	37.3	35.8	33.3	32.7	30.6	33.6	48.7
10.0	Turbine ON - background adj (dBA)	11.5	18.3	21.1	25.2	29.0	34.8	34.5	36.7	42.7	41.0	40.6	42.0	42.7	42.6	47.2	44.1	44.6	44.2	44.4	44.0	43.3	41.7	39.9	37.5	34.2	[31.2]	[27.6]	[29.2]	55.5
	Signal to noise (dB)	11.5	13.4	11.1	12.0	12.0	13.3	11.1	11.1	13.6	10.9	9.1	9.0	9.1	8.1	11.4	8.2	8.5	7.6	7.4	7.0	6.6	5.0	4.5	4.0	3.4	1.5	0.0	-1.4	7.6
	Uncertainty (dB)	1.3	1.1	1.2	1.2	1.1	0.9	1.1	1.0	1.0	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	1.3	1.4	1.5	1.6	1.8	1.8	4.0	0.9
	PWL (dBA)	60.0	66.9	69.6	73.7	77.6	83.3	83.0	85.3	91.2	89.6	89.2	90.5	91.2	91.1	95.7	92.7	93.2	92.8	93.0	92.5	91.9	90.3	88.5	86.1	82.7	[79.8]	[76.2]	[77.7]	104.0
	Turbine ON (dBA)	12.9	19.3	22.7	26.6	30.5	35.4	36.1	38.4	44.9	42.2	41.8	43.3	44.0	44.0	48.5	45.4	45.5	45.5	45.5	45.3	44.5	44.0	42.8	40.8	37.7	35.1	30.4	27.6	56.9
10.5	Background (dBA)	0.7	5.5	10.8	14.0	17.9	21.9	24.3	26.3	29.4	30.7	32.3	33.8	34.6	35.7	36.4	37.2	37.3	38.0	38.4	38.6	38.3	38.9	37.7	36.0	33.4	32.7	30.5	33.2	49.1
	Turbine ON - background adj (dBA)	12.7	19.1	22.4	26.4	30.3	35.2	35.9	38.1	44.8	41.8	41.3	42.7	43.4	43.3	48.3	44.7	44.8	44.7	44.6	44.2	43.4	42.4	41.3	39.0	35.7	[32.1]	[27.4]	[24.6]	56.2
	Signal to noise (dB)	12.3	13.8	11.9	12.7	12.6	13.5	11.9	12.1	15.5	11.5	9.5	9.4	9.4	8.3	12.1	8.2	8.2	7.5	7.1	6.7	6.2	5.1	5.2	4.7	4.3	2.4	-0.1	-5.6	7.9
	Uncertainty (dB)	1.0	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.9	0.8	0.7	0.7	0.7	0.8	0.7	0.8	0.8	0.8	0.8	0.9	1.2	1.2	1.3	1.3	1.8	1.8	3.5	0.8
	PWL (dBA)	61.2	67.6	70.9	74.9	78.8	83.7	84.4	86.7	93.3	90.4	89.8	91.3	92.0	91.9	96.8	93.2	93.4	93.2	93.1	92.8	91.9	90.9	89.8	87.5	84.2	[80.6]	[76]	[73.1]	104.7
10.5	Turbine ON (dBA)	13.9	20.1	23.5	27.3	31.2	35.8	36.7	39.0	44.6	42.6	42.1	43.7	44.2	44.3	49.0	45.7	45.8	45.8	45.8	45.6	44.9	44.3	43.2	41.1	38.1	35.4	30.6	25.8	57.2
	Background (dBA)	0.1	5.6	11.3	14.8	19.0	22.7	25.0	28.0	30.6	32.0	33.7	35.3	36.1	37.1	38.0	38.7	38.6	39.7	40.0	40.1	39.7	40.4	39.2	37.4	34.5	33.6	30.7	31.6	50.5
	Turbine ON - background adj (dBA)	13.7	20.0	23.3	27.1	30.9	35.6	36.4	38.6	44.4	42.2	41.4	43.0	43.5	43.4	48.6	44.7	44.9	44.6	44.5	44.1	43.3	42.1	41.0	38.8	35.6	[32.4]	[27.6]	[22.8]	56.2
	Signal to noise (dB)	13.8	14.5	12.3	12.5	12.2	13.1	11.7	11.0	13.9	10.6	8.4	8.3	8.2	7.2	11.0	7.0	7.2	6.1	5.9	5.5	5.2	3.9	4.0	3.8	3.6	1.8	-0.1	-5.8	6.8
	Uncertainty (dB)	1.0	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.8	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	1.0	1.0	1.5	1.5	1.5	1.8	1.8	3.2	0.9
10.5	PWL (dBA)	62.3	68.5	71.8	75.6	79.5	84.1	84.9	87.2	92.9	90.8	90.0	91.5	92.1	91.9	97.1	93.3	93.5	93.1	93.1	92.7	91.8	90.6	89.5	87.3	84.1	[81]	[76.1]	[71.4]	104.8

# Table C.01 Detailed apparent sound power level data at hub height

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement

Report ID: 13259.00.T24.RP3

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																		Overall										
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000		1250	1600	2000	2500	3150	4000	5000	6300	8000	10000
11.0	Turbine ON (dBA)	12.9	19.8	22.9	26.8	30.6	35.3	36.1	38.4	44.4	42.2	41.7	43.4	43.9	44.0	49.5	45.7	45.9	46.2	46.3	46.1	45.4	44.9	43.7	41.7	38.7	36.2	31.3	26.3	57.4
	Background (dBA)	1.3	6.2	12.0	15.5	19.0	22.8	24.6	27.0	30.2	31.4	32.9	34.4	35.1	36.2	37.0	37.8	38.0	38.6	38.9	39.0	38.8	39.1	37.9	36.3	33.8	32.9	30.3	32.2	49.5
	Turbine ON - background adj (dBA)	12.6	19.6	22.6	26.5	30.3	35.0	35.8	38.0	44.3	41.8	41.1	42.9	43.2	43.2	42.9	44.9	45.1	45.4	45.5	45.1	44.3	43.5	42.4	40.2	37.0	33.4	[28.3]	[23.3]	56.7
	Signal to noise (dB)	11.6	13.6	11.0	11.3	11.6	12.5	11.5	11.4	14.2	10.7	8.7	9.1	8.8	7.8	12.5	7.9	7.9	7.6	7.4	7.1	6.6	5.7	5.8	5.4	4.9	3.3	1.0	-5.9	7.9
	Uncertainty (dB)	1.1	1.1	0.9	0.9	0.9	0.8	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	1.2	1.2	1.2	1.3	1.7	1.9	3.5	0.9
11.5	PWL (dBA)	61.2	68.2	71.1	75.0	78.8	83.5	84.3	86.6	92.8	90.3	89.6	91.4	91.8	91.8	97.8	93.4	93.7	93.9	94.0	93.7	92.9	92.1	91.0	88.7	85.5	82.0	[76.8]	[71.8]	105.2
	Turbine ON (dBA)	12.7	19.9	22.7	26.8	30.4	35.1	36.2	38.1	44.4	42.2	41.6	43.4	43.8	43.9	49.8	45.7	45.9	46.3	46.3	46.1	45.4	44.8	43.6	41.6	38.5	36.0	31.0	25.8	57.5
	Background (dBA)	1.6	6.3	11.8	14.9	18.7	22.8	24.8	27.3	30.8	31.6	33.0	34.7	35.4	36.4	37.2	38.0	38.5	39.4	39.5	39.2	38.9	39.4	38.1	36.5	33.8	32.8	30.1	31.5	49.8
	Turbine ON - background adj (dBA)	12.4	19.7	22.4	26.5	30.1	34.9	35.8	37.8	44.2	41.8	41.0	42.8	43.1	43.1	49.5	44.8	45.0	45.2	45.3	45.1	44.3	43.4	42.2	40.0	36.8	33.1	[28]	[22.8]	56.7
	Signal to noise (dB)	11.2	13.6	11.0	11.8	11.7	12.3	11.4	10.8	13.6	10.6	8.6	8.8	8.4	7.5	12.5	7.6	7.4	6.8	6.8	6.8	6.5	5.4	5.5	5.1	4.8	3.2	0.9	-5.7	7.6
12.0	Uncertainty (dB)	1.1	1.0	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.9	0.9	0.9	0.9	1.2	1.2	1.2	1.3	1.7	1.8	3.3	0.9
	PWL (dBA)	60.9	68.3	70.9	75.0	78.7	83.4	84.4	86.3	92.7	90.3	89.5	91.4	91.7	91.6	98.1	93.4	93.6	93.8	93.9	93.6	92.8	91.9	90.7	88.5	85.3	81.7	[76.5]	[71.4]	105.2
	Turbine ON (dBA)	13.0	19.7	22.8	26.5	30.4	35.0	35.8	38.1	45.0	42.1	41.6	43.4	43.7	43.8	49.6	45.6	45.9	46.2	46.4	46.1	45.5	44.9	43.7	41.7	38.7	36.2	31.3	26.3	57.5
	Background (dBA)	2.5	7.7	13.7	17.2	20.6	24.5	26.4	28.8	30.9	31.8	33.5	35.1	35.8	36.9	37.7	38.5	38.7	39.6	40.1	40.3	40.2	40.8	39.5	37.7	35.1	34.3	31.2	30.6	50.6
	Turbine ON - background adj (dBA)	12.6	19.5	22.2	26.0	29.9	34.6	35.2	37.6	44.8	41.7	40.8	42.7	43.0	42.9	49.3	44.7	45.0	45.1	45.2	44.8	44.0	42.8	41.7	39.5	36.3	[33.2]	[28.3]	[23.3]	56.5
12.5	Signal to noise (dB)	10.5	12.0	9.1	9.3	9.8	10.5	9.3	9.3	14.1	10.3	8.1	8.2	7.9	6.9	11.8	7.1	7.2	6.6	6.3	5.9	5.3	4.2	4.2	4.0	3.7	1.9	0.1	-4.3	6.9
	Uncertainty (dB)	1.1	1.0	0.9	0.9	0.9	0.8	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.9	0.9	0.9	1.0	1.4	1.4	1.5	1.6	1.9	1.9	3.3	0.9
	PWL (dBA)	61.1	68.0	70.8	74.5	78.5	83.1	83.8	86.1	93.3	90.2	89.4	91.2	91.5	91.4	97.8	93.2	93.5	93.7	93.7	93.4	92.5	91.4	90.2	88.1	84.8	[81.8]	[76.8]	[71.8]	105.0
	Turbine ON (dBA)	12.9	19.7	22.7	26.4	30.3	35.1	35.8	38.2	45.1	42.2	41.6	43.5	43.8	44.0	49.7	45.7	46.0	46.4	46.5	46.3	45.7	45.2	44.0	42.0	39.0	36.5	31.5	26.3	57.6
	Background (dBA)	1.0	6.3	12.1	15.1	19.4	23.1	25.0	27.4	30.6	31.5	32.9	34.6	35.6	36.7	37.4	38.3	38.2	39.2	39.6	39.6	39.3	39.9	38.6	36.6	33.6	32.7	29.5	28.1	49.9
13.0	Turbine ON - background adj (dBA)	12.6	19.5	22.3	26.1	29.9	34.8	35.5	37.8	44.9	41.8	40.9	42.9	43.1	43.1	49.4	44.9	45.3	45.5	45.5	45.3	44.6	43.7	42.6	40.5	37.5	34.2	[28.5]	[23.3]	56.8
	Signal to noise (dB)	11.8	13.4	10.6	11.3	10.9	12.0	10.8	10.8	14.4	10.6	8.7	8.9	8.3	7.3	12.3	7.5	7.9	7.2	6.9	6.7	6.4	5.3	5.5	5.4	5.4	3.8	2.0	-1.8	7.7
	Uncertainty (dB)	1.1	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.9	0.8	0.9	0.8	0.9	0.9	0.9	1.0	1.2	1.2	1.2	1.2	1.6	1.9	3.4	0.9
	PWL (dBA)	61.1	68.0	70.9	74.6	78.5	83.3	84.0	86.4	93.4	90.3	89.5	91.4	91.7	91.7	97.9	93.4	93.8	94.0	94.1	93.8	93.1	92.2	91.1	89.0	86.0	82.7	[77.1]	[71.9]	105.4
	Turbine ON (dBA)	12.8	20.1	22.8	26.6	30.5	35.1	36.0	38.2	44.4	42.1	41.6	43.6	43.9	44.2	50.1	45.9	46.1	46.5	46.7	46.6	45.9	45.6	44.4	42.3	39.3	36.9	32.0	26.8	57.8
13.5	Background (dBA)	1.1	6.6	12.3	15.2	19.3	23.4	25.2	27.8	31.1	32.4	34.0	35.6	36.6	37.5	38.4	39.2	39.1	40.2	40.6	40.7	40.4	41.1	39.8	37.8	34.7	33.7	30.1	27.6	50.9
	Turbine ON - background adj (dBA)	12.5	19.9	22.4	26.3	30.1	34.8	35.6	37.8	44.2	41.7	40.8	42.9	43.0	43.1	49.8	44.9	45.1	45.4	45.5	45.2	44.4	43.7	42.5	40.4	37.4	34.0	[29]	[23.8]	56.8
	Signal to noise (dB)	11.7	13.5	10.5	11.4	11.2	11.8	10.8	10.4	13.3	9.8	7.6	8.0	7.3	6.6	11.7	6.7	7.0	6.3	6.2	5.8	5.5	4.5	4.6	4.5	4.6	3.2	1.9	-0.8	6.9
	Uncertainty (dB)	1.1	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.9	0.9	0.8	0.9	0.9	1.0	1.0	1.0	1.1	1.4	1.4	1.4	1.4	1.9	2.0	3.4	1.0
	PWL (dBA)	61.1	68.4	71.0	74.8	78.7	83.4	84.1	86.4	92.7	90.2	89.3	91.4	91.6	91.6	98.3	93.4	93.7	93.9	94.1	93.8	93.0	92.2	91.1	89.0	86.0	82.5	[77.5]	[72.4]	105.3
13.5	Turbine ON (dBA)	12.7	19.8	22.3	26.3	30.2	34.8	35.6	37.8	45.0	41.8	41.3	43.3	43.7	43.9	49.7	45.8	46.1	46.8	47.2	47.1	46.5	46.4	45.2	43.1	40.1	37.8	33.1	28.0	58.0
	Background (dBA)	1.8	6.8	12.5	15.6	19.6	23.2	25.2	27.5	30.6	31.6	33.1	34.7	35.6	36.7	37.5	38.3	38.1	39.2	39.6	39.8	39.6	40.3	39.0	37.0	33.9	32.8	29.3	27.4	50.1
	Turbine ON - background adj (dBA)	12.3	19.6	21.8	25.9	29.8	34.5	35.2	37.4	44.8	41.4	40.6	42.6	42.9	43.0	49.4	45.0	45.3	45.9	46.3	46.2	45.6	45.2	44.0	41.9	38.9	36.2	30.7	[25]	57.2
	Signal to noise (dB)	10.8	13.0	9.8	10.7	10.6	11.6	10.4	10.3	14.4	10.2	8.2	8.6	8.0	7.3	12.2	7.5	7.9	7.6	7.3	7.0	6.1	6.2	6.2	6.2	5.0	3.8	0.6	7.9	
	Uncertainty (dB)	1.1	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.9	0.8	0.9	0.8	0.9	0.9	0.9	1.0	1.2	1.2	1.2	1.4	1.7	3.5	0.9	
PWL (dBA)	60.8	68.1	70.4	74.5	78.3	83.0	83.8	85.9	93.3	90.0	89.1	91.2	91.5	91.6	98.0	93.5	93.9	94.5	94.9	94.8	94.1	93.7	92.6	90.5	87.4	84.7	79.2	[73.5]	105.8	

# Table C.02 Detailed apparent sound power level data at 10m height

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement

Report ID: 13259.00.T24.RP3

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																		Overall										
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
5.0	Turbine ON (dBA)	12.3	11.1	15.4	21.5	23.8	30.7	29.2	32.1	36.1	37.4	37.7	38.1	38.5	39.6	41.4	40.6	41.3	39.9	40.1	40.3	39.6	38.6	37.0	35.4	32.9	31.4	30.3	33.8	51.6
	Background (dBA)	-2.4	2.8	7.8	11.4	15.0	19.7	21.0	22.9	25.6	26.3	27.5	29.4	29.6	30.7	31.3	30.9	30.8	30.3	30.3	30.5	30.5	31.0	30.7	30.8	29.9	30.5	30.6	35.8	43.7
	Turbine ON - background adj (dBA)	12.1	10.4	14.6	21.0	23.1	30.4	28.5	31.5	35.7	37.0	37.3	37.4	37.9	39.0	40.9	40.1	41.0	39.3	39.6	39.8	39.0	37.8	35.8	33.6	30.0	[28.4]	[27.3]	[30.8]	50.9
	Signal to noise (dB)	14.7	8.3	7.6	10.0	8.8	11.0	8.2	9.1	10.5	11.1	10.2	8.7	8.9	8.9	10.1	9.7	10.6	9.6	9.7	9.8	9.1	7.6	6.3	4.6	3.1	1.0	-0.2	-2.1	7.8
	Uncertainty (dB)	1.0	1.2	1.0	0.9	0.9	0.8	0.9	0.9	0.8	0.8	0.7	0.8	0.8	0.8	0.7	0.7	0.7	0.8	0.8	0.7	0.8	0.9	1.0	1.2	1.7	1.7	1.8	3.2	0.8
6.0	PWL (dBA)	60.7	58.9	63.1	69.6	71.7	78.9	77.0	80.0	84.2	85.6	85.9	86.0	86.5	87.5	89.5	88.6	89.5	87.9	88.1	88.3	87.5	86.4	84.3	82.2	78.5	[77]	[75.9]	[79.3]	99.4
	Turbine ON (dBA)	10.3	17.0	18.8	23.1	27.3	32.9	32.3	34.6	38.3	39.9	40.2	41.2	41.8	42.0	45.6	43.8	44.6	43.6	44.0	43.8	43.5	42.1	40.1	38.2	35.3	33.0	31.0	34.7	54.8
	Background (dBA)	-0.9	3.9	9.0	12.3	16.0	20.7	23.0	24.9	28.0	29.5	31.0	32.3	32.7	33.6	34.4	34.8	34.9	35.2	35.6	35.7	35.5	36.0	35.1	34.1	32.2	31.9	30.7	35.0	47.0
	Turbine ON - background adj (dBA)	10.0	16.8	18.3	22.8	26.9	32.6	31.8	34.1	37.9	39.5	39.6	40.6	41.2	41.3	45.3	43.2	44.1	42.9	43.3	43.1	42.8	40.9	38.4	36.1	32.4	[30]	[28]	[31.7]	54.1
	Signal to noise (dB)	11.2	13.0	9.8	10.9	11.3	12.1	9.3	9.6	10.3	10.4	9.1	8.9	9.1	8.4	11.3	9.0	9.7	8.4	8.4	8.1	8.0	6.1	5.0	4.1	3.1	1.1	0.3	-0.3	7.9
7.0	Uncertainty (dB)	1.1	1.0	0.9	0.9	0.9	0.8	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.1	1.2	1.4	1.7	1.8	1.8	3.3	0.9	
	PWL (dBA)	58.5	65.3	66.8	71.3	75.5	81.1	80.3	82.6	86.4	88.0	88.1	89.2	89.8	89.9	93.8	91.8	92.7	91.5	91.9	91.6	91.3	89.4	87.0	84.6	80.9	[78.5]	[76.6]	[80.3]	102.7
	Turbine ON (dBA)	12.3	18.8	21.9	25.9	29.7	34.9	35.3	37.5	43.5	41.6	41.4	42.8	43.5	43.5	47.9	45.1	45.4	45.2	45.3	45.1	44.5	43.6	42.2	40.2	37.2	34.6	30.6	30.8	56.5
	Background (dBA)	0.3	5.3	10.6	13.8	17.8	22.0	24.3	26.6	29.7	31.0	32.6	34.2	34.8	35.8	36.7	37.4	37.4	38.2	38.6	38.7	38.4	39.1	37.9	36.3	33.7	32.9	30.6	33.0	49.3
	Turbine ON - background adj (dBA)	12.0	18.6	21.5	25.6	29.4	34.7	34.9	37.2	43.4	41.2	40.7	42.2	42.8	42.7	47.6	44.2	44.6	44.2	44.3	43.9	43.2	41.7	40.2	37.9	34.6	[31.6]	[27.6]	[27.8]	55.6
8.0	Signal to noise (dB)	12.0	13.5	11.3	12.0	11.8	12.9	11.0	11.0	13.9	10.6	8.7	8.6	8.6	7.7	11.3	7.7	8.0	7.0	6.7	6.4	6.0	4.5	4.3	3.9	3.5	1.7	0.0	-2.2	7.2
	Uncertainty (dB)	1.1	1.0	0.9	0.9	0.9	0.8	0.9	0.9	0.8	0.8	0.7	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.9	0.9	1.2	1.3	1.4	1.5	1.7	1.7	3.3	0.9
	PWL (dBA)	60.5	67.1	70.1	74.1	77.9	83.2	83.4	85.7	91.9	89.8	89.3	90.7	91.4	91.3	96.2	92.8	93.2	92.8	92.8	92.5	91.7	90.3	88.7	86.4	83.1	[80.1]	[76.1]	[76.4]	104.1
	Turbine ON (dBA)	13.0	19.8	22.8	26.7	30.5	35.2	36.1	38.3	44.4	42.2	41.7	43.4	43.9	44.0	49.5	45.7	45.9	46.1	46.3	46.0	45.3	44.8	43.6	41.6	38.5	36.0	31.1	26.3	57.4
	Background (dBA)	1.2	6.1	11.7	15.1	18.8	22.7	24.6	27.3	30.4	31.6	33.1	34.7	35.4	36.4	37.3	38.0	38.3	39.0	39.3	39.2	38.9	39.4	38.2	36.5	33.9	33.0	30.4	32.0	49.8
9.0	Turbine ON - background adj (dBA)	12.7	19.6	22.5	26.4	30.2	35.0	35.8	37.9	44.2	41.8	41.1	42.8	43.2	49.2	44.9	45.1	45.2	45.3	45.0	44.2	43.3	42.2	40.0	36.7	33.0	[28.1]	[23.3]	56.6	
	Signal to noise (dB)	11.8	13.7	11.2	11.7	11.7	12.6	11.5	11.0	14.0	10.6	8.6	8.8	8.5	7.6	12.2	7.7	7.6	7.1	7.0	6.8	6.4	5.4	5.4	5.1	4.7	3.0	0.8	-5.7	7.7
	Uncertainty (dB)	1.1	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.9	0.9	0.9	1.2	1.1	1.2	1.3	1.8	1.8	3.2	0.9	
	PWL (dBA)	61.2	68.2	71.0	75.0	78.8	83.5	84.3	86.5	92.8	90.4	89.6	91.4	91.8	91.7	97.8	93.4	93.6	93.7	93.8	93.5	92.7	91.9	90.7	88.5	85.3	81.6	[76.7]	[71.9]	105.1
	Turbine ON (dBA)	12.9	19.8	22.8	26.5	30.4	35.1	35.9	38.1	44.9	42.1	41.5	43.5	43.8	43.9	49.7	45.7	46.0	46.3	46.5	46.3	45.7	45.2	44.0	42.0	39.0	36.5	31.6	26.4	57.6
10.0	Background (dBA)	1.7	7.1	13.0	16.2	20.0	23.9	25.8	28.2	30.9	31.9	33.4	35.1	36.0	37.1	37.9	38.7	38.7	39.7	40.1	40.3	40.1	40.7	39.4	37.5	34.6	33.7	30.4	28.9	50.5
	Turbine ON - background adj (dBA)	12.6	19.6	22.3	26.1	30.0	34.7	35.4	37.7	44.7	41.7	40.8	42.8	43.0	42.9	49.4	44.7	45.1	45.3	45.4	45.1	44.3	43.3	42.2	40.1	37.0	[33.5]	[28.6]	[23.4]	56.6
	Signal to noise (dB)	11.2	12.7	9.8	10.3	10.4	11.2	10.1	10.0	14.0	10.2	8.1	8.4	7.8	6.8	11.8	7.0	7.3	6.6	6.4	6.0	5.6	4.5	4.6	4.5	4.4	2.8	1.1	-2.4	7.0
	Uncertainty (dB)	1.1	1.0	0.9	0.8	0.8	0.8	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.9	0.9	0.9	1.0	1.3	1.3	1.3	1.3	1.8	1.8	3.1	0.9
	PWL (dBA)	61.1	68.1	70.9	74.7	78.5	83.3	84.0	86.2	93.3	90.2	89.3	91.3	91.5	91.5	97.9	93.3	93.6	93.8	93.9	93.6	92.8	91.8	90.7	88.6	85.5	[82]	[77.1]	[72]	105.2
10.0	Turbine ON (dBA)	12.7	19.7	22.3	26.2	30.2	34.8	35.4	37.6	44.7	41.7	41.0	43.2	43.4	43.7	49.4	45.6	46.0	46.6	47.1	47.0	46.3	46.1	44.9	42.9	39.8	37.5	32.7	27.6	57.8
	Background (dBA)	1.4	6.7	12.5	15.5	19.7	23.1	25.3	27.7	30.8	31.8	33.3	34.8	35.9	37.0	37.6	38.5	38.3	39.4	39.8	40.0	39.6	40.4	39.1	37.1	33.9	29.3	26.7	50.2	
	Turbine ON - background adj (dBA)	12.3	19.5	21.9	25.9	29.7	34.4	35.0	37.2	44.5	41.2	40.2	42.5	42.6	42.6	49.1	44.7	45.1	45.7	46.1	46.0	45.3	44.7	43.6	41.5	38.5	35.7	30.0	[24.6]	56.9
	Signal to noise (dB)	11.3	13.0	9.9	10.8	10.5	11.6	10.2	10.0	13.9	9.9	7.7	8.4	7.5	6.6	11.7	7.1	7.7	7.2	7.3	7.0	6.7	5.7	5.8	5.7	5.9	4.6	3.4	0.9	7.6
	Uncertainty (dB)	1.1	1.0	0.9	0.9	0.9	0.8	0.9	0.9	0.8	0.9	0.8	0.8	0.8	0.9	0.7	0.8	0.8	0.9	0.9	0.9	0.9	1.2	1.1	1.1	1.1	1.3	1.6	3.2	0.9
PWL (dBA)	60.9	68.0	70.4	74.4	78.3	83.0	83.6	85.7	93.1	89.8	88.8	91.0	91.1	91.1	97.6	93.3	93.7	94.2	94.7	94.6	93.9	93.3	92.1	90.1	87.1	84.2	78.6	[73.1]	105.5	

## Table C.03 Type B measurement uncertainty summary

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 1  
 Created on: 10/11/2017

Overall Equipment Uncertainties		
	Typical values	Used values
Calibration	0.2 dB	0.2 dB
Board	0.3 dB	0.3 dB
Distance	0.1 dB	0.1 dB
Air absorption	0 dB	0 dB
Weather	0.5 dB	0.5 dB

1/3 Octave Band Uncertainties		
Frequency (Hz)	Microphone Uncertainty	Overall (including overall equipment Uncertainties)
20	0.8 dB	1 dB
25	0.8 dB	1 dB
31.5	0.5 dB	0.8 dB
40	0.5 dB	0.8 dB
50	0.5 dB	0.8 dB
63	0.5 dB	0.8 dB
80	0.5 dB	0.8 dB
100	0.5 dB	0.8 dB
125	0.5 dB	0.8 dB
160	0.5 dB	0.8 dB
200	0.3 dB	0.7 dB
250	0.3 dB	0.7 dB
315	0.3 dB	0.7 dB
400	0.3 dB	0.7 dB
500	0.3 dB	0.7 dB
630	0.3 dB	0.7 dB
800	0.3 dB	0.7 dB
1000	0.3 dB	0.7 dB
1250	0.3 dB	0.7 dB
1600	0.3 dB	0.7 dB
2000	0.3 dB	0.7 dB
2500	0.5 dB	0.8 dB
3150	0.5 dB	0.8 dB
4000	0.5 dB	0.8 dB
5000	0.5 dB	0.8 dB
6300	0.5 dB	0.8 dB
8000	0.5 dB	0.8 dB
10000	1.3 dB	1.4 dB

# Table C.04 Detailed measurement uncertainty at hub height

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 11/6/2017

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																Overall															
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630		800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000			
8.0	Turbine ON	8.01	25	Average (dBA)	10.3	17.2	18.9	23.2	27.2	32.8	32.3	34.4	37.9	39.8	39.9	41.1	41.7	41.7	44.8	43.5	44.4	43.4	43.8	43.6	43.2	41.8	39.8	37.9	35.0	32.7	30.9	34.6	54.6			
				Uncertainty A (dB)	0.4	0.4	0.4	0.3	0.3	0.2	0.3	0.3	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1		0.1	0.3	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	0.8	1.4
				Combined Uncertainty (dB)	1.1	1.1	0.9	0.9	0.9	0.8	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	1.7	
	Background	7.99	22	Average (dBA)	-1.9	3.1	8.1	11.5	14.8	20.0	22.3	24.1	27.0	28.8	30.2	31.6	31.9	32.7	33.6	33.7	34.0	33.8	34.3	34.3	34.2	34.7	33.9	33.3	31.7	31.6	30.8	35.4	46.1			
				Uncertainty A (dB)	0.5	0.4	0.3	0.4	0.4	0.4	0.6	0.5	0.5	0.6	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9	0.9	0.8	0.8	0.7	0.6	0.4	0.3	0.2		0.7		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.1	1.1	0.9	0.9	0.9	0.9	1.0	0.9	0.9	1.0	0.9	0.9	1.0	1.0	1.0	1.0	1.0	1.0	1.1	1.1	1.1	1.1	1.1	1.2	1.1	1.0	0.9	0.8		0.8	1.6	
8.5	Turbine ON	8.49	31	Average (dBA)	9.7	17.1	18.5	22.9	27.3	33.0	32.2	34.5	38.3	40.0	40.3	41.3	41.9	42.3	46.1	44.1	44.9	43.9	44.4	44.1	43.9	42.4	40.3	38.4	35.6	33.2	31.3	35.2	55.1			
				Uncertainty A (dB)	0.3	0.2	0.3	0.3	0.3	0.2	0.3	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1		0.1	0.3	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.0	1.0	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.5	
	Background	8.50	20	Average (dBA)	-1.0	3.8	9.3	12.4	16.4	21.2	23.6	25.4	28.6	30.1	31.7	33.0	33.2	34.0	34.5	35.1	35.0	35.5	35.9	35.9	35.7	36.4	35.4	34.4	32.4	32.1	30.9	35.1	47.3			
				Uncertainty A (dB)	0.5	0.4	0.4	0.4	0.6	0.4	0.7	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.7	1.0	1.0	1.0	1.0	1.1	1.0	0.8	0.6	0.5	0.3		0.9		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.1	1.1	0.9	0.9	1.0	0.9	1.1	1.0	1.0	1.1	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.2	1.2	1.2	1.2	1.2	1.4	1.3	1.1	1.0	0.9		0.9	1.7	
9.0	Turbine ON	9.01	43	Average (dBA)	10.6	17.6	19.9	24.0	27.9	33.5	33.3	35.6	40.2	40.5	40.6	41.9	42.5	42.6	46.7	44.4	45.1	44.3	44.6	44.4	44.0	42.7	40.9	38.9	36.0	33.5	30.9	34.1	55.5			
				Uncertainty A (dB)	0.4	0.2	0.5	0.4	0.3	0.2	0.3	0.3	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1		0.2	0.8	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.1	1.0	0.9	0.9	0.9	0.8	0.9	0.9	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.6	
	Background	8.97	17	Average (dBA)	0.5	5.2	10.1	13.2	17.1	21.4	23.6	25.9	29.2	30.3	31.9	33.2	33.9	34.9	35.7	36.4	36.5	36.9	37.4	37.5	37.2	37.6	36.5	35.2	33.0	32.3	30.4	33.6	48.2			
				Uncertainty A (dB)	0.7	0.6	0.6	0.5	0.6	0.5	0.6	0.6	0.7	0.5	0.5	0.6	0.7	0.6	0.6	0.6	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.6	0.5	0.4		0.5	1.6	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.2	1.2	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.9	1.0	0.9	0.9	0.9	1.0	1.0	1.1	1.1	1.1	1.1	1.1	1.1	1.2	1.1	1.0	0.9		0.9	2.1	
9.5	Turbine ON	9.51	28	Average (dBA)	11.8	18.5	21.4	25.5	29.3	35.0	34.9	37.1	42.9	41.4	41.2	42.6	43.2	43.3	47.5	44.9	45.3	45.1	45.3	45.0	44.4	43.4	41.8	39.8	36.8	34.2	30.6	32.1	56.3			
				Uncertainty A (dB)	0.7	0.4	0.8	0.7	0.6	0.4	0.6	0.5	0.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1		0.2	1.1	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.2	1.1	1.1	1.1	1.0	0.9	1.0	1.0	1.0	1.0	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.8	
	Background	9.46	35	Average (dBA)	0.3	5.1	10.2	13.4	17.3	21.7	23.7	25.9	29.3	30.5	32.1	33.6	34.1	35.1	36.0	36.7	36.8	37.4	37.8	38.0	37.8	38.4	37.3	35.8	33.3	32.7	30.6	33.6	48.6			
				Uncertainty A (dB)	0.6	0.4	0.4	0.4	0.5	0.4	0.5	0.4	0.5	0.4	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.8	0.8	0.8	0.8	0.8	0.8	0.6	0.5	0.4	0.4		1.1		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.2	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	1.0	1.1	1.1	1.1	1.1	1.2	1.1	1.0	0.9	0.9		1.8		
10.0	Turbine ON	10.06	20	Average (dBA)	13.1	19.4	22.8	26.8	30.7	35.4	36.3	38.6	45.2	42.3	41.9	43.3	44.1	44.1	48.7	45.5	45.5	45.6	45.6	45.3	44.5	44.0	43.0	40.9	37.8	35.2	30.4	27.0	57.0			
				Uncertainty A (dB)	0.4	0.3	0.5	0.5	0.4	0.2	0.2	0.3	0.6	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.2	0.3	0.3		0.7		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.1	1.1	0.9	0.9	0.9	0.8	0.8	0.9	1.0	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.6	
	Background	10.00	24	Average (dBA)	0.7	5.5	10.8	14.0	17.9	21.9	24.3	26.3	29.4	30.7	32.3	33.8	34.6	35.7	36.4	37.2	37.3	38.0	38.4	38.6	38.3	38.9	37.6	36.0	33.4	32.7	30.5	33.2	49.1			
				Uncertainty A (dB)	0.6	0.5	0.5	0.5	0.6	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.6	0.5		1.4		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4	
				Combined Uncertainty (dB)	1.2	1.1	1.0	0.9	1.0	0.9	1.0	1.0	1.0	1.0	0.9	0.9	0.9	0.9	1.0	1.0	1.0	1.1	1.0	1.2	1.1	1.2	1.2	1.3	1.3	1.1	1.0	0.9		2.0		

# Table C.04 Detailed measurement uncertainty at hub height

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																Overall														
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630		800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
10.5	Turbine ON	10.58	13	Average (dBA)	14.1	20.2	23.6	27.4	31.3	35.9	36.8	39.1	44.5	42.7	42.2	43.7	44.3	44.3	49.0	45.7	45.9	45.8	45.9	45.6	44.9	44.4	43.2	41.2	38.1	35.5	30.6	25.6	57.3		
				Uncertainty A (dB)	0.3	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.6	0.2	0.2	0.2	0.2	0.2	0.4	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.4	0.4	0.4	0.3	0.4		0.5	0.5
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4
				Combined Uncertainty (dB)	1.1	1.1	0.9	0.9	0.8	0.8	0.8	0.9	1.0	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.9	0.9	0.9	0.9		1.5	
	Background	10.49	31	Average (dBA)	0.1	5.6	11.3	14.8	19.0	22.7	25.0	28.0	30.6	32.0	33.7	35.4	36.1	37.1	38.0	38.7	38.6	39.7	40.0	40.1	39.7	40.4	39.2	37.4	34.5	33.6	30.7	31.6	50.5		
Uncertainty A (dB)				0.5	0.5	0.5	0.5	0.6	0.4	0.4	0.5	0.5	0.4	0.5	0.5	0.6	0.6	0.6	0.6	0.7	0.6	0.8	0.8	0.8	0.8	0.9	0.8	0.7	0.5	0.5	0.4	1.0			
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		1.4	
Combined Uncertainty (dB)				1.1	1.1	0.9	0.9	1.0	0.9	0.9	0.9	0.9	0.9	0.8	0.9	0.9	0.9	0.9	1.0	0.9	1.1	1.1	1.1	1.1	1.1	1.2	1.2	1.1	1.0	0.9	0.9	1.8			
11.0	Turbine ON	10.99	30	Average (dBA)	12.9	19.8	22.9	26.8	30.6	35.3	36.1	38.4	44.4	42.2	41.7	43.4	43.9	44.0	49.5	45.7	45.9	46.2	46.3	46.1	45.4	44.9	43.7	41.7	38.7	36.2	31.3	26.3	57.4		
				Uncertainty A (dB)	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3		0.3	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.4
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.5
	Background	11.00	24	Average (dBA)	1.3	6.3	12.0	15.5	19.0	22.8	24.6	27.0	30.2	31.4	32.9	34.4	35.1	36.2	37.0	37.8	38.0	38.6	38.9	39.0	38.7	39.1	37.9	36.3	33.7	32.8	30.3	32.2	49.5		
Uncertainty A (dB)				0.6	0.5	0.6	0.6	0.6	0.4	0.3	0.3	0.4	0.3	0.3	0.4	0.4	0.4	0.4	0.5	0.5	0.6	0.6	0.7	0.7	0.7	0.8	0.7	0.6	0.5	0.5	0.5	1.3			
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8		1.4	
Combined Uncertainty (dB)				1.2	1.1	1.0	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.9	0.8	0.9	0.9	0.9	0.9	1.0	1.0	1.1	1.1	1.0	1.0	0.9	0.9	2.0			
11.5	Turbine ON	11.53	25	Average (dBA)	12.7	20.0	22.7	26.7	30.4	35.1	36.2	38.1	44.4	42.2	41.6	43.4	43.8	43.9	49.8	45.7	45.9	46.3	46.3	46.1	45.4	44.8	43.6	41.6	38.5	36.0	31.0	25.8	57.5		
				Uncertainty A (dB)	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3		0.3	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8		0.8	1.4
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.5
	Background	11.47	26	Average (dBA)	1.5	6.3	11.7	14.8	18.6	22.7	24.7	27.3	30.8	31.6	33.0	34.7	35.4	36.4	37.2	38.0	38.5	39.4	39.5	39.2	38.8	39.3	38.1	36.4	33.7	32.8	30.1	31.6	49.8		
Uncertainty A (dB)				0.6	0.4	0.4	0.4	0.4	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.6	0.6	0.8	0.7	0.7	0.7	0.7	0.8	0.8	0.7	0.5	0.5	0.5	1.3			
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8		1.4	
Combined Uncertainty (dB)				1.2	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.9	0.9	0.9	1.0	1.0	1.0	1.0	1.0	1.1	1.1	1.0	1.0	0.9	0.9	1.9			
12.0	Turbine ON	11.96	37	Average (dBA)	13.0	19.7	22.8	26.5	30.4	35.0	35.8	38.1	45.0	42.1	41.6	43.4	43.7	43.8	49.6	45.6	45.9	46.2	46.3	46.1	45.5	44.9	43.7	41.7	38.7	36.2	31.3	26.3	57.4		
				Uncertainty A (dB)	0.2	0.2	0.2	0.2	0.2	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2		0.2	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.4
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.5
	Background	12.04	21	Average (dBA)	2.5	7.8	13.9	17.4	20.8	24.7	26.5	28.9	30.9	31.9	33.5	35.2	35.9	37.0	37.8	38.6	38.7	39.6	40.1	40.3	40.3	40.9	39.6	37.8	35.1	34.5	31.3	30.5	50.7		
Uncertainty A (dB)				0.8	0.6	0.8	0.8	0.8	0.7	0.7	0.6	0.3	0.3	0.4	0.4	0.5	0.5	0.5	0.6	0.5	0.7	0.7	0.7	0.8	0.9	0.9	0.9	0.8	0.8	0.8	0.8	1.3			
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8		1.4	
Combined Uncertainty (dB)				1.3	1.2	1.1	1.1	1.1	1.1	1.1	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.9	0.9	1.0	1.0	1.0	1.0	1.0	1.1	1.2	1.2	1.2	1.1	1.1	1.1	2.0			
12.5	Turbine ON	12.50	36	Average (dBA)	12.9	19.7	22.7	26.4	30.3	35.1	35.8	38.2	45.1	42.2	41.6	43.5	43.8	44.0	49.7	45.7	46.0	46.4	46.5	46.3	45.7	45.2	44.0	42.0	39.0	36.5	31.5	26.3	57.6		
				Uncertainty A (dB)	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2		0.2	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.4
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.5
	Background	12.48	19	Average (dBA)	1.0	6.3	12.1	15.1	19.4	23.1	25.0	27.3	30.6	31.5	32.9	34.5	35.5	36.7	37.4	38.2	38.1	39.2	39.6	39.6	39.2	39.9	38.5	36.6	33.5	32.6	29.4	28.1	49.9		
Uncertainty A (dB)				0.5	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.6	0.6	0.6	0.6	0.7	0.8	0.7	0.6	0.6	0.5	1.1				
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4			
Combined Uncertainty (dB)				1.1	1.1	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	1.0	1.1	1.1	1.1	1.0	1.0	1.0	1.8			
13.0	Turbine ON	12.99	19	Average (dBA)	12.8	20.1	22.8	26.6	30.5	35.1	36.0	38.2	44.4	42.1	41.6	43.6	43.9	44.2	50.1	45.9	46.1	46.5	46.7	46.5	45.9	45.6	44.4	42.3	39.3	36.8	31.9	26.8	57.8		
				Uncertainty A (dB)	0.3	0.2	0.4	0.3	0.3	0.2	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.4	0.1	0.1	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.4	0.4		0.5	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.4
				Combined Uncertainty (dB)	1.1	1.0	0.9	0.9	0.9	0.9	0.																								

## Table C.05 Secondary Windscreen Influence

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
Report ID: 13259.00.T24.RP3


Page 1 of 1  
Created on: 11/1/2017


1/3 Octave Band (Hz)	Average (dB) (Lp screen - Lp no screen)	Standard Deviation (dB)
100	0.0	0.2
125	0.0	0.2
160	0.0	0.2
200	0.0	0.0
250	-0.1	0.2
315	-0.1	0.1
400	0.2	0.2
500	0.3	0.1
630	0.6	0.2
800	0.0	0.1
1000	0.2	0.3
1250	0.5	0.4
1600	0.6	0.3
2000	0.7	0.2
2500	1.0	0.2
3150	0.5	0.7
4000	0.1	0.7
5000	-0.5	0.6
6300	0.5	0.7
8000	0.9	1.1
10000	0.7	0.9
12500	0.3	0.7
16000	0.2	0.9
20000	0.2	0.8


---


## Appendix D Tonality Assessment


---











13259.00.T24.RP3

**Project Name**

Summerhaven Wind Energy Centre - Turbine T24 - IEC61400-11 Edition 3.0





Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 11, 2017  
 Revision: 1


**Figure Title**


Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s


**Figure D.05**

















# Table D.01 Tonality Assessment Table - 8 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 1  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
209	511			24.3	43.3	34.1	-9.2	-2.3	-6.9
509	512			24.8	43.8	42.5	-1.3	-2.3	1.0
514	513			24.2	43.1	41.0	-2.1	-2.3	0.2
506	517			24.8	43.8	42.6	-1.2	-2.3	1.1
437	522			25.1	44.1	39.5	-4.5	-2.3	-2.2
452	535			24.1	43.1	38.8	-4.4	-2.3	-2.0
468	535			24.7	43.7	38.5	-5.2	-2.3	-2.9
440	535			24.8	43.8	40.9	-2.9	-2.3	-0.6
501	535			24.2	43.2	35.4	-7.8	-2.3	-5.5
469	535			24.2	43.2	37.7	-5.6	-2.3	-3.2
435	535			24.3	43.4	35.6	-7.8	-2.3	-5.5
505	535			24.2	43.2	38.4	-4.8	-2.3	-2.5
460	535			24.9	44.0	39.7	-4.3	-2.3	-1.9
448	535			24.4	43.5	42.0	-1.4	-2.3	0.9
510	535			24.1	43.2	38.4	-4.7	-2.3	-2.4
453	535			24.3	43.3	36.2	-7.2	-2.3	-4.8
421	535			24.1	43.1	38.7	-4.4	-2.3	-2.1
436	535			24.3	43.3	34.8	-8.5	-2.3	-6.2
208	535			24.4	43.5	31.6	-11.9	-2.3	-9.6
492	535			23.8	42.8	38.2	-4.6	-2.3	-2.3
402	535			23.9	43.0	34.4	-8.6	-2.3	-6.2
779	536			26.0	45.0	35.8	-9.2	-2.3	-6.9
503	536			24.6	43.6	34.8	-8.8	-2.3	-6.4
513	536			24.4	43.4	38.5	-4.9	-2.3	-2.6
809	536			25.8	44.8	35.9	-8.9	-2.3	-6.5
Average	531						-4.9	-2.3	-2.6

# Table D.02 Tonality Assessment Table - 8.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 1  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
446	507			24.7	43.6	39.7	-3.9	-2.3	-1.6
481	510			24.7	43.6	42.9	-0.7	-2.3	1.6
508	510			24.6	43.5	42.1	-1.4	-2.3	0.9
433	511			25.0	44.0	40.6	-3.4	-2.3	-1.1
427	512			25.1	44.1	40.3	-3.7	-2.3	-1.4
428	512			24.9	43.9	40.1	-3.8	-2.3	-1.5
401	512			24.9	43.9	43.1	-0.8	-2.3	1.5
426	513			25.1	44.1	41.3	-2.8	-2.3	-0.5
504	513			24.3	43.3	41.4	-1.9	-2.3	0.4
464	514			24.7	43.7	42.6	-1.0	-2.3	1.3
463	515			24.8	43.8	42.8	-1.0	-2.3	1.3
400	515			24.5	43.5	44.0	0.6	-2.3	2.9
482	517			24.7	43.7	43.2	-0.5	-2.3	1.8
507	517			24.6	43.6	45.1	1.6	-2.3	3.9
422	518			25.0	44.0	44.2	0.2	-2.3	2.5
419	518			25.2	44.2	42.5	-1.7	-2.3	0.7
439	535			24.9	44.0	42.3	-1.6	-2.3	0.7
491	535			23.6	42.6	38.3	-4.3	-2.3	-2.0
486	535			24.7	43.7	41.1	-2.6	-2.3	-0.3
430	535			24.5	43.5	38.1	-5.4	-2.3	-3.1
418	535			24.6	43.6	38.6	-5.0	-2.3	-2.7
449	535			24.6	43.7	41.6	-2.1	-2.3	0.2
500	535			24.2	43.2	39.7	-3.5	-2.3	-1.2
434	535			24.6	43.6	38.4	-5.2	-2.3	-2.8
467	535			24.6	43.6	39.3	-4.3	-2.3	-2.0
498	535			25.3	44.3	37.3	-7.0	-2.3	-4.7
447	535			24.2	43.2	41.1	-2.1	-2.3	0.2
465	535			25.2	44.2	42.0	-2.2	-2.3	0.1
462	535			25.1	44.1	37.9	-6.3	-2.3	-3.9
476	535			25.0	44.0	40.2	-3.7	-2.3	-1.4
749	536			26.3	45.3	38.3	-7.0	-2.3	-4.6
Average	524						-2.3	-2.3	0.0

# Table D.05 Tonality Assessment Table - 10 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
849	121			27.5	45.8	42.4	-3.4	-2.0	-1.4
723	121			27.4	45.7	41.8	-3.9	-2.0	-1.9
628	121			27.1	45.4	48.1	2.7	-2.0	4.7
842	121			27.5	45.8	40.9	-4.9	-2.0	-2.9
722	121			27.9	46.2	47.5	1.3	-2.0	3.3
833	121			27.7	46.0	37.3	-8.7	-2.0	-6.7
753	121			27.3	45.5	41.7	-3.9	-2.0	-1.9
617	121			27.5	45.7	43.9	-1.9	-2.0	0.1
863	122			27.7	46.0	45.0	-1.0	-2.0	1.0
776	122			28.1	46.4	38.5	-7.9	-2.0	-5.9
629	124			27.6	45.8	42.6	-3.3	-2.0	-1.3
845	124			29.2	47.5	35.6	-11.8	-2.0	-9.8
740	127			27.5	45.8	35.6	-10.2	-2.0	-8.2
612	127			26.9	45.2	39.8	-5.4	-2.0	-3.4
Average	122						-2.7	-2.0	-0.7

# Table D.05 Tonality Assessment Table - 10 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 2 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
722	490			26.0	45.0	43.6	-1.4	-2.3	0.9
776	506			26.4	45.4	45.0	-0.3	-2.3	2.0
833	508			26.1	45.0	46.3	1.3	-2.3	3.6
740	508			26.7	45.7	43.5	-2.2	-2.3	0.1
753	509			26.3	45.2	48.3	3.1	-2.3	5.4
757	510			27.2	46.1	44.5	-1.6	-2.3	0.7
844	511			27.2	46.2	46.3	0.1	-2.3	2.4
849	512			27.3	46.2	37.2	-9.1	-2.3	-6.8
629	512			26.7	45.7	44.7	-1.0	-2.3	1.3
845	512			26.8	45.8	43.6	-2.1	-2.3	0.2
723	513			26.8	45.7	46.7	1.0	-2.3	3.3
444	515			25.6	44.5	47.8	3.2	-2.3	5.5
842	516			26.4	45.4	48.2	2.8	-2.3	5.1
777	517			26.3	45.3	45.6	0.3	-2.3	2.6
804	517			26.3	45.2	45.3	0.1	-2.3	2.4
617	517			27.3	46.2	45.3	-0.9	-2.3	1.4
Average	511						0.3	-2.3	2.6

# Table D.03 Tonality Assessment Table - 9 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
473	507			25.3	44.2	43.0	-1.2	-2.3	1.1
747	509			25.7	44.7	44.1	-0.6	-2.3	1.7
485	510			24.9	43.8	40.1	-3.7	-2.3	-1.4
838	511			25.0	43.9	43.0	-0.9	-2.3	1.4
424	511			24.7	43.6	43.9	0.3	-2.3	2.6
480	511			24.6	43.6	43.8	0.2	-2.3	2.5
425	511			25.1	44.1	42.7	-1.4	-2.3	1.0
839	512			25.7	44.7	42.1	-2.6	-2.3	-0.3
744	512			25.7	44.7	44.8	0.1	-2.3	2.5
417	512			25.4	44.4	43.3	-1.1	-2.3	1.3
479	512			24.2	43.2	42.7	-0.5	-2.3	1.8
410	512			24.9	43.8	42.6	-1.2	-2.3	1.1
415	512			25.0	44.0	43.6	-0.3	-2.3	2.0
451	512			24.9	43.9	43.3	-0.6	-2.3	1.7
484	513			24.8	43.7	43.8	0.0	-2.3	2.3
416	513			25.5	44.5	44.1	-0.4	-2.3	1.9
474	513			25.1	44.1	43.9	-0.2	-2.3	2.1
748	514			26.7	45.7	43.5	-2.1	-2.3	0.2
438	516			24.3	43.3	44.8	1.5	-2.3	3.8
432	516			24.7	43.7	43.3	-0.4	-2.3	1.9
423	517			24.9	43.9	45.7	1.8	-2.3	4.1
489	518			25.5	44.5	44.1	-0.4	-2.3	1.9
490	518			24.9	43.8	44.8	1.0	-2.3	3.3
431	518			24.5	43.5	43.6	0.1	-2.3	2.4
483	518			24.8	43.8	44.2	0.4	-2.3	2.7
450	518			24.5	43.4	44.2	0.7	-2.3	3.1
420	520			24.7	43.7	43.6	-0.1	-2.3	2.2
429	521			24.9	43.8	43.6	-0.3	-2.3	2.0
441	523			25.2	44.2	43.1	-1.0	-2.3	1.3
477	525			25.1	44.1	43.3	-0.8	-2.3	1.6
407	527			24.8	43.8	39.1	-4.7	-2.3	-2.3
471	529			25.4	44.4	44.1	-0.3	-2.3	2.0
750	530			26.4	45.4	41.9	-3.5	-2.3	-1.2
475	535			25.0	44.0	42.2	-1.8	-2.3	0.5
488	535			25.3	44.3	41.7	-2.6	-2.3	-0.3
461	535			25.4	44.4	43.4	-1.0	-2.3	1.3
466	535			24.9	43.9	41.4	-2.5	-2.3	-0.2
499	535			25.3	44.3	41.8	-2.6	-2.3	-0.2
743	536			26.0	45.0	40.6	-4.4	-2.3	-2.1
610	536			25.9	44.9	35.0	-9.9	-2.3	-7.6
736	536			26.8	45.8	39.7	-6.0	-2.3	-3.7
754	536			26.3	45.4	43.1	-2.3	-2.3	0.1
851	536			27.0	46.1	36.2	-9.9	-2.3	-7.6
Average	520						-1.0	-2.3	1.3

# Table D.04 Tonality Assessment Table - 9.5 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
411	58			17.5	35.8	31.6	-4.1	-2.0	-2.1
840	58			24.1	42.4	30.9	-11.5	-2.0	-9.5
409	58			16.7	35.0	32.1	-2.9	-2.0	-0.9
408	58			17.0	35.2	31.1	-4.1	-2.0	-2.1
611	58			22.1	40.3	32.0	-8.3	-2.0	-6.3
412	58			17.4	35.6	32.9	-2.7	-2.0	-0.7
864	58			24.3	42.6	31.0	-11.6	-2.0	-9.6
478	58			19.9	38.2	30.2	-7.9	-2.0	-5.9
472	58			20.3	38.6	30.5	-8.1	-2.0	-6.1
487	58			20.5	38.7	30.3	-8.5	-2.0	-6.5
413	58			17.8	36.0	31.3	-4.8	-2.0	-2.8
414	58			17.8	36.0	33.1	-2.9	-2.0	-0.9
445	61			19.3	37.6	39.3	1.7	-2.0	3.7
443	70			19.6	37.9	37.7	-0.1	-2.0	1.9
442	74			18.8	37.1	37.3	0.2	-2.0	2.2
Average	60						-3.4	-2.0	-1.4

# Table D.04 Tonality Assessment Table - 9.5 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 2 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
837	503			25.1	44.1	42.0	-2.0	-2.3	0.3
409	506			24.7	43.6	39.6	-4.0	-2.3	-1.7
445	510			24.6	43.6	45.6	2.0	-2.3	4.3
472	510			25.9	44.8	44.4	-0.4	-2.3	1.9
442	510			24.8	43.7	43.6	-0.1	-2.3	2.2
413	511			25.0	44.0	42.7	-1.3	-2.3	1.0
805	511			26.5	45.5	46.3	0.8	-2.3	3.1
746	511			25.9	44.8	44.2	-0.7	-2.3	1.7
803	511			25.9	44.9	47.2	2.3	-2.3	4.6
414	511			24.9	43.9	40.0	-3.8	-2.3	-1.5
412	514			25.5	44.5	42.8	-1.7	-2.3	0.7
411	514			25.7	44.7	40.7	-4.0	-2.3	-1.7
755	515			26.7	45.7	46.2	0.5	-2.3	2.8
443	515			24.9	43.9	44.6	0.8	-2.3	3.1
756	517			26.9	45.8	47.6	1.8	-2.3	4.1
778	517			26.2	45.2	47.5	2.3	-2.3	4.6
611	517			25.8	44.8	42.3	-2.5	-2.3	-0.2
852	517			27.5	46.4	43.0	-3.4	-2.3	-1.1
487	518			25.2	44.1	43.3	-0.9	-2.3	1.5
840	521			26.1	45.1	43.0	-2.0	-2.3	0.3
Average	513						-0.3	-2.3	2.0

# Table D.06 Tonality Assessment Table - 10.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 1  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
759	510			26.4	45.3	48.7	3.3	-2.3	5.6
815	512			26.6	45.5	43.7	-1.8	-2.3	0.5
729	512			26.9	45.9	48.5	2.7	-2.3	5.0
860	513			26.4	45.4	47.8	2.4	-2.3	4.7
869	513			26.5	45.5	44.5	-1.0	-2.3	1.3
867	515			26.8	45.8	48.7	2.9	-2.3	5.2
836	515			25.9	44.9	47.3	2.4	-2.3	4.7
830	517			26.8	45.8	47.9	2.1	-2.3	4.4
613	520			26.6	45.5	43.6	-1.9	-2.3	0.4
810	524			26.7	45.6	45.4	-0.2	-2.3	2.1
846	530			27.8	46.8	42.9	-3.9	-2.3	-1.5
780	536			26.6	45.6	42.3	-3.2	-2.3	-0.9
650	536			27.6	46.6	39.3	-7.3	-2.3	-4.9
Average	519						0.7	-2.3	3.0

# Table D.07 Tonality Assessment Table - 11 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
817	120			28.5	46.8	46.8	0.0	-2.0	2.0
739	121			27.7	46.0	38.7	-7.3	-2.0	-5.3
832	121			28.2	46.5	38.0	-8.4	-2.0	-6.4
807	121			27.2	45.5	44.0	-1.5	-2.0	0.5
812	121			27.9	46.2	43.5	-2.7	-2.0	-0.7
649	121			27.6	45.9	47.8	1.9	-2.0	3.9
786	122			28.7	47.0	44.7	-2.3	-2.0	-0.3
915	122			25.8	44.1	44.8	0.7	-2.0	2.7
685	123			27.6	45.9	44.7	-1.2	-2.0	0.8
856	123			27.4	45.6	40.5	-5.1	-2.0	-3.1
910	123			27.7	46.0	44.4	-1.6	-2.0	0.4
916	123			28.0	46.3	41.9	-4.5	-2.0	-2.5
861	123			28.3	46.6	41.4	-5.3	-2.0	-3.2
926	123			28.4	46.6	43.6	-3.0	-2.0	-1.0
635	124			27.4	45.7	42.9	-2.7	-2.0	-0.7
898	124			27.2	45.5	42.4	-3.1	-2.0	-1.1
886	124			28.3	46.6	35.3	-11.3	-2.0	-9.3
625	124			26.9	45.2	43.0	-2.1	-2.0	-0.1
824	124			28.4	46.7	40.9	-5.9	-2.0	-3.8
619	124			27.1	45.4	44.0	-1.4	-2.0	0.7
887	125			26.6	44.9	37.8	-7.1	-2.0	-5.0
607	125			26.7	44.9	38.7	-6.2	-2.0	-4.2
854	126			26.6	44.9	36.8	-8.1	-2.0	-6.1
763	126			28.4	46.7	38.1	-8.6	-2.0	-6.6
806	127			27.7	46.0	40.8	-5.1	-2.0	-3.1
865	127			28.3	46.5	34.5	-12.1	-2.0	-10.0
719	127			28.7	47.0	41.7	-5.3	-2.0	-3.3
765	127			27.5	45.8	40.1	-5.7	-2.0	-3.7
Average	124						-3.3	-2.0	-1.3

# Table D.07 Tonality Assessment Table - 11 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 2 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
817	499			26.1	45.0	46.9	1.9	-2.3	4.2
807	500			25.9	44.8	43.9	-0.9	-2.3	1.4
786	505			26.2	45.1	48.0	2.8	-2.3	5.1
763	505			26.6	45.5	45.1	-0.4	-2.3	1.9
649	505			26.5	45.5	46.6	1.1	-2.3	3.4
910	506			26.9	45.9	48.6	2.7	-2.3	5.0
739	509			26.2	45.2	45.2	0.1	-2.3	2.4
926	509			26.2	45.2	46.8	1.6	-2.3	3.9
856	510			26.7	45.7	47.2	1.5	-2.3	3.8
916	511			27.0	46.0	48.6	2.6	-2.3	4.9
861	511			26.6	45.6	47.8	2.2	-2.3	4.5
915	511			25.4	44.4	47.1	2.7	-2.3	5.0
758	511			26.6	45.6	45.6	0.0	-2.3	2.3
765	512			25.9	44.8	45.2	0.3	-2.3	2.6
619	512			26.4	45.4	48.0	2.6	-2.3	4.9
685	512			26.1	45.0	46.0	0.9	-2.3	3.3
886	512			26.6	45.5	47.0	1.4	-2.3	3.8
625	512			26.5	45.5	47.5	2.1	-2.3	4.4
865	512			26.4	45.3	46.8	1.4	-2.3	3.7
775	512			26.3	45.3	49.0	3.7	-2.3	6.0
898	513			26.2	45.2	47.9	2.7	-2.3	5.0
832	514			26.5	45.5	48.1	2.6	-2.3	4.9
824	516			26.4	45.4	45.5	0.1	-2.3	2.4
635	517			26.2	45.2	47.6	2.4	-2.3	4.7
719	517			26.8	45.8	45.5	-0.3	-2.3	2.0
887	518			25.8	44.8	44.8	0.0	-2.3	2.3
812	519			26.3	45.3	48.2	2.9	-2.3	5.2
607	520			27.4	46.4	46.2	-0.2	-2.3	2.1
854	521			26.0	44.9	44.1	-0.8	-2.3	1.5
806	521			26.4	45.4	44.5	-0.9	-2.3	1.4
Average	512						1.5	-2.3	3.8

# Table D.08 Tonality Assessment Table - 11.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
734	119			27.1	45.4	46.3	0.8	-2.0	2.8
609	120			25.7	44.0	43.9	-0.1	-2.0	1.9
801	121			27.1	45.4	46.6	1.2	-2.0	3.2
654	121			26.8	45.1	45.1	0.0	-2.0	2.0
825	123			28.1	46.4	39.7	-6.7	-2.0	-4.7
795	123			27.4	45.7	44.6	-1.1	-2.0	0.9
870	123			28.6	46.9	39.2	-7.6	-2.0	-5.6
858	123			27.1	45.4	39.8	-5.6	-2.0	-3.6
630	124			26.7	45.0	42.8	-2.2	-2.0	-0.2
796	124			28.6	46.8	43.3	-3.6	-2.0	-1.6
859	124			26.6	44.9	40.3	-4.6	-2.0	-2.6
792	124			26.9	45.1	40.8	-4.4	-2.0	-2.4
823	124			27.5	45.7	43.1	-2.6	-2.0	-0.6
897	124			27.9	46.2	42.7	-3.5	-2.0	-1.5
752	124			27.7	46.0	38.6	-7.4	-2.0	-5.4
814	124			27.7	45.9	39.0	-7.0	-2.0	-5.0
636	125			27.3	45.6	41.6	-4.0	-2.0	-2.0
762	125			28.1	46.4	38.1	-8.4	-2.0	-6.3
714	125			27.1	45.4	41.4	-4.0	-2.0	-2.0
875	125			26.3	44.6	39.0	-5.6	-2.0	-3.6
868	126			28.8	47.1	38.2	-8.9	-2.0	-6.9
922	126			26.6	44.9	41.8	-3.1	-2.0	-1.1
732	126			27.5	45.8	40.6	-5.2	-2.0	-3.2
908	127			28.4	46.7	40.4	-6.3	-2.0	-4.3
Average	123.75						-3.2	-2.0	-1.2

# Table D.08 Tonality Assessment Table - 11.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
752	506			26.3	45.2	48.0	2.8	-2.3	5.1
823	511			27.0	46.0	48.8	2.8	-2.3	5.1
630	512			26.5	45.5	47.3	1.8	-2.3	4.1
654	512			26.9	45.8	46.0	0.2	-2.3	2.5
825	512			26.8	45.8	50.3	4.5	-2.3	6.8
814	512			26.5	45.5	48.3	2.8	-2.3	5.1
908	512			26.8	45.8	49.4	3.6	-2.3	5.9
762	512			25.9	44.9	49.8	4.9	-2.3	7.2
858	512			26.5	45.4	47.4	2.0	-2.3	4.3
732	513			25.7	44.7	47.6	3.0	-2.3	5.3
796	513			27.0	45.9	48.4	2.5	-2.3	4.8
792	513			26.0	45.0	48.1	3.1	-2.3	5.4
795	513			26.0	44.9	47.9	3.0	-2.3	5.3
922	513			26.8	45.8	45.7	-0.1	-2.3	2.2
897	514			26.4	45.4	47.4	2.0	-2.3	4.3
609	514			26.4	45.3	48.6	3.3	-2.3	5.6
801	516			27.0	46.0	47.3	1.3	-2.3	3.6
714	516			26.0	45.0	47.4	2.4	-2.3	4.8
870	516			26.7	45.7	46.7	1.0	-2.3	3.4
859	517			26.3	45.3	48.1	2.9	-2.3	5.2
636	517			26.2	45.2	46.4	1.2	-2.3	3.5
634	518			27.0	46.0	41.5	-4.5	-2.3	-2.2
868	518			26.9	45.9	47.5	1.7	-2.3	4.0
875	520			26.0	45.0	46.5	1.6	-2.3	3.9
Average	514						2.4	-2.3	4.7

# Table D.09 Tonality Assessment Table - 12 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
787	120			27.8	46.1	48.2	2.2	-2.0	4.2
799	121			27.0	45.3	45.6	0.3	-2.0	2.3
721	121			27.3	45.6	46.2	0.6	-2.0	2.6
827	121			28.8	47.0	44.8	-2.3	-2.0	-0.3
878	121			28.2	46.4	43.2	-3.3	-2.0	-1.2
727	121			27.6	45.9	43.7	-2.2	-2.0	-0.2
717	121			26.3	44.6	47.2	2.7	-2.0	4.7
925	123			27.7	46.0	43.4	-2.6	-2.0	-0.6
627	123			26.4	44.7	45.0	0.3	-2.0	2.3
698	123			26.5	44.8	43.4	-1.4	-2.0	0.6
716	123			26.7	45.0	42.0	-3.0	-2.0	-1.0
689	124			27.1	45.4	42.3	-3.0	-2.0	-1.0
781	124			28.0	46.3	39.1	-7.1	-2.0	-5.1
826	124			27.7	46.0	41.5	-4.5	-2.0	-2.5
655	124			26.0	44.3	42.8	-1.5	-2.0	0.5
728	124			27.9	46.2	44.7	-1.4	-2.0	0.6
798	124			27.7	46.0	41.9	-4.1	-2.0	-2.1
793	124			28.4	46.6	43.3	-3.3	-2.0	-1.3
656	124			25.8	44.1	43.3	-0.9	-2.0	1.2
791	124			26.3	44.5	41.9	-2.6	-2.0	-0.6
820	124			27.1	45.4	42.0	-3.4	-2.0	-1.4
782	124			27.9	46.2	41.9	-4.3	-2.0	-2.3
631	124			27.0	45.3	42.4	-2.9	-2.0	-0.8
831	124			28.4	46.7	35.6	-11.1	-2.0	-9.1
880	126			27.0	45.3	37.9	-7.4	-2.0	-5.4
855	126			26.7	45.0	38.5	-6.6	-2.0	-4.6
764	126			27.5	45.8	37.6	-8.2	-2.0	-6.2
720	126			28.1	46.3	42.8	-3.5	-2.0	-1.5
800	126			27.8	46.1	42.5	-3.6	-2.0	-1.6
699	126			26.0	44.3	44.1	-0.2	-2.0	1.8
760	126			28.2	46.5	40.2	-6.3	-2.0	-4.3
902	127			27.7	46.0	43.3	-2.8	-2.0	-0.8
745	127			27.6	45.9	38.5	-7.4	-2.0	-5.4
696	127			26.8	45.1	43.7	-1.5	-2.0	0.5
606	127			26.0	44.3	40.9	-3.4	-2.0	-1.4
620	128			26.6	44.9	43.0	-2.0	-2.0	0.0
Average	124						-2.2	-2.0	-0.2

# Table D.09 Tonality Assessment Table - 12 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 2 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
787	495			26.5	45.4	44.2	-1.2	-2.3	1.0
717	506			25.6	44.5	46.3	1.8	-2.3	4.1
627	508			27.3	46.3	47.4	1.1	-2.3	3.4
843	508			26.0	44.9	47.8	2.9	-2.3	5.2
781	510			26.3	45.2	43.5	-1.8	-2.3	0.5
793	510			26.5	45.5	51.0	5.5	-2.3	7.8
720	510			26.0	44.9	45.8	0.9	-2.3	3.2
826	511			26.4	45.4	46.9	1.5	-2.3	3.8
925	511			26.5	45.4	48.2	2.7	-2.3	5.1
782	512			25.7	44.7	47.2	2.5	-2.3	4.8
827	512			27.8	46.8	48.6	1.8	-2.3	4.2
721	512			26.6	45.6	47.3	1.8	-2.3	4.1
689	512			27.7	46.6	51.0	4.4	-2.3	6.7
716	512			25.9	44.9	49.1	4.2	-2.3	6.5
696	513			26.1	45.0	46.4	1.3	-2.3	3.7
655	513			26.0	45.0	47.6	2.6	-2.3	4.9
831	513			26.7	45.7	51.2	5.5	-2.3	7.8
880	513			25.5	44.4	51.3	6.9	-2.3	9.2
631	513			26.8	45.7	48.6	2.8	-2.3	5.1
727	513			26.3	45.2	48.1	2.9	-2.3	5.2
728	514			26.3	45.2	49.0	3.7	-2.3	6.0
699	514			26.9	45.8	45.9	0.1	-2.3	2.4
820	514			25.9	44.9	47.7	2.8	-2.3	5.1
902	514			26.8	45.7	46.5	0.8	-2.3	3.1
791	516			25.3	44.3	47.4	3.1	-2.3	5.4
764	517			25.7	44.7	46.6	1.8	-2.3	4.2
855	517			26.6	45.6	45.6	0.0	-2.3	2.3
698	519			26.2	45.2	46.9	1.7	-2.3	4.0
798	519			26.7	45.7	49.3	3.6	-2.3	6.0
800	520			27.1	46.1	45.7	-0.4	-2.3	1.9
656	520			26.3	45.2	48.9	3.6	-2.3	5.9
606	521			26.4	45.3	46.9	1.5	-2.3	3.9
760	522			26.9	45.9	45.5	-0.4	-2.3	2.0
745	523			26.5	45.4	44.4	-1.1	-2.3	1.3
Average	513						2.5	-2.3	4.9

# Table D.10 Tonality Assessment Table - 12.5 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
877	121			27.3	45.6	45.4	-0.2	-2.0	1.8
616	121			26.8	45.1	46.9	1.9	-2.0	3.9
866	123			28.3	46.6	38.4	-8.2	-2.0	-6.2
911	123			28.3	46.6	41.5	-5.0	-2.0	-3.0
647	123			26.3	44.6	45.0	0.4	-2.0	2.4
632	123			27.1	45.4	42.9	-2.5	-2.0	-0.5
924	123			26.6	44.9	44.1	-0.8	-2.0	1.2
697	123			25.3	43.5	44.2	0.6	-2.0	2.7
797	123			28.5	46.8	43.6	-3.2	-2.0	-1.2
657	124			25.4	43.7	45.1	1.4	-2.0	3.4
648	124			27.2	45.5	43.2	-2.3	-2.0	-0.3
705	124			28.0	46.3	42.1	-4.2	-2.0	-2.2
633	124			27.7	46.0	42.0	-4.0	-2.0	-2.0
652	124			27.3	45.6	42.6	-2.9	-2.0	-0.9
715	124			25.9	44.2	40.7	-3.5	-2.0	-1.5
818	124			29.2	47.5	35.5	-12.0	-2.0	-10.0
821	124			28.5	46.8	39.8	-7.0	-2.0	-5.0
909	124			27.8	46.1	41.1	-5.0	-2.0	-3.0
895	124			27.3	45.6	41.5	-4.1	-2.0	-2.1
660	124			25.2	43.5	44.9	1.4	-2.0	3.4
785	124			27.9	46.2	42.0	-4.2	-2.0	-2.2
788	124			28.4	46.7	42.7	-4.0	-2.0	-2.0
623	124			26.0	44.3	42.0	-2.2	-2.0	-0.2
695	125			27.1	45.4	42.9	-2.5	-2.0	-0.5
848	125			28.2	46.5	37.2	-9.3	-2.0	-7.3
730	125			28.3	46.6	39.9	-6.7	-2.0	-4.7
923	125			27.0	45.2	43.4	-1.8	-2.0	0.2
819	126			27.4	45.6	42.3	-3.3	-2.0	-1.3
726	126			27.6	45.9	40.9	-5.0	-2.0	-3.0
626	126			25.9	44.2	43.6	-0.6	-2.0	1.4
614	127			26.7	44.9	41.1	-3.8	-2.0	-1.8
691	127			26.6	44.9	41.6	-3.3	-2.0	-1.3
811	127			27.3	45.6	37.4	-8.2	-2.0	-6.2
841	127			28.2	46.4	37.0	-9.4	-2.0	-7.4
618	127			27.4	45.7	41.4	-4.3	-2.0	-2.3
651	128			28.0	46.3	43.4	-2.9	-2.0	-0.9
	124						-2.6	-2.0	-0.6

# Table D.10 Tonality Assessment Table - 12.5 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 2 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
877	508			25.7	44.6	47.3	2.7	-2.3	5.0
924	510			25.8	44.8	48.9	4.2	-2.3	6.5
911	511			26.6	45.5	45.9	0.4	-2.3	2.7
866	512			26.4	45.4	47.9	2.5	-2.3	4.8
616	512			26.3	45.3	47.7	2.5	-2.3	4.8
632	512			26.3	45.3	48.5	3.2	-2.3	5.5
660	512			25.5	44.5	46.5	2.1	-2.3	4.4
797	512			26.6	45.6	47.6	2.1	-2.3	4.4
785	512			26.5	45.5	49.7	4.2	-2.3	6.6
841	512			25.4	44.4	48.6	4.2	-2.3	6.5
909	512			26.2	45.1	47.4	2.2	-2.3	4.6
821	512			26.3	45.2	48.8	3.5	-2.3	5.9
623	513			25.9	44.8	46.8	1.9	-2.3	4.3
657	513			25.7	44.7	48.3	3.7	-2.3	6.0
652	513			26.2	45.2	49.1	3.9	-2.3	6.2
697	513			25.6	44.6	46.2	1.7	-2.3	4.0
647	513			25.9	44.8	50.7	5.8	-2.3	8.2
788	513			26.5	45.4	47.1	1.6	-2.3	3.9
705	513			27.2	46.1	47.0	0.8	-2.3	3.2
715	513			25.4	44.4	48.5	4.1	-2.3	6.4
633	514			27.7	46.6	50.5	3.9	-2.3	6.2
730	516			27.1	46.1	46.8	0.7	-2.3	3.0
811	516			26.5	45.4	48.9	3.5	-2.3	5.8
691	517			25.7	44.7	47.7	3.0	-2.3	5.3
648	517			25.7	44.6	49.5	4.9	-2.3	7.2
848	517			26.9	45.8	46.1	0.3	-2.3	2.6
695	517			27.2	46.1	47.0	0.9	-2.3	3.2
895	517			26.1	45.1	47.7	2.6	-2.3	4.9
614	520			26.0	45.0	44.9	-0.1	-2.3	2.2
819	520			26.5	45.5	45.1	-0.4	-2.3	1.9
626	521			25.3	44.2	47.2	3.0	-2.3	5.3
726	521			26.8	45.8	43.0	-2.8	-2.3	-0.5
618	521			26.5	45.5	46.1	0.6	-2.3	3.0
651	533			26.5	45.5	43.1	-2.4	-2.3	0.0
818	536			27.3	46.3	46.0	-0.3	-2.3	2.0
Average	516						2.5	-2.3	4.8

# Table D.12 Tonality Assessment Table - 13.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
725	121			28.3	46.6	44.4	-2.2	-2.0	-0.2
813	121			27.9	46.2	44.3	-1.9	-2.0	0.1
930	122			27.2	45.5	44.8	-0.7	-2.0	1.3
929	123			26.8	45.1	43.5	-1.5	-2.0	0.5
885	123			28.3	46.5	37.8	-8.8	-2.0	-6.8
913	123			26.3	44.6	42.9	-1.8	-2.0	0.3
693	123			25.9	44.2	43.7	-0.5	-2.0	1.5
901	123			26.9	45.2	43.8	-1.4	-2.0	0.6
904	123			26.9	45.2	42.6	-2.6	-2.0	-0.6
702	124			28.1	46.4	43.8	-2.5	-2.0	-0.5
894	124			26.0	44.3	41.6	-2.7	-2.0	-0.7
712	124			26.8	45.1	43.1	-2.0	-2.0	0.0
658	124			25.8	44.1	43.9	-0.1	-2.0	1.9
659	124			25.4	43.7	44.0	0.3	-2.0	2.3
888	125			27.1	45.3	37.3	-8.1	-2.0	-6.1
889	125			27.0	45.3	40.1	-5.2	-2.0	-3.2
881	125			27.3	45.6	41.2	-4.4	-2.0	-2.4
917	126			27.2	45.5	39.9	-5.6	-2.0	-3.6
707	126			26.3	44.6	43.8	-0.8	-2.0	1.2
914	126			26.6	44.9	40.9	-4.1	-2.0	-2.0
931	126			28.2	46.5	39.3	-7.1	-2.0	-5.1
741	127			27.6	45.8	38.8	-7.1	-2.0	-5.1
686	128			26.0	44.3	41.5	-2.8	-2.0	-0.8
Average	124						-2.6	-2.0	-0.5

# Table D.12 Tonality Assessment Table - 13.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 2 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
693	507			26.7	45.7	46.5	0.8	-2.3	3.2
913	510			25.5	44.4	47.7	3.3	-2.3	5.6
901	510			26.2	45.2	47.6	2.4	-2.3	4.7
712	510			26.2	45.1	50.0	4.8	-2.3	7.1
885	512			27.2	46.1	49.6	3.5	-2.3	5.8
930	513			27.8	46.7	46.0	-0.8	-2.3	1.5
658	513			25.5	44.5	46.8	2.3	-2.3	4.6
894	514			25.7	44.7	48.5	3.8	-2.3	6.1
702	514			28.1	47.0	46.7	-0.3	-2.3	2.0
904	516			27.2	46.2	47.4	1.2	-2.3	3.6
881	516			27.0	46.0	50.5	4.5	-2.3	6.8
889	516			24.4	43.3	45.3	2.0	-2.3	4.3
929	517			27.0	46.0	46.1	0.0	-2.3	2.4
917	517			25.4	44.4	46.6	2.3	-2.3	4.6
888	517			25.1	44.1	44.8	0.7	-2.3	3.0
659	518			26.0	44.9	48.8	3.8	-2.3	6.2
725	519			27.5	46.5	43.9	-2.6	-2.3	-0.3
707	521			25.3	44.3	46.4	2.1	-2.3	4.4
931	521			27.0	46.0	47.0	1.1	-2.3	3.4
914	523			26.5	45.5	49.2	3.7	-2.3	6.0
686	527			26.2	45.2	43.1	-2.2	-2.3	0.2
813	530			26.1	45.1	45.1	0.0	-2.3	2.3
741	533			26.0	45.0	45.5	0.5	-2.3	2.8
Average	517						2.0	-2.3	4.4

# Table D.11 Tonality Assessment Table - 13 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
724	121			28.0	46.3	43.5	-2.9	-2.0	-0.8
742	122			27.0	45.3	43.9	-1.4	-2.0	0.6
876	123			27.0	45.3	40.1	-5.2	-2.0	-3.2
761	123			28.5	46.8	38.3	-8.5	-2.0	-6.5
921	123			26.4	44.7	42.8	-1.9	-2.0	0.1
694	123			26.1	44.4	44.6	0.2	-2.0	2.2
615	124			26.1	44.4	42.9	-1.5	-2.0	0.5
896	124			27.4	45.7	41.9	-3.8	-2.0	-1.8
784	124			27.6	45.9	40.2	-5.6	-2.0	-3.6
713	124			27.7	46.0	41.2	-4.8	-2.0	-2.8
690	124			26.4	44.7	42.6	-2.1	-2.0	-0.1
688	124			26.3	44.6	43.2	-1.4	-2.0	0.6
783	125			27.5	45.8	40.9	-4.9	-2.0	-2.9
822	126			27.9	46.1	39.0	-7.2	-2.0	-5.2
731	126			27.1	45.4	38.9	-6.5	-2.0	-4.5
706	126			28.3	46.6	43.8	-2.9	-2.0	-0.8
857	126			27.7	46.0	39.9	-6.1	-2.0	-4.1
873	127			29.1	47.4	39.6	-7.8	-2.0	-5.8
874	127			28.7	47.0	40.7	-6.3	-2.0	-4.3
Average	124						-3.6	-2.0	-1.6

# Table D.11 Tonality Assessment Table - 13 m/s

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 2 of 2  
 Created on: 10/11/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
694	508			26.8	45.8	48.6	2.9	-2.3	5.2
761	508			26.1	45.0	49.0	3.9	-2.3	6.3
921	510			27.3	46.2	47.1	0.9	-2.3	3.2
713	511			26.6	45.6	51.6	6.0	-2.3	8.3
615	512			25.3	44.2	48.4	4.2	-2.3	6.5
688	512			26.5	45.4	47.6	2.2	-2.3	4.5
876	512			26.4	45.4	49.4	4.0	-2.3	6.3
822	513			26.9	45.9	49.9	4.0	-2.3	6.3
857	514			26.2	45.2	47.1	1.8	-2.3	4.2
706	514			26.1	45.1	49.4	4.3	-2.3	6.6
724	515			26.7	45.7	48.2	2.5	-2.3	4.9
784	517			26.4	45.4	47.4	2.0	-2.3	4.3
783	517			26.0	45.0	46.7	1.7	-2.3	4.0
896	517			27.1	46.1	48.9	2.8	-2.3	5.1
742	517			26.4	45.4	46.7	1.2	-2.3	3.6
690	520			26.7	45.6	49.5	3.9	-2.3	6.2
731	521			26.3	45.2	44.2	-1.0	-2.3	1.3
874	523			26.5	45.5	44.1	-1.4	-2.3	0.9
873	524			27.0	45.9	45.0	-1.0	-2.3	1.4
Average	515						2.8	-2.3	5.1

---

## Appendix E Measurement Data

---

# Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 6  
 Created on: 10/11/2017

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
1	6.0	48.4	379	292.0	281.7	0.5	11.1	3.2	4.3	8	98.8	73
2	5.5	47.1	306	292.0	282.4	1.5	10.0	4.4	4.1	8	98.8	73
3	5.1	46.2	236	292.0	277.0	0.5	8.8	4.0	4.2	8	98.8	73
4	4.8	45.0	184	292.0	277.6	0.5	8.0	3.8	4.4	8	98.8	73
5	4.4	44.4	147	292.0	279.9	1.1	7.7	3.2	3.9	8	98.8	73
6	4.6	44.7	168	292.0	282.1	1.5	7.8	5.1	3.4	8	98.8	74
7	4.6	45.5	172	292.0	282.5	1.5	7.9	4.8	3.5	8	98.8	74
8	4.6	46.1	165	292.0	282.5	1.5	7.8	4.8	4.3	8	98.8	74
9	4.6	45.7	171	292.0	282.4	1.5	7.9	5.5	4.5	8	98.8	74
10	4.7	45.5	142	292.0	283.4	1.2	7.6	4.7	4.6	8	98.8	74
11				292.0	285.9	0.5	7.3	4.4	4.3	8	98.8	72
12				292.0	288.2	0.5	7.1	2.8	4.6	8	98.8	72
13				292.0	288.6	0.5	7.1	2.0	4.2	8	98.8	72
14				292.0	289.6	0.5	7.1	2.1	4.0	8	98.8	72
15	3.6	44.3	56	292.0	287.6	0.5	7.2	2.7	4.0	8	98.8	72
16	4.1	44.6	107	292.0	286.0	0.5	7.4	4.1	3.6	8	98.8	72
17	4.3	44.6	133	292.0	285.9	1.0	7.5	3.5	3.6	8	98.8	72
18	4.8	45.3	187	292.0	285.9	1.5	8.0	3.5	4.2	8	98.8	74
19	5.3	45.7	266	292.0	285.9	1.5	9.1	6.5	4.2	8	98.8	74
20	5.7	47.1	341	292.0	285.9	1.5	10.5	6.6	4.3	8	98.8	74
21	6.0	48.2	393	292.0	285.9	1.5	11.2	5.3	4.1	8	98.8	74
22	6.3	48.9	451	292.0	287.0	1.5	11.7	6.5	3.8	8	98.8	74
23	6.9	49.7	525	292.0	287.6	1.3	12.9	7.2	3.8	8	98.8	74
24	7.3	51.5	724	292.0	287.6	0.5	13.9	6.7	3.4	8	98.8	75
25	7.2	51.7	703	292.0	287.6	0.5	13.7	5.6	3.2	8	98.8	75
26	7.2	51.2	690	292.0	287.7	0.5	13.6	6.3	3.4	8	98.8	75
27	7.1	50.9	659	292.0	287.7	0.5	13.4	6.6	3.7	8	98.8	75
28	6.6	50.9	529	292.0	287.7	0.5	12.4	6.4	4.3	8	98.8	75
29	6.1	49.2	402	292.0	288.3	0.8	11.3	5.4	5.7	8	98.8	75
30				292.0	289.1	1.5	10.9	6.1	6.6	8	98.8	73
31				292.0	289.2	1.5	10.8	6.4	6.9	8	98.8	73
32	5.7	47.8	333	292.0	289.2	1.5	10.4	5.9	5.1	8	98.8	73
33	5.5	46.4	293	292.0	289.2	1.5	9.7	4.0	5.3	8	98.8	73
34	5.4	46.2	279	292.0	289.2	1.5	9.5	4.7	5.2	8	98.8	73
35	5.4	46.5	286	292.0	289.2	1.4	9.6	5.9	5.0	8	98.8	73
36	5.5	46.5	297	292.0	289.2	0.5	9.8	5.1	5.0	8	98.8	73
37	5.5	46.7	301	292.0	289.2	0.5	9.9	5.4	4.5	8	98.8	73
38	5.4	46.3	285	292.0	289.2	0.5	9.7	5.3	4.1	8	98.8	73
39	5.3	45.8	272	292.0	289.2	0.5	9.4	6.0	3.9	8	98.8	73
40	5.3	45.9	259	292.0	289.2	0.5	9.2	5.8	3.9	8	98.8	73
41	5.3	45.5	272	292.0	289.2	0.7	9.4	6.4	4.1	8	98.8	73
42	5.5	46.0	299	292.0	289.7	1.5	9.9	6.2	3.9	8	98.8	73
43	5.6	46.7	309	292.0	290.2	1.5	10.0	5.3	3.8	8	98.8	74
44	5.4	46.5	286	292.0	290.3	1.5	9.8	6.0	4.3	8	98.8	74
45	5.2	46.0	245	292.0	290.3	1.5	9.0	4.1	3.4	8	98.8	74
46	5.1	45.1	234	292.0	290.3	1.5	8.8	5.0	4.2	8	98.8	74
47				292.0	290.3	1.5	9.3	5.6	5.5	8	98.8	74
48	5.5	46.0	296	292.0	290.3	0.5	9.8	5.5	4.8	8	98.8	72
49	5.7	46.5	331	292.0	290.3	0.5	10.4	5.4	5.2	8	98.8	72
50	6.1	47.7	399	292.0	290.3	0.5	11.3	6.3	5.5	8	98.8	72
51	6.2	48.7	441	292.0	290.2	0.5	11.7	5.3	4.9	8	98.8	72
52	6.3	49.0	448	292.0	289.8	0.5	11.7	5.6	4.4	8	98.8	72
53	6.1	50.4	399	292.0	286.2	0.6	11.3	4.9	5.1	8	98.8	72
54	5.7	48.0	341	292.0	285.0	1.5	10.6	5.6	5.0	8	98.8	72
55	5.5	47.1	299	292.0	285.0	1.5	9.8	4.8	5.2	8	98.8	72
56	5.3	46.2	267	292.0	285.0	1.5	9.3	3.5	4.9	8	98.8	72
57	5.3	46.2	260	292.0	285.0	1.5	9.3	3.4	4.8	8	98.8	72
58	5.3	46.4	266	292.0	286.2	1.5	9.4	3.8	4.7	8	98.8	72
59	5.5	47.3	290	292.0	288.3	1.5	9.7	5.3	4.6	8	98.8	72
60	5.7	47.5	327	292.0	288.7	0.6	10.3	6.0	4.0	8	98.8	74
61	6.0	47.9	386	292.0	288.7	0.5	11.2	6.4	4.5	8	98.8	74
62	6.1	49.2	419	292.0	288.7	0.5	11.5	6.4	4.7	8	98.8	74
63	5.9	49.4	376	292.0	289.5	0.5	11.1	4.7	5.0	8	98.8	74
64	5.8	48.3	344	292.0	291.9	0.5	10.7	5.4	5.6	8	98.8	74
65				292.0	293.0	0.5	10.2	4.2	6.1	8	98.8	74
66				292.0	293.0	1.4	9.5	3.4	5.8	8	98.8	71
67				292.0	293.0	1.5	9.3	5.5	5.6	8	98.8	70
68	5.3	46.4	262	292.0	293.0	1.5	9.2	4.7	5.1	8	98.8	70
69				292.0	293.0	1.5	9.0	4.7	5.4	8	98.8	70
70	5.1	45.5	228	292.0	293.0	1.5	8.7	4.2	4.5	8	98.8	70
71	4.9	45.5	205	292.0	293.0	1.5	8.2	3.9	4.3	8	98.8	70
72	4.8	45.6	184	292.0	293.0	1.0	8.0	3.7	4.6	8	98.8	71
73				292.0	293.0	0.5	8.2	4.2	5.0	8	98.8	71
74				292.0	293.0	0.5	8.4	4.2	5.2	8	98.8	72
75				292.0	293.0	0.5	8.4	4.0	5.5	8	98.8	72
76				292.0	293.0	0.5	8.4	4.3	5.2	8	98.8	72
77	5.1	45.6	228	292.0	292.8	0.5	8.7	3.8	4.1	8	98.8	73
78	5.2	45.6	253	292.0	290.8	1.4	9.2	4.1	3.9	8	98.8	73
79	5.4	46.5	287	292.0	288.3	1.5	9.7	5.0	4.5	8	98.8	73
80	5.6	46.9	311	292.0	287.7	1.5	10.1	4.6	3.7	8	98.8	73
81	5.8	47.6	348	292.0	287.7	1.5	10.9	5.1	3.2	8	98.8	73
82	5.5	48.1	295	292.0	287.8	1.5	9.9	5.8	3.8	8	98.8	73
83	5.6	47.1	310	292.0	289.4	1.5	10.1	5.9	4.3	8	98.8	73
84	5.7	47.3	328	292.0	290.7	0.9	10.4	5.2	4.6	8	98.8	73
85	5.5	47.4	305	292.0	290.8	0.5	10.0	5.1	4.8	8	98.8	73
86	5.4	47.1	292	292.0	290.8	0.5	9.6	5.3	4.4	8	98.8	73
87	5.4	46.9	288	292.0	290.8	0.5	9.6	5.8	4.7	8	98.8	73
88	5.5	47.4	300	292.0	290.8	0.5	9.8	5.3	5.2	8	98.8	73

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
89	5.5	47.4	305	292.0	290.8	0.5	10.0	4.8	5.1	8	98.8	73
90	5.5	47.0	301	292.0	290.8	1.3	9.9	4.7	5.0	8	98.8	72
91	5.6	47.1	307	292.0	290.8	1.5	10.0	4.9	4.6	8	98.8	71
92	5.4	46.6	290	292.0	290.8	1.5	9.8	4.3	4.3	8	98.8	71
93	5.3	46.4	264	292.0	290.8	1.5	9.3	5.2	2.9	8	98.8	71
94	5.0	45.6	213	292.0	292.4	1.5	8.5	4.1	3.7	8	98.8	71
95	4.7	45.3	175	292.0	295.0	1.5	8.0	4.4	4.2	8	98.8	71
96	4.7	44.8	178	292.0	296.3	1.0	8.0	4.8	4.6	8	98.8	73
97				292.0	296.3	0.5	7.9	3.8	5.1	8	98.8	74
98				292.0	296.3	0.5	8.0	4.7	5.9	8	98.8	74
99				292.0	296.3	0.5	8.3	4.3	6.0	8	98.8	74
100				292.0	296.3	0.5	9.0	6.5	5.7	8	98.8	74
101	5.7	46.1	326	292.0	296.3	0.5	10.3	6.7	5.0	8	98.8	74
102	6.0	47.2	386	292.0	296.4	1.2	11.1	5.6	5.6	8	98.8	72
103	6.2	48.4	426	292.0	296.4	1.5	11.5	4.7	5.3	8	98.8	72
104	6.2	48.4	435	292.0	296.3	1.5	11.6	5.2	6.0	8	98.8	72
105	6.1	48.5	419	292.0	296.1	1.5	11.4	5.2	5.0	8	98.8	72
106	5.9	47.5	367	292.0	293.8	1.5	10.9	5.7	4.4	8	98.8	72
107	5.8	47.1	346	292.0	293.7	1.5	10.7	5.4	4.2	8	98.8	72
108												

# Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 2 of 6  
 Created on: 10/11/2017

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Lid	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
177	7.3	51.0	706	292.0	303.5	1.5	13.8	8.8	5.3	8	98.8	71
178	7.7	53.2	839	292.0	305.5	1.5	14.8	7.5	5.5	8	98.8	71
179	7.7	53.6	837	292.0	303.5	1.5	14.8	7.8	4.4	8	98.8	71
180	7.7	53.2	834	292.0	303.6	1.5	14.8	7.8	4.5	8	98.8	73
181	7.5	53.2	792	292.0	303.6	0.8	14.4	8.0	4.6	8	98.8	73
182	7.4	52.3	740	292.0	304.3	0.5	14.0	7.9	4.7	8	98.8	73
183	7.4	52.1	752	292.0	306.8	0.5	14.2	8.6	4.7	8	98.8	73
184			846	292.0	309.0	0.5	14.9	7.3	5.4	8	98.8	73
185			1001	292.0	309.3	0.5	15.5	6.3	5.8	8	98.8	73
186			1147	292.0	308.7	0.5	15.5	6.5	5.6	8	98.8	71
187			1020	292.0	308.6	1.4	15.4	7.7	5.6	8	98.8	71
188			905	292.0	308.6	1.5	15.3	6.8	5.3	8	98.8	71
189			869	292.0	308.6	1.5	15.0	7.3	5.3	8	98.8	71
190			923	292.0	308.6	1.5	15.3	7.2	5.6	8	98.8	71
191			1006	292.0	308.6	1.5	15.5	6.8	4.9	8	98.8	71
192			1066	292.0	308.6	1.5	15.5	8.3	4.3	8	98.8	73
193			1130	292.0	308.5	0.9	15.4	7.6	4.8	8	98.8	73
194			910	292.0	308.4	0.5	15.3	8.6	5.1	8	98.8	73
195			926	292.0	308.4	0.5	15.4	8.8	6.3	8	98.8	73
196			906	292.0	308.4	0.5	15.3	5.9	6.4	8	98.8	73
197			869	292.0	308.4	0.5	15.0	7.3	5.3	8	98.8	73
198			875	292.0	308.4	0.5	15.0	7.3	5.8	8	98.8	72
199			854	292.0	308.5	1.3	14.9	6.7	7.0	8	98.8	71
200			793	292.0	308.4	1.5	14.4	5.4	6.7	8	98.8	71
201			722	292.0	308.4	1.5	13.9	6.3	6.4	8	98.8	71
202			652	292.0	307.9	1.5	13.3	5.7	7.1	8	98.8	71
203			637	292.0	307.9	1.5	13.2	6.2	6.3	8	98.8	71
204			662	292.0	307.5	1.5	13.4	6.0	6.0	8	98.8	70
205	7.1	51.7	656	292.0	305.9	1.0	13.3	7.9	5.7	8	98.8	70
206	7.2	51.6	704	292.0	305.7	0.5	13.7	7.7	5.5	8	98.8	70
207	7.6	52.8	807	292.0	305.7	0.5	14.7	7.5	5.5	8	98.8	70
208	7.9	53.4	915	292.0	305.7	0.5	15.3	7.4	5.7	8	98.8	70
209	7.9	54.1	921	292.0	305.6	0.5	15.4	6.9	4.9	8	98.8	70
210	7.7	53.3	833	292.0	305.6	0.5	14.7	6.9	5.9	8	98.8	72
211	7.2	52.2	689	292.0	305.5	1.2	13.7	6.4	6.5	8	98.8	72
212	7.0	51.6	630	292.0	305.5	1.5	13.2	6.5	5.6	8	98.8	72
213	6.8	51.6	586	292.0	305.5	1.5	12.8	6.9	5.7	8	98.8	72
214	6.9	51.1	608	292.0	305.5	1.5	13.0	6.2	6.5	8	98.8	72
215	7.1	51.8	641	292.0	305.5	1.5	13.3	6.1	5.9	8	98.8	72
216	7.0	52.7	628	292.0	305.6	1.5	13.1	7.2	7.0	8	98.8	71
217	7.1	51.7	665	292.0	305.5	1.1	13.4	7.4	6.9	8	98.8	71
218	7.1	51.1	649	292.0	305.5	0.5	13.3	7.4	6.5	8	98.8	71
219	6.7	50.8	557	292.0	305.5	0.5	12.6	6.8	5.7	8	98.8	71
220	6.4	47.1	471	292.0	305.5	0.5	12.0	5.9	6.1	8	98.8	73
221	6.2	48.7	424	292.0	305.5	0.5	11.5	5.3	5.9	8	98.8	71
222	6.3	48.4	455	292.0	305.5	0.5	11.8	6.2	5.9	8	98.8	71
223	6.5	49.2	506	292.0	305.5	1.1	12.3	6.6	6.9	8	98.8	71
224	6.5	49.5	507	292.0	305.5	1.5	12.3	6.1	6.1	8	98.8	71
225	6.5	49.7	496	292.0	305.5	1.5	12.2	6.0	6.4	8	98.8	71
226	6.6	49.5	528	292.0	305.5	1.5	12.4	5.0	4.7	8	98.8	71
227	6.6	50.1	541	292.0	304.8	1.5	12.5	5.2	4.4	8	98.8	71
228	6.6	50.2	519	292.0	304.6	1.5	12.3	5.2	4.7	8	98.8	72
229	6.2	49.5	435	292.0	303.6	1.2	11.6	5.9	5.8	8	98.8	73
230			361	292.0	303.5	0.5	10.8	4.7	7.0	8	98.8	73
231	5.9	47.6	366	292.0	303.5	0.5	11.0	5.9	6.5	8	98.8	73
232	6.3	48.6	457	292.0	303.5	0.5	11.8	5.9	6.1	8	98.8	73
233	6.3	48.1	448	292.0	303.5	0.5	11.7	5.9	5.9	8	98.8	73
234	6.3	48.8	456	292.0	303.5	0.5	11.8	5.5	5.9	8	98.8	71
235	6.9	49.8	597	292.0	303.5	1.0	12.9	5.9	5.9	9	98.8	70
236	7.2	51.5	691	292.0	303.5	1.5	13.6	6.4	6.3	9	98.8	70
237	7.0	51.6	633	292.0	303.5	1.5	13.1	6.6	5.3	9	98.8	70
238	6.4	50.4	489	292.0	303.4	1.5	12.1	5.7	5.5	9	98.8	70
239	6.3	49.7	466	292.0	303.5	1.5	12.0	6.3	4.8	9	98.8	70
240	6.6	50.1	525	292.0	303.7	1.5	12.4	6.1	6.0	9	98.8	70
241	6.7	50.5	546	292.0	303.7	1.3	12.5	6.1	6.1	9	98.8	71
242	6.8	50.4	581	292.0	303.7	0.5	12.8	6.1	6.3	9	98.8	71
243	7.0	50.8	637	292.0	303.7	0.5	13.2	6.3	5.2	9	98.8	71
244	6.9	50.3	608	292.0	303.6	0.5	13.0	6.6	5.4	9	98.8	71
245	6.7	50.2	542	292.0	303.6	0.5	12.5	6.7	5.5	9	98.8	71
246	6.7	51.0	547	292.0	303.6	0.5	12.5	7.2	5.3	9	98.8	71
247	6.8	50.7	572	292.0	304.7	0.9	12.8	6.5	5.4	9	98.8	71
248			648	292.0	307.3	1.5	13.3	8.4	5.7	9	98.8	71
249			638	292.0	310.0	0.5	13.7	8.7	5.9	9	98.8	71
250			616	292.0	313.6	1.5	13.1	7.5	5.3	9	98.8	71
251			541	292.0	314.2	1.5	12.5	6.7	4.6	9	98.8	71
252			479	292.0	314.2	1.5	12.0	5.6	4.6	9	98.8	72
253			425	292.0	314.2	1.5	11.5	4.5	4.5	9	98.8	72
254			366	292.0	314.2	0.5	11.1	4.3	4.7	9	98.8	72
255			354	292.0	314.2	0.5	10.8	5.8	4.9	9	98.8	72
256			320	292.0	314.2	0.5	10.2	4.2	5.5	9	98.8	72
257			287	292.0	314.2	0.5	9.7	4.2	5.9	9	98.8	72
258			274	292.0	314.2	0.5	9.5	3.9	6.7	9	98.8	71
259			278	292.0	313.7	0.7	9.6	3.6	6.1	9	98.8	71
260			309	292.0	312.0	1.5	10.1	4.7	5.9	9	98.8	71
261			342	292.0	311.9	1.5	10.6	5.1	7.2	9	98.8	71
262			336	292.0	311.6	1.5	10.6	6.4	6.4	9	98.8	71
263			343	292.0	310.1	1.5	10.6	5.5	6.5	9	98.8	71
264			344	292.0	309.9	1.5	10.6	5.3	6.3	9	98.8	69

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Lid	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
265			407	292.0	309.9	1.5	11.4	4.3	6.6	9	98.8	69
266			452	292.0	309.9	0.5	11.7	6.7	6.1	9	98.8	69
267			479	292.0	309.9	0.5	12.0	6.3	6.0	9	98.8	69
268			477	292.0	309.9	0.5	12.0	5.1	5.2	9	98.8	69
269	6.9	51.0	594	292.0	304.4	0.7	13.0	6.6	4.3	8	98.8	73
270	6.8	51.2	580	292.0	304.4	0.5	12.9	6.0	4.1	8	98.8	73
271	6.8	50.6	576	292.0	304.4	0.5	12.8	6.3	4.2	8	98.8	73
272	6.8	50.3	568	292.0	304.3	0.5	12.8	5.3	4.4	8	98.8	73
273	6.7	50.7	553	292.0	302.2	0.5	12.7	4.3	3.9	8	98.8	73
274	6.8	50.6	568	292.0	300.1	0.5	12.8	5.0	3.4	8	98.8	74
275	7.0	51.3	622	292.0	299.6	1.4	13.2	5.4	3.5	8	98.8	74
276	7.0	52.3	632	292.0	297.5	1.5	13.3	5.6	4.3	8	98.8	74
277	6.9	51.8	609	292.0	296.2	1.5	13.1	7.3	4.5	8	98.8	74
278	6.8	51.2	567	292.0	294.9	1.5	12.8	6.8	4.3	8	98.8	74
279	6.6	50.8	539	292.0	294.9	1.5	12.5	6.4	4.6	8	98.8	74
280	6.6	51.1	536	292.0	294.9	1.5	12.5	7.1	4.3	8	98.8	72
281	6.7	50.9	544	292.0	294.9	0.9	12.6	6.0	4.6	8	98.8	72
282	6.8	50.4	571	292.0	294.9	0.5	12.8	6.4	4.2	8	98.8	72
283	7.0	50.9	629	292.0	294.9	0.5	13.2	5.2	4.0			

# Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 3 of 6  
 Created on: 10/11/2017

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
353	4.6	46.1	167	292.0	303.1	1.4	7.9	3.4	4.8	8	98.8	73
354	4.2	46.0	119	292.0	302.0	1.5	7.5	4.0	4.4	8	98.8	73
355			73	292.0	301.6	0.5	7.3	3.6	4.7	8	98.8	73
356			110	292.0	302.5	0.5	7.4	4.1	5.2	8	98.8	73
357			151	292.0	302.8	0.5	7.7	4.4	5.1	8	98.8	73
358	4.7	46.8	181	292.0	302.9	0.5	8.0	5.2	5.0	8	98.8	72
359	5.0	46.1	208	292.0	302.8	0.7	8.3	4.8	4.6	8	98.8	71
360	5.2	46.5	245	292.0	302.8	1.5	8.9	5.0	4.3	8	98.8	71
361	5.4	46.9	274	292.0	302.8	1.5	9.5	5.2	2.9	8	98.8	71
362	5.5	47.7	301	292.0	302.0	1.5	10.1	4.6	3.7	8	98.8	71
363	5.5	48.2	306	292.0	300.0	1.5	10.2	5.4	4.5	8	98.8	71
364	5.6	48.5	317	292.0	299.8	1.5	10.2	4.9	4.6	8	98.8	73
365	5.6	48.2	320	292.0	299.8	1.5	10.3	3.5	2.9	8	98.8	74
366	5.5	49.1	302	292.0	298.4	0.5	10.0	3.9	5.9	8	98.8	74
367			270	292.0	295.9	0.5	9.5	4.0	6.0	8	98.8	74
368	5.2	48.3	238	292.0	293.4	0.5	9.0	4.0	5.7	8	98.8	74
369	5.0	47.5	207	292.0	289.7	0.5	8.5	3.7	5.0	8	98.8	74
370	4.8	46.9	192	292.0	289.1	0.5	8.3	3.8	5.6	8	98.8	72
371			166	292.0	289.9	0.5	7.9	3.9	5.3	8	98.8	72
372			149	292.0	280.2	1.5	7.7	4.1	6.0	8	98.8	72
373			132	292.0	280.7	1.5	7.6	4.7	5.0	8	98.8	72
374	4.6	46.2	161	292.0	282.9	1.5	7.9	4.4	4.4	8	98.8	72
375	4.9	46.9	209	292.0	285.4	1.5	8.4	5.2	4.2	8	98.8	72
376	5.0	46.6	212	292.0	289.5	1.5	8.5	5.0	4.3	8	98.8	72
377	4.9	46.4	202	292.0	292.4	1.5	8.2	3.8	4.1	8	98.8	72
378			154	292.0	292.5	0.7	7.8	3.6	6.0	8	98.8	72
379			139	292.0	292.4	0.5	7.6	4.1	6.9	8	98.8	72
380			141	292.0	292.4	0.5	7.6	4.3	6.6	8	98.8	72
381			154	292.0	292.4	0.5	7.7	4.2	6.0	8	98.8	72
382			143	292.0	292.4	0.5	7.7	3.7	5.4	8	98.8	72
383			127	292.0	292.4	0.5	7.5	2.6	6.9	8	98.8	72
384	4.4	46.0	147	292.0	291.9	1.4	7.7	2.7	4.7	8	98.8	72
385	4.7	46.4	172	292.0	289.6	1.5	8.0	3.5	4.8	8	98.8	72
386	4.8	46.5	184	292.0	287.1	1.5	8.1	3.7	5.0	8	98.8	72
387	5.1	46.9	223	292.0	287.5	1.5	8.5	4.2	4.1	8	98.8	72
388	5.3	47.0	266	292.0	286.4	1.5	9.3	4.8	5.3	8	98.8	72
389	5.6	47.7	309	292.0	284.8	1.5	10.2	3.7	5.8	8	98.8	72
390	5.9	48.1	360	292.0	282.4	0.8	11.0	4.8	5.6	8	98.8	72
391	6.0	48.8	377	292.0	279.7	0.5	11.2	5.7	5.3	8	98.8	72
392			365	292.0	276.6	0.5	11.1	5.4	5.3	8	98.8	72
393			343	292.0	276.2	0.5	10.7	4.0	5.8	8	98.8	72
394	7.6	53.3	807	264.0	255.3	0.5	14.6	5.9	5.1	12	98.8	56
395	7.4	52.8	753	264.0	255.0	0.5	14.2	7.1	4.6	12	98.8	56
396	7.4	52.8	748	264.0	255.0	0.5	14.2	7.5	4.5	12	98.8	56
397	7.4	52.5	759	264.0	255.0	0.5	14.3	5.0	5.0	12	98.8	56
398	7.5	52.8	786	264.0	255.0	0.5	14.4	8.1	5.8	12	98.8	56
399	7.7	53.4	855	264.0	255.0	1.1	15.0	8.9	3.3	12	98.8	56
400	8.4	54.4	1117	264.0	255.0	1.5	15.6	8.9	3.4	12	98.8	56
401	8.4	55.1	1109	264.0	255.0	1.5	15.4	8.8	4.9	12	98.8	57
402	7.9	54.1	911	264.0	255.0	1.5	15.2	6.6	6.5	12	98.8	57
403	7.6	53.5	825	264.0	255.0	1.5	14.7	6.2	6.4	12	98.8	57
404	7.4	53.5	753	264.0	255.0	1.5	14.2	7.8	5.5	12	98.8	57
405	7.3	52.7	730	264.0	255.0	1.2	14.0	6.9	5.2	12	98.8	57
406	7.5	52.4	780	264.0	255.0	0.5	14.4	7.3	5.0	12	98.8	57
407	8.8	54.0	1250	264.0	255.0	0.3	15.7	7.8	5.0	12	98.8	57
408	9.7	55.4	1643	264.0	254.5	0.5	15.6	9.2	5.2	12	98.8	57
409	9.3	54.8	1479	264.0	252.9	0.5	15.3	10.0	5.0	12	98.8	57
410	9.2	54.4	1452	264.0	252.7	0.5	15.4	10.1	5.3	12	98.8	57
411	9.5	55.2	1573	264.0	252.7	1.0	15.5	9.3	7.2	12	98.8	57
412	9.7	55.9	1672	264.0	252.7	1.5	15.5	6.6	6.6	12	98.8	57
413	9.6	55.4	1626	264.0	252.8	1.5	15.4	10.3	6.6	12	98.8	55
414	9.3	55.0	1481	264.0	252.7	1.5	15.4	10.1	6.4	12	98.8	55
415	9.2	55.1	1421	264.0	252.7	1.5	15.4	9.6	7.1	12	98.8	55
416	9.2	55.4	1417	264.0	252.7	1.5	15.4	10.1	7.4	12	98.8	55
417	9.0	55.6	1333	264.0	252.7	1.3	15.4	10.4	6.9	12	98.8	55
418	8.3	54.6	1046	264.0	252.7	0.5	15.2	8.9	5.8	12	98.8	55
419	8.5	54.5	1146	264.0	252.7	0.5	15.5	7.9	6.1	12	98.8	56
420	9.0	55.3	1360	264.0	252.7	0.5	15.5	9.3	7.0	12	98.8	56
421	8.2	54.3	1015	264.0	252.7	0.5	15.2	8.5	7.4	12	98.8	56
422	8.4	54.5	1098	264.0	252.7	0.5	15.5	9.0	7.5	12	98.8	56
423	8.9	55.1	1300	264.0	252.7	0.8	15.5	9.6	7.4	12	98.8	56
424	8.9	55.2	1317	264.0	252.7	1.5	15.4	8.8	6.2	12	98.8	56
425	8.8	55.0	1289	264.0	252.7	1.5	15.4	7.9	6.9	12	98.8	57
426	8.7	54.9	1227	264.0	252.7	1.5	15.4	8.0	5.8	12	98.8	57
427	8.5	55.1	1151	264.0	252.7	1.5	15.4	8.2	6.1	12	98.8	57
428	8.5	55.2	1128	264.0	252.6	1.5	15.4	8.7	5.3	12	98.8	57
429	9.0	56.0	1421	264.0	252.5	1.5	15.7	8.5	7.0	12	98.8	57
430	8.7	55.1	1211	264.0	252.5	0.5	15.2	9.8	5.9	12	98.8	57
431	8.9	54.7	1285	264.0	252.5	0.5	15.6	10.2	6.3	12	98.8	57
432	8.8	55.0	1279	264.0	252.5	0.5	15.4	9.0	6.2	12	98.8	57
433	9.3	1049	1845	264.0	252.5	0.5	15.3	7.7	6.7	12	98.8	57
434	8.3	55.1	1052	264.0	252.5	0.5	15.4	7.8	6.8	12	98.8	57
435	8.0	54.6	939	264.0	252.5	0.7	15.3	7.9	5.8	12	98.8	57
436	7.8	54.2	871	264.0	252.5	1.5	15.1	8.4	5.6	12	98.8	57
437	8.2	54.6	1034	264.0	252.5	1.5	15.5	9.0	7.0	12	98.8	58
438	9.0	54.9	1349	264.0	252.5	1.5	15.6	9.3	6.4	12	98.8	58
439	8.6	55.3	1191	264.0	252.6	1.5	15.3	8.2	5.6	12	98.8	58
440	8.2	54.5	1007	264.0	253.7	1.5	15.4	8.9	5.8	12	98.8	58

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
441	9.2	55.2	1424	264.0	256.3	1.4	15.7	9.9	6.4	12	98.8	58
442	9.5	55.3	1560	264.0	257.6	0.5	15.4	9.9	6.5	12	98.8	58
443	9.5	54.9	1592	264.0	257.7	0.5	15.5	10.6	6.4	12	98.8	58
444	10.0	56.0	1812	264.0	257.8	0.5	15.5	10.9	5.4	12	98.8	58
445	9.5	56.1	1592	264.0	257.8	0.5	15.2	10.7	6.8	12	98.8	58
446	8.7	54.6	1226	264.0	257.8	0.5	15.2	10.1	7.9	12	98.8	58
447	8.4	54.3	1089	264.0	257.8	0.5	15.3	9.0	7.6	12	98.8	58
448	8.1	54.5	1001	264.0	257.8	1.5	15.4	8.3	6.5	12	98.8	58
449	8.3	54.9	1069	264.0	257.8	1.5	15.5	7.5	6.5	12	98.8	58
450	9.0	55.0	1352	264.0	257.8	1.5	15.7	8.2	6.6	12	98.8	58
451	8.9	55.2	1291	264.0	257.8	1.5	15.3	8.6	8.1	12	98.8	58
452	8.0	54.4	954	264.0	257.8	1.5	15.2	7.4	8.5	12	98.8	58
453	7.9	54.2	905	264.0	257.8	1.5	15.3	7.9	8.5	12	98.8	58
454	7.6	53.9	822	264.0	257.8	0.6	14.7	7.0	7.5	12	98.8	58
455	7.3	52.5	728	264.0	257.8	0.5	14.0	6.1	7.0	12	98.8	58
456	7.2	52.2	694	264.0	257.7	0.5	13.7	7.0	6.4	1		

# Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 4 of 6  
 Created on: 10/11/2017

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
529	6.8	50.8	577	264.0	262.5	0.5	12.8	5.6	6.1	12	98.9	60
530	6.7	50.6	562	264.0	262.5	0.5	12.7	6.0	5.9	12	98.9	60
531	6.6	50.3	538	264.0	262.5	0.5	12.5	7.0	6.0	12	98.9	60
532	6.5	50.2	511	264.0	262.5	0.5	12.3	6.3	5.5	12	98.9	60
533	6.6	49.9	523	264.0	262.5	1.5	12.4	6.3	4.9	12	98.9	61
534	6.4	49.8	473	264.0	262.5	1.5	12.0	6.5	4.5	12	98.9	61
535	6.3	49.5	455	264.0	262.5	1.5	11.8	6.5	4.4	12	98.9	61
536	6.4	49.7	484	264.0	262.5	1.5	12.1	7.0	4.6	12	98.9	61
537	6.9	50.6	607	264.0	262.5	1.5	13.0	7.2	4.9	12	98.9	61
538	7.1	68.8	688	264.0	262.5	0.3	13.5	6.8	4.8	12	98.9	61
539	6.8	50.9	582	264.0	262.5	0.5	12.8	6.5	5.1	12	98.9	61
540	6.7	50.3	543	264.0	262.5	0.5	12.6	7.1	4.5	12	98.9	61
541	6.8	50.5	576	264.0	262.5	0.5	12.8	6.8	4.8	12	98.9	61
542	6.9	50.7	608	264.0	262.5	0.5	13.0	7.3	5.0	12	98.9	61
543	6.8	50.3	573	264.0	262.5	0.5	12.8	5.8	4.7	12	98.9	61
544	6.7	50.2	550	264.0	262.5	0.8	12.7	5.6	4.3	12	98.9	61
545	6.6	50.1	539	264.0	262.5	1.5	12.5	5.9	4.4	12	98.9	61
546	6.6	49.8	539	264.0	262.5	1.5	12.5	6.9	5.0	12	98.9	61
547	6.8	50.3	584	264.0	262.7	1.5	12.9	6.8	5.9	12	98.9	61
548	7.1	50.9	648	264.0	263.0	1.5	13.4	7.0	5.4	12	98.9	61
549	7.3	51.6	704	264.0	263.1	1.5	13.8	7.5	5.5	12	98.9	61
550	7.3	52.0	723	264.0	263.1	1.4	14.0	6.9	5.2	12	98.9	61
551	7.1	49.8	659	264.0	262.5	0.5	13.5	6.8	5.0	12	98.9	61
552	6.9	51.0	601	264.0	263.1	0.5	13.0	5.7	4.3	12	98.9	61
553	6.6	50.6	519	264.0	263.0	0.5	12.9	5.9	4.4	12	98.9	61
554	6.3	49.7	466	264.0	262.6	0.5	11.9	5.9	4.8	12	98.9	61
555	6.2	49.0	420	264.0	262.5	0.5	11.6	5.8	5.2	12	98.9	61
556	6.1	48.8	404	264.0	262.6	0.7	11.4	6.2	5.1	12	98.9	61
557	6.4	49.2	485	264.0	264.0	1.5	12.1	7.1	5.8	12	98.9	61
558	6.7	50.2	552	264.0	266.0	1.5	12.7	6.3	6.0	12	98.9	62
559	6.6	50.6	537	264.0	266.3	1.5	12.5	5.5	6.5	12	98.9	62
560	6.5	50.2	505	264.0	266.3	1.5	12.3	6.5	6.5	12	98.9	62
561	6.5	50.1	513	264.0	266.3	1.5	12.3	6.6	6.5	12	98.9	62
562	6.7	50.3	562	264.0	266.3	1.5	12.7	7.6	5.2	12	98.9	62
563	6.9	50.8	605	264.0	266.3	0.5	13.0	7.6	4.7	12	98.9	62
564	6.9	50.9	610	264.0	266.3	0.5	13.1	7.6	4.9	12	98.9	61
565	6.9	50.9	611	264.0	266.3	0.5	13.1	7.4	4.8	12	98.9	61
566	6.8	50.9	582	264.0	267.1	0.5	12.9	7.0	5.4	12	98.9	61
567	6.8	50.5	568	264.0	266.5	0.5	12.8	7.3	5.0	12	98.9	61
568	6.9	51.1	611	264.0	266.5	0.6	13.1	7.4	5.0	12	98.9	61
569	7.0	51.1	634	264.0	268.5	1.5	13.3	8.0	5.0	12	98.9	61
570	7.0	51.4	632	264.0	268.5	1.5	13.2	6.9	4.7	12	98.9	61
571	7.1	51.4	601	264.0	268.5	1.5	13.0	6.4	4.7	12	98.9	61
572	6.9	51.1	609	264.0	268.5	1.5	13.1	7.1	4.5	12	98.9	61
573	7.0	51.2	622	264.0	268.5	1.5	13.1	7.2	4.2	12	98.9	61
574	6.9	51.0	597	264.0	268.5	1.5	13.0	6.5	4.5	12	98.9	61
575	6.6	50.6	537	264.0	268.5	0.6	12.5	6.2	4.4	12	98.9	61
576	6.3	49.4	456	264.0	268.5	0.5	11.8	4.7	4.7	12	98.9	61
577	6.1	49.5	400	264.0	268.5	0.5	11.3	5.8	4.6	12	98.9	61
578	5.8	48.4	356	264.0	269.7	0.5	10.9	5.4	4.9	12	98.9	61
579	5.7	48.1	331	264.0	271.6	0.5	10.5	4.3	5.5	12	98.9	61
580	5.5	47.5	304	264.0	271.8	0.5	10.0	5.4	5.7	12	98.9	61
581	5.5	47.0	298	264.0	271.8	1.4	9.9	6.1	5.4	12	98.9	61
582	5.5	48.0	304	264.0	271.8	1.5	10.1	6.0	5.3	12	98.9	61
583	5.6	47.6	323	264.0	271.8	1.5	10.3	5.5	5.6	12	98.9	61
584	5.7	47.6	339	264.0	271.8	1.5	10.6	5.7	5.3	12	98.9	61
585	5.8	47.9	350	264.0	271.8	1.5	10.8	6.1	5.7	12	98.9	61
586	5.8	47.7	349	264.0	271.8	1.5	10.7	5.2	5.3	12	98.9	61
587	5.7	47.5	329	264.0	271.8	0.7	10.4	3.9	5.0	12	98.9	60
588	5.5	47.5	307	264.0	271.8	0.5	10.0	6.3	4.3	12	98.9	60
589	5.5	47.2	290	264.0	271.8	0.5	9.8	5.7	3.7	12	98.9	60
590	5.3	46.9	268	264.0	271.8	0.5	9.4	4.4	3.9	12	98.9	60
591	5.2	46.4	244	264.0	271.8	0.5	9.1	4.3	3.9	12	98.9	60
592	5.3	46.6	255	264.0	271.8	0.5	9.2	4.6	4.2	12	98.9	60
593	5.4	46.4	275	264.0	271.7	1.4	9.6	4.9	4.1	12	98.9	61
594	5.5	47.4	302	264.0	271.4	1.5	10.0	5.8	4.6	12	98.9	61
595	5.5	47.4	307	264.0	271.3	1.5	10.0	5.8	4.4	12	98.9	61
596	5.6	47.8	310	264.0	271.3	1.5	10.1	4.6	4.0	12	98.9	61
597	5.7	48.0	340	264.0	271.8	1.5	10.6	5.2	4.5	12	98.9	61
598	6.0	48.2	382	264.0	271.3	1.5	11.2	6.3	5.0	12	98.9	61
599	6.0	48.6	378	264.0	271.3	0.9	11.2	5.4	4.6	12	98.9	61
600	5.8	48.2	355	264.0	271.3	0.5	10.8	5.3	4.4	12	98.9	61
601	5.8	48.1	347	264.0	271.3	0.5	10.7	4.6	4.4	12	98.9	61
602	5.6	47.8	316	264.0	271.3	0.5	10.2	4.9	3.9	12	98.9	61
603	5.4	47.4	276	264.0	271.3	0.5	9.5	5.2	3.8	12	98.9	61
604	5.2	47.1	248	264.0	271.4	0.5	9.1	5.2	4.1	12	98.9	61
605	5.5	48.2	298	264.0	271.8	1.5	10.2	5.3	4.3	12	98.9	61
606	11.9	57.7	2238	245.0	238.8	1.4	15.7	11.1	8.1	13	98.8	67
607	10.8	57.5	2233	245.0	238.8	2.1	15.6	10.1	7.8	13	98.8	67
608	11.4	57.2	2221	245.0	238.1	1.7	15.5	8.7	8.7	13	98.8	67
609	11.2	57.2	2172	245.0	238.2	1.0	15.2	10.6	6.9	13	98.8	67
610	9.1	55.6	1387	245.0	235.9	1.5	14.7	7.2	6.1	13	98.8	66
611	9.3	55.4	1479	245.0	234.3	1.5	15.5	8.0	6.1	13	98.8	66
612	10.0	56.0	1781	245.0	233.1	1.4	15.7	10.7	6.6	13	98.8	66
613	10.5	56.7	2172	245.0	233.0	0.9	15.7	9.8	7.1	13	98.8	66
614	12.5	56.6	2230	245.0	232.9	3.3	15.8	11.7	7.4	13	98.8	66
615	13.0	56.2	2227	245.0	232.9	3.7	15.5	12.2	7.6	13	98.8	67
616	12.5	56.9	2178	245.0	232.9	0.9	15.2	11.7	8.2	13	98.8	67

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
617	10.1	56.7	1848	245.0	232.9	1.4	15.1	9.4	7.1	13	98.8	67
618	12.3	57.4	2223	245.0	232.9	2.6	15.8	11.5	6.9	13	98.8	67
619	11.1	56.8	2225	245.0	232.9	1.0	15.5	10.4	7.8	13	98.8	67
620	12.2	57.3	2231	245.0	232.9	5.1	15.9	11.5	7.0	13	98.8	67
621	14.4	56.6	2224	245.0	232.9	6.3	15.5	13.5	5.9	13	98.8	67
622	14.2	57.3	2214	245.0	232.9	7.6	15.5	13.3	6.3	13	98.8	67
623	12.6	58.3	2231	245.0	232.9	6.8	15.5	11.8	6.3	13	98.8	67
624	14.3	56.9	2211	245.0	232.9	5.9	15.3	13.4	6.3	13	98.8	67
625	11.2	57.7	2225	245.0	232.9	2.7	15.5	10.5	6.7	13	98.8	67
626	12.6	57.0	2225	245.0	232.9	4.7	15.6	11.8	5.9	13	98.8	67
627	11.8	57.0	2207	245.0	232.9	2.2	15.3	11.1	7.1	13	98.8	68
628	10.2	58.5	1875	245.0	232.9	1.3	14.8	10.9	9.8	13	98.8	68
629	10.2	57.1	1894	245.0	232.9	1.4	15.4	8.7	8.0	13	98.8	68
630	11.5	56.6	2014	245.0	232.8	1.2	15.4	10.8	9.0	13	98.8	68</

# Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 5 of 6  
 Created on: 10/11/2017

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
705	12.7	58.3	2223	245.0	232.2	4.0	15.4	11.9	9.2	13	98.8	68
706	13.1	58.5	2221	245.0	232.0	3.4	15.7	12.2	11.4	13	98.8	68
707	13.3	56.5	2235	245.0	232.2	5.8	15.6	12.5	9.4	13	98.8	68
708	14.8	56.8	2224	245.0	232.2	7.7	15.6	13.9	9.4	13	98.8	68
709	15.7	56.8	2227	245.0	232.2	9.6	15.6	14.7	10.7	13	98.8	68
710	15.8	56.4	2214	245.0	232.2	7.7	15.4	14.8	10.1	13	98.8	68
711	14.1	57.3	2209	245.0	232.2	6.4	15.3	13.2	9.3	13	98.8	68
712	13.4	58.4	2225	245.0	232.2	3.7	15.5	12.5	7.9	13	98.8	68
713	12.8	58.4	2230	245.0	233.3	1.6	15.5	11.9	8.6	13	98.8	68
714	11.4	57.5	2235	245.0	234.0	3.4	15.6	10.7	7.5	13	98.8	68
715	12.7	57.1	2223	245.0	234.0	3.9	15.5	11.9	7.8	13	98.8	68
716	12.2	56.5	2213	245.0	234.0	3.0	15.3	11.5	8.5	13	98.8	68
717	12.0	56.4	2019	245.0	234.1	1.2	14.9	11.2	9.5	13	98.8	68
718	11.8	57.0	1944	245.0	234.1	1.2	15.4	8.7	10.0	13	98.8	68
719	11.0	57.3	2222	245.0	234.1	2.6	15.8	10.3	9.2	13	98.8	67
720	12.0	57.0	2225	245.0	234.1	3.1	15.7	11.3	9.4	13	98.8	67
721	12.0	56.5	2215	245.0	234.1	2.5	15.3	11.2	9.1	13	98.8	67
722	10.2	56.5	1882	245.0	234.1	1.4	14.9	9.1	8.2	13	98.8	67
723	10.2	56.3	1885	245.0	234.1	1.5	15.4	10.0	9.7	13	98.8	67
724	12.9	57.3	2194	245.0	234.1	0.9	15.5	12.1	9.4	13	98.8	67
725	13.3	57.6	2077	245.0	234.1	1.1	15.5	12.5	8.6	13	98.8	67
726	12.4	57.4	2237	245.0	234.1	1.5	15.6	11.6	7.8	13	98.8	67
727	11.8	57.0	2189	245.0	234.1	1.0	15.4	11.1	8.4	13	98.8	67
728	11.8	56.9	2051	245.0	234.1	1.2	15.2	11.0	8.3	13	98.8	67
729	10.3	56.9	2039	245.0	234.1	1.2	15.3	9.7	11.9	13	98.8	67
730	12.5	57.6	2198	245.0	234.1	1.0	15.6	11.7	11.3	13	98.8	67
731	13.1	57.0	2180	245.0	234.0	1.0	15.2	12.2	9.7	13	98.8	67
732	11.7	56.3	2235	245.0	234.1	2.4	15.6	11.0	9.8	13	98.8	67
733	13.8	56.5	2229	245.0	234.2	2.9	15.5	12.9	9.2	13	98.8	67
734	11.5	56.7	2015	245.0	236.8	1.2	15.0	10.8	8.4	13	98.8	67
735	9.3	55.7	1504	245.0	236.8	1.5	15.0	10.6	8.5	13	98.8	67
736	9.0	55.7	1363	245.0	239.2	1.4	15.3	8.1	5.7	13	98.8	67
737			1971	245.0	239.2	1.0	15.8	9.1	6.9	13	98.8	68
738			2063	245.0	239.0	1.1	15.4	9.5	8.0	13	98.8	68
739	11.0	56.6	1800	245.0	237.5	3.5	15.3	10.3	8.4	13	98.8	67
740	10.0	56.2	1821	245.0	237.3	1.4	15.4	11.1	9.7	13	98.8	68
741	13.4	56.6	2221	245.0	237.3	1.1	15.9	12.5	9.3	13	98.8	68
742	13.2	56.5	2186	245.0	237.3	0.9	15.4	12.3	7.3	13	98.8	68
743	9.1	55.8	1381	245.0	237.3	1.5	14.8	10.2	8.1	13	98.8	68
744	9.1	55.4	1389	245.0	237.4	1.5	15.4	10.1	7.8	13	98.8	68
745	11.9	56.1	1941	245.0	237.4	1.0	15.8	11.2	6.2	13	98.8	68
746	9.7	56.4	1688	245.0	237.4	1.4	15.1	10.5	6.1	13	98.8	68
747	9.2	55.7	1441	245.0	237.4	1.5	15.3	9.6	8.6	13	98.8	68
748	9.0	56.3	1382	245.0	236.8	1.5	15.2	7.9	8.9	13	98.8	68
749	8.5	57.0	1145	245.0	241.1	1.5	15.2	6.6	7.1	13	98.8	67
750	9.1	55.8	1379	245.0	241.6	1.1	15.7	8.4	9.5	13	98.8	68
751			2033	245.0	241.6	0.6	15.8	9.5	11.3	13	98.8	68
752	11.3	56.9	2033	245.0	241.7	1.1	15.3	10.5	10.5	13	98.8	68
753	10.2	56.6	1896	245.0	241.7	1.3	15.2	10.4	12.0	13	98.8	68
754	9.2	56.3	1448	245.0	241.7	1.5	15.1	8.3	11.5	13	98.8	68
755	9.5	56.7	1572	245.0	241.8	1.5	15.5	10.3	10.5	13	98.8	65
756	9.7	57.9	1688	245.0	241.8	1.4	15.5	9.3	11.6	13	98.8	65
757	9.8	57.4	1726	245.0	241.8	1.5	15.5	7.8	10.0	13	98.8	65
758	11.0	56.9	1974	245.0	241.8	1.1	15.5	10.3	10.5	13	98.8	65
759	10.6	56.9	2022	245.0	241.8	0.3	15.5	9.9	8.0	13	98.8	65
760	11.8	57.0	2229	245.0	241.8	0.1	15.7	11.0	9.8	13	98.8	65
761	13.0	57.1	2231	245.0	241.8	0.4	15.5	12.2	9.4	13	98.8	66
762	11.3	57.2	2208	245.0	241.8	0.4	15.5	10.6	8.1	13	98.8	66
763	11.0	56.6	2216	245.0	241.8	2.4	15.6	10.3	7.3	13	98.8	66
764	11.9	56.8	2221	245.0	241.8	4.5	15.7	11.1	10.2	13	98.8	66
765	10.9	57.1	2218	245.0	241.8	4.5	15.5	10.2	9.9	13	98.8	66
766			2228	245.0	240.6	0.9	15.6	9.6	8.3	13	98.8	66
767			1882	245.0	203.3	2.1	13.1	8.8	11.4	13	98.8	65
768			2224	245.0	238.5	0.9	15.4	11.3	9.9	13	98.8	65
769			2215	245.0	238.3	1.0	15.3	10.5	10.0	13	98.8	65
770			2215	245.0	238.3	1.0	15.3	10.5	9.7	13	98.8	65
771			2215	245.0	238.3	1.0	15.3	10.5	8.9	13	98.8	65
772			2188	245.0	238.3	1.0	15.3	10.7	10.0	13	98.8	65
773			1988	245.0	238.1	1.2	15.4	11.8	9.5	13	98.8	65
774			2046	245.0	238.1	1.1	15.4	11.1	10.4	13	98.8	65
775	10.8	56.5	1944	245.0	238.1	1.3	15.5	10.1	10.9	13	98.8	65
776	10.0	56.5	1790	245.0	238.1	1.4	15.3	9.8	10.9	13	98.8	65
777	10.0	56.3	1791	245.0	238.1	1.4	15.5	10.5	10.5	13	98.8	65
778	9.7	56.9	1685	245.0	238.1	1.5	15.2	10.4	8.9	13	98.8	65
779	8.2	55.2	1014	245.0	238.2	1.4	15.0	5.9	8.4	13	98.8	65
780	10.5	56.2	2111	245.0	238.2	5.1	16.1	9.8	8.4	13	98.8	65
781	11.9	56.8	2216	245.0	238.2	7.6	15.6	11.2	10.2	13	98.8	65
782	12.0	57.4	2230	245.0	237.1	4.6	15.5	11.2	9.6	13	98.8	65
783	12.9	56.6	2233	245.0	235.0	2.9	15.6	12.0	7.5	13	98.8	65
784	13.0	56.9	2222	245.0	234.8	2.6	15.6	12.2	7.5	13	98.8	65
785	12.5	57.4	2219	245.0	234.7	1.5	15.4	11.7	11.7	13	98.8	65
786	11.0	57.5	2213	245.0	234.7	0.8	15.3	10.3	9.8	13	98.8	65
787	11.9	57.2	2106	245.0	234.7	1.1	15.1	11.1	8.7	13	98.8	65
788	12.3	57.0	2179	245.0	234.7	1.0	15.4	11.6	9.5	13	98.8	65
789	14.0	56.9	2222	245.0	234.7	7.3	16.0	13.1	13.1	13	98.8	65
790	15.1	57.0	2204	245.0	234.7	6.6	15.4	14.2	14.2	13	98.8	65
791	12.2	56.7	2231	245.0	234.7	5.1	15.5	11.4	9.3	13	98.8	65
792	11.6	56.4	2229	245.0	234.7	3.7	15.5	10.8	8.6	13	98.8	65

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
794			2234	245.0	233.9	4.2	15.7	9.5	7.7	13	98.8	65
795	12.0	57.1	2213	245.0	234.0	1.2	15.4	11.2	9.2	13	98.8	65
796	11.7	56.6	2223	245.0	233.7	3.6	15.4	11.0	5.8	13	98.8	65
797	11.7	57.2	2217	245.0	233.7	1.7	15.4	10.9	5.6	13	98.8	65
798	12.2	57.2	2234	245.0	233.7	0.9	15.5	11.7	7.2	13	98.8	66
799	12.0	57.4	2012	245.0	233.7	1.2	14.9	11.2	8.3	13	98.8	66
800	12.0	56.4	2085	245.0	233.7	1.1	15.5	11.3	7.5	13	98.8	66
801	11.5	57.3	2103	245.0	233.7	1.1	15.2	10.8	7.9	13	98.8	66
802	9.3	56.7	1487	245.0	233.7	1.5	15.0	10.0	7.5	13	98.8	66
803	9.3	56.0	1474	245.0	234.0	1.5	15.4	9.3	10.1	13	98.7	66
804	9.8	56.7	1716	245.0	236.2	1.5	15.6	10.0	10.4	13	98.7	66
805	9.7	56.5	1685	245.0	237.1	1.5	15.4	10.1	10.1	13	98.7	66
806	11.0	56.5	2146	245.0	237.2	0.9	15.8	10.3	8.9	13	98.7	66
807												



# Table E.02 Measurement data - Background

Project: Summerhaven Wind Energy Centre - Turbine T24 - IEC 61400-11 Measurement  
 Report ID: 13259.00.T24.RP3

Page 1 of 2  
 Created on: 10/11/2017

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (kPa)	Relative Humidity (%)
1	5.4	42.7	0.1	4.2	13	98.7	43
2	4.8	42.9	0.2	3.7	13	98.7	43
3	5.3	42.7	0.2	4.1	13	98.7	43
4	6.0	43.2	0.3	4.7	13	98.7	43
5	6.3	43.4	0.3	4.9	13	98.7	43
6	8.3	43.2	0.4	6.4	13	98.7	43
7	7.9	43.7	0.4	6.1	13	98.7	43
8	7.2	43.4	0.3	5.6	13	98.7	44
9	7.6	44.0	0.5	5.8	13	98.7	44
10	8.1	43.9	0.5	6.3	13	98.7	44
11	9.3	43.9	0.5	7.2	13	98.7	44
12	8.1	44.4	0.5	6.3	13	98.7	44
13	7.1	44.7	0.5	5.5	13	98.7	43
14	10.1	45.6	0.4	7.8	13	98.7	42
15	10.5	45.6	0.5	8.1	13	98.7	42
16	11.4	44.8	0.8	8.8	13	98.7	42
17	11.6	45.6	0.7	9.0	13	98.7	42
18	10.4	45.4	0.8	8.0	13	98.7	42
19	10.8	50.3	0.8	8.3	13	98.7	42
20	12.3	47.4	0.8	9.5	13	98.7	41
21	12.5	48.1	0.6	9.7	13	98.7	41
22	11.8	48.2	0.7	9.1	13	98.7	41
23	11.2	49.0	0.7	8.6	13	98.7	41
24	11.3	49.4	0.5	8.7	13	98.7	41
25	11.6	48.2	0.5	8.9	13	98.7	41
26	11.0	47.5	0.4	8.5	13	98.7	42
27	9.7	47.9	0.6	7.5	13	98.7	42
28	10.0	47.0	0.5	7.7	13	98.7	42
29	9.4	46.9	0.5	7.3	13	98.7	42
30	8.8	46.8	0.5	6.8	13	98.7	42
31	8.9	47.3	0.3	6.9	13	98.7	43
32	8.8	45.1	0.3	6.8	13	98.7	44
33	9.6	46.6	0.6	7.4	13	98.7	44
34	9.9	46.5	0.8	7.7	13	98.7	44
35	9.0	45.9	0.5	6.9	13	98.7	44
36	8.6	45.8	0.4	6.6	13	98.7	44
37	9.9	44.5	0.3	7.7	13	98.7	44
38	10.6	45.1	0.7	8.2	13	98.7	44
39	10.5	44.7	0.8	8.1	13	98.7	44
40	10.4	45.7	0.7	8.0	13	98.7	44
41	9.5	43.5	0.4	7.3	13	98.7	44
42	8.1	43.3	0.5	6.2	13	98.7	44
43	7.7	43.5	0.6	5.9	13	98.7	43
44	7.4	44.2	0.7	5.7	13	98.7	43
45	7.0	44.4	0.8	5.4	13	98.7	43
46	6.8	44.2	0.8	5.2	13	98.7	43
47	8.2	44.3	0.8	6.3	13	98.7	43
48	8.5	45.7	0.5	6.5	13	98.7	43
49			0.3	6.2	13	98.7	44
50			0.3	5.7	13	98.7	46
51			0.5	5.8	13	98.7	46
52			0.7	6.8	13	98.7	46
53	8.5	45.7	0.5	6.5	13	98.7	46
54	7.2	43.4	0.5	5.5	13	98.7	46
55	7.4	43.1	0.6	5.7	13	98.7	46
56	8.6	43.2	0.4	6.6	13	98.7	46
57	6.8	43.7	0.2	5.3	13	98.7	46
58	7.1	44.0	0.4	5.5	13	98.7	46
59	9.3	43.7	0.3	7.2	13	98.7	46
60	7.2	43.8	0.3	5.6	13	98.7	46
61	7.3	43.1	0.3	5.7	13	98.7	46
62	7.7	43.2	0.3	5.9	13	98.8	46
63	7.4	43.7	0.3	5.7	13	98.8	46
64	6.8	43.0	0.3	5.3	13	98.8	46
65	6.5	42.4	0.2	5.0	13	98.8	46
66	6.2	42.7	0.3	4.8	13	98.8	46
67	6.0	42.4	0.2	4.7	13	98.8	46
68	6.7	42.2	0.1	5.2	13	98.8	45
69	6.3	42.2	0.1	4.9	13	98.8	46
70	5.3	42.1	0.1	4.1	13	98.8	46
71	6.6	42.0	0.2	5.1	13	98.8	46
72	6.8	41.9	0.2	5.3	13	98.8	46
73	6.8	42.0	0.2	5.3	13	98.8	47
74	5.8	41.9	0.3	4.5	13	98.8	47
75	6.4	41.9	0.3	5.0	13	98.8	47
76	7.9	41.8	0.3	6.1	13	98.8	47
77	5.8	42.2	0.4	4.5	13	98.8	47
78	6.7	42.6	0.3	5.2	13	98.8	47
79	6.2	42.3	0.5	4.8	13	98.8	48
80	6.1	42.3	0.5	4.7	13	98.8	48
81	6.3	42.7	0.3	4.9	13	98.8	48
82	7.1	43.6	0.3	5.5	13	98.8	48
83	7.7	44.3	0.3	6.0	13	98.8	48

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (kPa)	Relative Humidity (%)
84	8.0	43.4	0.4	6.2	13	98.8	48
85	7.0	43.2	0.3	5.4	13	98.7	45
86	6.8	43.3	0.2	5.4	13	98.7	43
87	7.3	43.7	0.3	5.6	13	98.7	43
88	8.5	44.1	0.3	6.6	13	98.7	43
89	9.4	43.9	0.4	7.2	13	98.7	43
90	8.4	44.0	0.6	6.5	13	98.7	43
91	7.3	44.2	0.7	5.6	13	98.7	43
92	7.2	43.9	0.8	5.5	13	98.7	44
93	7.2	44.8	0.7	5.6	13	98.7	44
94	7.8	46.6	0.6	6.0	13	98.7	44
95	7.9	48.2	0.6	6.1	13	98.7	44
96	8.1	49.2	0.6	6.3	13	98.7	44
97	9.7	48.5	0.7	7.5	13	98.7	45
98	11.4	49.6	0.8	8.8	13	98.7	45
99	10.0	48.4	0.7	7.7	13	98.7	45
100	9.2	48.5	0.6	7.1	13	98.7	45
101	10.7	47.9	0.4	8.3	13	98.7	45
102	9.6	47.7	0.7	7.4	13	98.7	45
103	8.9	46.8	0.6	6.9	13	98.7	46
104	8.1	46.7	0.5	6.2	13	98.8	46
105	8.7	45.8	0.3	6.7	13	98.8	46
106	10.1	44.7	0.5	7.8	13	98.7	46
107	10.1	44.9	0.5	7.8	13	98.8	46
108	9.5	46.1	0.6	7.3	13	98.8	46
109	9.3	44.8	0.7	7.2	13	98.8	46
110	8.4	45.8	0.7	6.5	13	98.8	46
111	8.9	45.8	0.7	5.3	13	98.8	46
112	7.8	45.2	0.7	6.1	13	98.8	46
113	9.3	45.0	0.6	7.2	13	98.8	46
114	10.9	47.3	0.8	8.4	13	98.8	46
115	10.7	49.1	0.6	8.3	13	98.7	45
116	12.0	51.1	0.5	9.4	13	98.7	44
117	10.9	47.1	0.5	8.4	13	98.7	44
118	10.1	47.8	0.6	7.8	13	98.7	44
119	10.1	45.9	0.5	7.8	13	98.7	44
120	10.2	44.7	0.4	7.9	13	98.7	44
121	9.5	44.3	0.4	7.4	13	98.7	44
122	8.6	44.1	0.5	6.6	13	98.8	44
123	8.8	44.4	0.5	6.8	13	98.8	44
124	8.6	44.3	0.4	6.7	13	98.8	44
125	7.6	44.1	0.4	5.9	13	98.8	44
126	8.3	45.2	0.4	6.4	13	98.8	44
127	10.4	45.9	0.5	8.1	13	98.8	45
128	11.7	44.2	0.5	9.0	13	98.8	46
129	10.5	44.3	0.4	8.1	13	98.8	46
130	9.4	46.8	0.5	7.2	13	98.8	46
131	9.6	48.1	0.5	7.4	13	98.8	46
132	9.0	48.4	0.3	7.0	13	98.8	46
133	9.5	45.5	0.3	7.3	13	98.8	47
134	9.8	44.1	0.3	7.5	13	98.8	48
135	8.1	43.8	0.4	6.3	13	98.8	48
136	8.0	44.6	0.5	6.2	13	98.8	48
137	9.7	44.6	0.5	7.5	13	98.8	48
138	10.9	48.1	0.4	8.5	13	98.8	48
139	12.2	50.8	0.3	9.4	13	98.8	47
140	13.3	48.7	0.3	10.3	13	98.8	46
141	12.1	47.2	0.3	9.3	13	98.8	46
142	9.6	45.3	0.4	7.4	13	98.8	46
143	8.0	44.9	0.2	6.2	13	98.8	46
144	9.1	46.0	0.2	7.0	13	98.8	46
145	8.1	44.9	0.1	6.2	13	98.8	45
146	6.5	42.7	0.1	5.1	13	98.8	44
147	6.6	42.4	0.2	5.1	13	98.8	44
148	7.8	42.6	0.2	6.0	13	98.8	44
149	5.6	42.5	0.4	4.4	13	98.8	44
150	6.4	42.5	0.3	4.9	13	98.8	44
151	6.9	42.2	0.2	5.3	13	98.8	45
152	7.0	42.0	0.2	5.4	13	98.8	47
153	6.1	42.2	0.2	4.7	13	98.8	47
154	7.6	42.5	0.3	5.8	13	98.8	47
155	7.9	43.5	0.3	6.1	13	98.8	47
156	8.2	44.9	0.6	6.3	13	98.8	47
157	10.7	44.7	0.5	8.2	13	98.8	47
158	10.0	43.8	0.4	7.8	13	98.8	46
159	9.3	43.1	0.2	7.2	13	98.8	46
160	7.8	43.0	0.2	6.1	13	98.8	46
161	6.4	44.3	0.3	4.9	13	98.8	46
162	6.6	45.9	0.4	5.1	13	98.8	46
163	8.7	46.3	0.6	6.8	13	98.8	46
164	8.5	45.9	0.4	6.6	13	98.8	46
165	8.4	48.2	0.5	6.5	13	98.8	46
166	10.9	46.4	0.6	8.4	13	98.8	46

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (kPa)	Relative Humidity (%)
167	11.5	47.0	0.6	8.9	13	98.8	46
168	11.4	47.2	0.5	8.8	13	98.8	46
169	11.4	46.2	0.5	8.8	13	98.8	45
170	11.0	47.6	0.5	8.5	13		



---

**End of Report**

---