

REPORT ID: 13259.00.T38.RP1

Summerhaven Wind Energy Centre – Turbine T38 IEC 61400-11 Edition 3.0 Measurement Report


Prepared for:

NextEra Energy Canada
179 Norpark Ave, Unit #20-21
Mount Forest, Ontario, N0G 1A0

Prepared by:

A. Munro

Allan Munro, B.A.Sc.



Payam Ashtiani, B.A.Sc., P.Eng.

08 January 2018 – Revision #1



Revision History

Revision Number	Description	Date
1	Issued Edition 3.0 test report	January 8, 2018

This report in its entirety, including appendices contains 72 pages.

Statement Qualifications and Limitations

This report was prepared by Aercoustics Engineering Limited in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to the Wind Turbine identified in this report.

Aercoustics Engineering Limited shall not be responsible for any events or circumstances that may have occurred since the date on which the Wind Turbine was tested and/or this report was prepared, or for any inaccuracies contained in information that was provided to Aercoustics Engineering Limited. Further, Aercoustics Engineering Limited agrees that this report represents test data analysed as per the above described standard for the specific Wind Turbine described in this report, but Aercoustics Engineering Limited makes no other representations with respect to this report or any part thereof.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Aercoustics Engineering Limited accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Any use of this report is subject to this Statement of Qualifications and Limitations. Any damages arising from improper use of this report or parts thereof shall be borne by the party making such use.

This Statement of Qualifications and Limitations is attached to and forms part of this report.

Table of Contents

Revision History	2
Statement Qualifications and Limitations	2
List of Appendices	6
1 Introduction	8
2 Wind Turbine Information	8
2.1 Wind turbine equipment specific information.....	8
2.2 Wind Turbine Location.....	9
3 Measurement Details	10
3.1 Measurement Equipment.....	10
3.1.1 Acoustic Measurement Equipment.....	10
3.1.2 Meteorological Equipment.....	10
3.2 Measurement Setup.....	10
3.2.1 Microphone Placement.....	10
3.2.2 Double Windscreen Setup.....	11
3.3 Measurement Schedule.....	11
3.4 Meteorological Conditions.....	11
3.5 Turbine operational information.....	11
4 Measurement Results	12
4.1 Deviations from IEC-61400-11 Edition 3.0.....	12
4.2 Special Notes & Considerations.....	12
4.3 Analysis Details.....	12
4.3.1 Double Windscreen Adjustment.....	12
4.3.2 Wind Speed Correction.....	12
4.4 Type B uncertainties.....	12
4.5 Sound Pressure Level Measurements.....	13
4.6 Sound Power Level of Turbine.....	13
4.7 Tonality Analysis.....	14
5 Closure	14
6 References	15

List of Figures

Figure A.01 – Site plan.....	Appendix A
Figure A.02 – Site photos	Appendix A
Figure B.01 – Power Curve.....	Appendix B
Figure B.02 – Rotor RPM vs. Wind Speed.....	Appendix B
Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON &Background).....	Appendix C
Figure C.02 – Plot of measured total noise vs electrical power output.....	Appendix C
Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer.....	Appendix C
Figure C.04 - Plot of rotor RPM vs. electrical power output.....	Appendix C
Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 8 m/s.....	Appendix C
Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s.....	Appendix C
Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s.....	Appendix C
Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s.....	Appendix C
Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s.....	Appendix C
Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s.....	Appendix C
Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s.....	Appendix C
Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s.....	Appendix C
Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 12 m/s.....	Appendix C
Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s.....	Appendix C
Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s.....	Appendix D
Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s...Appendix D	
Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s.....Appendix D	
Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s...Appendix D	
Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s....Appendix D	
Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s...Appendix D	
Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s...Appendix D	
Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s...Appendix D	
Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 12 m/s...Appendix D	
Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 12.5 m/s...Appendix D	

List of Tables

Table 1 - Wind Turbine Details	8
Table 2 - Operating Details.....	8
Table 3 - Rotor Details.....	9
Table 4 - Gearbox Details.....	9
Table 5 - Generator Details	9
Table 6 - Acoustic Measurement Equipment.....	10
Table 7 – Meteorological Measurement Equipment.....	10
Table 8 - Measurement Schedule Summary	11
Table 9 - Summary of Type B uncertainties	12
Table 10 - Summary of Sound Pressure Level Measurements.....	13
Table 11 - LWA _{10m, K} at each integer wind speed	13
Table 12 - Tonality Assessment Summary.....	14
Table C.01 – Detailed apparent sound power level data at hub height.....	Appendix C
Table C.02 – Detailed apparent sound power level data at 10m height.....	Appendix C
Table C.03 – Type B measurement uncertainty summary.....	Appendix C
Table C.04 – Detailed measurement uncertainty at hub height.....	Appendix C
Table E.01 – Measurement data –Turbine ON.....	Appendix E
Table E.02 – Measurement data – Background.....	Appendix E

List of Appendices

Appendix A – Site Details

- Figure A.01 – Site plan
- Figure A.02 – Site photos

Appendix B – Turbine Information

- Figure B.01 – Power curve
- Figure B.02 – Rotor RPM vs. wind speed

Appendix C – Apparent Sound Power Level

- Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)
- Figure C.02 – Plot of measured total noise vs electrical power output
- Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer
- Figure C.04 - Plot of rotor RPM vs. electrical power output
- Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 8 m/s
- Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s
- Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s
- Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s
- Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s
- Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s
- Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s
- Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s
- Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 12 m/s
- Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s
- Table C.01 – Detailed apparent sound power level data at hub height
- Table C.02 – Detailed apparent sound power level data at 10m height
- Table C.03 – Type B measurement uncertainty summary
- Table C.04 – Detailed measurement uncertainty at hub height

Appendix D – Tonality Assessment

- Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s
- Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s
- Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s
- Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s
- Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s
- Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s
- Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s
- Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s
- Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 12 m/s
- Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 12.5 m/s
- Table D.01 – Tonality assessment table – 8.5 m/s
- Table D.02 – Tonality assessment table – 9 m/s
- Table D.03 – Tonality assessment table – 9.5 m/s
- Table D.04 – Tonality assessment table – 10 m/s
- Table D.05 – Tonality assessment table – 10.5 m/s
- Table D.06 – Tonality assessment table – 11 m/s
- Table D.07 – Tonality assessment table – 11.5 m/s

Table D.08 – Tonality assessment table – 12 m/s
Table D.09 – Tonality assessment table – 12.5 m/s

Appendix E – Measurement Data

Table E.01 – Measurement data – Turbine ON
Table E.02 – Measurement data – Background

1 Introduction

Aercoustics Engineering Limited (Aercoustics) was retained by NextEra Energy Canada (“NextEra”) to conduct an acoustic measurement of turbine T38 at the Summerhaven Wind Energy Centre. The purpose of the measurement was to provide verification of the maximum noise emission of the turbine. The measurement was carried out in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to Turbine T38.

2 Wind Turbine Information

2.1 Wind turbine equipment specific information

Wind turbine specific equipment information for turbine T38 was provided by Siemens and is summarized in Tables 1 – 5.

Table 1 - Wind Turbine Details

Wind Turbine Details	
Manufacturer	Siemens
Model Number	SWT 2.3-101
Turbine ID	T38 (Serial# 2306913)

Table 2 - Operating Details

Operating Details	
Vertical or Horizontal axis wind turbine	Horizontal
Upwind or downwind rotor	Upwind rotor
Hub height	80 m
Horizontal distance from rotor centre to tower axis	3500 mm
Diameter of rotor	101
Tower type (lattice or tube)	Tube
Passive stall, active stall, or pitch controlled turbine	Pitch Controlled
Constant or variable speed	Variable speed
Power curve	See Figure B.01
Rotational speed at each integer standardised wind speed	See Figure B.02
Rated power output	2.221 MW
Control software version	16.01.28

Table 3 - Rotor Details

Rotor Details	
Rotor control devices	Pitch control
Presence of vortex generators, stall strips, serrated trailing edges	Vortex generators and DinoTails
Blade type	RAL 7035 PC3, B49-01
Serial number	Blade A: 490338401
Number of blades	Blade B: 490437601

Table 4 - Gearbox Details

Gearbox Details	
Manufacturer	Winergy
Model number	PEAB4456.8 cold climate 2.3MW
Serial number	4837930-020-5

Table 5 - Generator Details

Generator Details	
Manufacturer	Siemens
Model number	Geared, 2.3 MW – 690V
Serial number	5477273

2.2 Wind Turbine Location

Turbine T38 is located in the municipality of Nanticoke, in Haldimand County, approximately 700m North of Rainham Road, and 835m East of Fisherville Road. The area surrounding T38 is flat and consists primarily of farmland.

A general layout of the area in which the turbine is located is provided in the site plan (Figure A.01).

3 Measurement Details

3.1 Measurement Equipment

3.1.1 Acoustic Measurement Equipment

A summary of acoustic equipment utilized by Aercoustics for the measurement of turbine T38 is summarized in Table 6.

Table 6 - Acoustic Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Acoustic Data acquisition system	LMS SCADA Mobile	22163146
Microphone	B&K 4189	3060528
Pre-amplifier	B&K 2671	2369795
Acoustic calibrator	B&K 4231	3012380

Calibration of the measurement setup was carried out before and after Aercoustics set of measurements.

3.1.2 Meteorological Equipment

Wind speed for Turbine ON was derived from the power curve (as per procedures outlined in IEC 61400-11). Wind direction for turbine ON measurements was utilized from the nacelle anemometer located at hub height (80m high) from turbine T38. Data for background measurements was obtained from a 10m high anemometer, which was placed as per guidelines outlined in IEC-61400-11 Edition 3.0.

The meteorological equipment is summarized in Table 7

Table 7 – Meteorological Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Anemometer	VAISALA WXT520	K2420011
Serial to Analog Converter	NOKEVAL 7470	A165152

3.2 Measurement Setup

3.2.1 Microphone Placement

The measurement microphone was setup 132m from the base of the turbine in ‘Position 1’, (i.e. downwind of the turbine, as per IEC 61400-11) at an elevation of 0m relative to the base of T38. The microphone was placed in the centre of a circular, acoustically reflective board.

During the measurement period only data points for which the microphone was within 15 degrees of downwind from the turbine were used. The microphone position relative to downwind of the turbine was monitoring via the yaw angle output provided from the turbine

system (discussed further in Section 3.5). During placement of the microphone the turbine was parked and the reference yaw angle for that measurement logged.

When measurements of T38 were taken, the surrounding land cleared farmland. There were no nearby reflecting surfaces (houses, barns etc.); as such the influence from reflecting surfaces was considered to be negligible.

Photos of the measurement setup are provided in Figure A.02, Appendix A.

3.2.2 Double Windscreen Setup

A double windscreen setup was not utilized.

3.3 Measurement Schedule

Table 8 provides a summary of the test date and times. Data was logged in 10 second intervals for post-processing (as per the measurement standard).

Table 8 - Measurement Schedule Summary

Date	Test Type	Start Time	Finish time
October 30, 2017	Turbine ON	11:22am	12:06pm
	Background	12:09pm	12:46pm
	Turbine ON	12:50pm	2:29pm

3.4 Meteorological Conditions

Detailed meteorological data relevant to the measurement is provided in Appendix E.

As previously mentioned, wind speed for Turbine ON was derived from T38’s power curve (as per the standard), while wind direction was provided by T38’s yaw position. Background data was obtained from an anemometer located 10m above ground level near T38.

Temperature and pressure readings during the measurement period were provided by the 10m anemometer, located near turbine T38 for the duration of Aeroacoustics measurements.

3.5 Turbine operational information

Output data from the turbine (Power, yaw, RPM, pitch angle, and nacelle wind speed) were obtained as analog output signals that were simultaneously acquired with the acoustic and anemometer measurement data using Aeroacoustics data acquisition system.

4 Measurement Results

4.1 Deviations from IEC-61400-11 Edition 3.0

No deviations.

4.2 Special Notes & Considerations

Turbines T39 and T37 were parked for the duration of testing at Turbine T38.

4.3 Analysis Details

The following section outlines analysis of the measurement data acquired for T38. The data presented is exclusive of transient events such as vehicle traffic, wildlife, air traffic etc. The site has been assessed to have a roughness length of 0.05m, representative of farmland with some vegetation.

4.3.1 Double Windscreen Adjustment

As previously mentioned, no double wind screen was used, as such the measurement data did not require adjustment.

4.3.2 Wind Speed Correction

The wind speed for each measurement data point for Turbine ON was derived through the power curve (as per Section 8.2.1.1 of IEC-61400-11). For data points during Turbine ON that were outside the allowed range of the power curve, the wind speed was derived from the nacelle anemometer wind speed (as specified in Section 8.2.1.2 of IEC-61400-11).

Background wind speed was derived utilizing data acquired with the 10m anemometer and normalizing the wind speed (as per Section 8.2.2 of IEC-61400-11).

4.4 Type B uncertainties

Type B uncertainties were obtained through interpretation of information provided in Annex C of IEC-61400-11, and instrument uncertainties obtained from the calibration certificate. A summary of Type B uncertainties is provided in Table 9, while detailed information (including data in 1/3 octave) is provided in Appendix C.

Table 9 - Summary of Type B uncertainties

Component	Typical (dB)	Used (dB)
Calibration	0.2	0.2
Board	0.3	0.3
Distance & direction	0.1	0.1
Air absorption	0	0
Weather conditions	0.5	0.5
Wind speed measured	0.7	0.7
Wind speed derived	0.2	0.2
Wind speed from power curve	0.2	0.2

4.5 Sound Pressure Level Measurements

Sound pressure level measurements are summarized in Table 10. Detailed 1/3 Octave band spectrum data, respective uncertainties, and analysis plots are provided in Appendix C. A copy of the measurement data used for analysis is provided in Appendix E and includes meteorological and turbine operational data.

Table 10 - Summary of Sound Pressure Level Measurements

Wind Speed (m/s)	Turbine ON		Background		Turbine ON, Background adjusted L_{eq} , (dBA)
	L_{eq} , (dBA)	# of data pts	L_{eq} , (dBA)	# of data pts	
8	56.8	6*	41.4	13	56.7
8.5	58.0	17	41.6	11	57.9
9	58.1	37	42.9	18	58.0
9.5	58.4	41	42.5	14	58.3
10	58.5	26	44.0	19	58.3
10.5	58.4	21	46.0	12	58.1
11	58.2	45	46.2	23	58.0
11.5	58.2	77	46.0	24	58.0
12	58.2	58	47.4	13	57.8
12.5	58.1	52	48.5	19	57.6

*less than 10 data points collected in 8m/s wind bin

4.6 Sound Power Level of Turbine

The calculated sound power level of the turbine T38 (as per IEC 61400-11) is summarized in Table 11 (hub height) and Table 12 (10m height). Detailed 1/3 Octave band spectrum data and respective uncertainties are provided in Appendix C.

Table 11 - $L_{WA,K}$ at each integer wind speed

Wind Speed (m/s)	Apparent L_{WA} , (dBA)	Uncertainty (dB)
8	-	-
8.5	106.8	0.8
9	106.9	0.7
9.5	107.3	0.7
10	107.2	0.7
10.5	107.0	0.8
11	106.9	0.7
11.5	106.9	0.8
12	106.8	0.8
12.5	106.6	0.8

Table 12 - $L_{WA, 10m, K}$ at each integer wind speed

Wind Speed (m/s)	Apparent L_{WA} , (dBA)	Uncertainty (dB)
6	106.6	1.0
7	107.2	0.7
8	106.9	0.7
9	106.6	0.8
10	106.6	0.8

4.7 Tonality Analysis

The tonality analysis for Turbine T38 is summarized in Table 13, while plots of narrow band spectra at each wind speed are provided in Appendix D. The ΔL_{tn} and ΔL_a values reported represent the energy average of all data points with an identified tone that falls within the same frequency origin (as specified in Section 9.5.8 in IEC-61400-11).

The narrow band spectra provided in the plots represents an energy average of all data points in the given wind speed bin for both Turbine ON and Background.

Table 13 - Tonality Assessment Summary

Wind Speed (m/s)	Frequency (Hz)	Tonality, ΔL_{tn} (dB)	Tonal audibility, ΔL_a (dB)	FFT's with tones	Total # of FFT's	Presence (%)
8.5	511	-3.0	-0.6	16	17	94%
9	504	-2.1	0.2	25	37	68%
9.5	501	-1.0	1.3	24	41	59%
10	515	-1.1	1.2	18	26	69%
10.5	506	-0.9	1.4	14	21	67%
11	515	0.4	2.7	43	45	96%
11.5	515	0.1	2.4	75	77	97%
12	515	0.3	2.6	55	58	95%
12.5	513	0.9	3.2	51	52	98%

5 Closure

Measurements and analysis were carried on Turbine T38 of the Summerhaven Wind Energy Centre as per International IEC 61400-11 (Edition 3.0, released 2012-11), "Wind turbine generator systems – Part 11: Acoustic noise measurement techniques".

Should you have any questions or comments please do not hesitate to contact the authors of this report.

6 References

1. International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”.

Appendix A Site Details



Google earth

© 2017 Google

13259.00.T38.RP1

Project Name

Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1

Figure Title

Site Plan

Figure A.01





13259.00.T38.RP1

Project Name



Scale: NTS
Drawn by: AM
Reviewed by: PA
Date: Jan 05, 2018
Revision: 1


Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title


Site Photos

Figure A.02

Appendix B Turbine Information




Power Curve	
Hub Wind Speed (m/s)	Power [kW]
0	0
1	0
2	0
3	23
4	107
5	248
6	457
7	748
8	1131
9	1601
10	2008
11	2177
12	2215
13	2220
14	2221
15	2221
16	2221
17	2221
18	2221
19	2221
20	2221
21	2221
22	2221
23	2221
24	2221
25	2221



Appendix C

Apparent Sound Power Level



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1


Project Name

Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)

Figure C.01



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1


Project Name


Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title


Plot of measured total noise vs electrical power output

Figure C.02





8.0 m/s - Hub Height



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 8 m/s

Figure C.05

8.5 m/s - Hub Height



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s

Figure C.06

9.0 m/s - Hub Height



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1


Project Name

Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 9 m/s

Figure C.07



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s

Figure C.08

10.0 m/s - Hub Height



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1


Project Name

Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title


Plot of sound pressure spectrum in 1/3 Octave at 10 m/s

Figure C.09



	13259.00.T38.RP1	Project Name	Figure C.10
	Scale: NTS Drawn by: AM Reviewed by: PA Date: Jan 05, 2018 Revision: 1	Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0 Figure Title Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s	

11.0 m/s - Hub Height



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 11 m/s

Figure C.11

11.5 m/s - Hub Height



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s

Figure C.12

12.0 m/s - Hub Height



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1

Project Name


Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 12 m/s

Figure C.13

12.5 m/s - Hub Height



13259.00.T38.RP1

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Jan 05, 2018
 Revision: 1

Project Name

Summerhaven Wind Energy Centre - Turbine T38 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s

Figure C.14

Table C.01 Detailed apparent sound power level data at hub height

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement

Report ID: 13259.00.T38.RP1

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																			Overall									
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250		1600	2000	2500	3150	4000	5000	6300	8000	10000
8.0	Turbine ON (dBA)	15.4	19.1	22.9	26.8	30.1	34.2	35.7	37.6	39.9	41.2	40.8	42.8	43.0	43.3	46.3	46.2	47.1	46.8	46.7	46.2	45.2	44.1	41.4	38.6	40.6	31.6	33.4	33.6	56.8
	Background (dBA)	10.5	12.0	14.5	16.5	19.3	23.5	24.1	25.2	27.3	28.6	28.7	29.2	29.6	31.3	31.5	31.8	32.2	30.4	28.6	26.5	24.2	22.6	20.1	18.9	18.6	18.9	18.9	18.6	41.4
	Turbine ON - background adj (dBA)	13.7	18.1	22.3	26.3	29.8	33.8	35.4	37.4	39.7	41.0	40.5	42.6	42.8	43.0	46.2	46.0	46.9	46.7	46.6	46.1	45.1	44.1	41.3	38.6	40.6	31.4	33.2	33.5	56.7
	Signal to noise (dB)	4.9	7.1	8.4	10.2	10.9	10.7	11.6	12.4	12.6	12.6	12.1	13.6	13.4	11.9	14.8	14.4	14.9	16.5	18.1	19.7	21.0	21.6	21.3	19.7	22.0	12.8	14.4	15.0	15.4
	Uncertainty (dB)	2.4	1.8	1.3	1.2	1.2	1.2	1.2	1.1	1.1	1.1	1.0	1.0	1.0	1.0	0.9	1.0	0.9	0.9	0.9	0.9	0.9	1.1	1.1	1.2	1.5	1.6	1.6	2.3	1.0
8.5	PWL (dBA)	62.7	67.0	71.2	75.3	78.7	82.7	84.3	86.3	88.6	89.9	89.4	91.5	91.7	91.9	95.1	95.0	95.9	95.7	95.5	95.0	94.1	93.0	90.3	87.5	89.5	80.3	82.2	82.4	105.6
	Turbine ON (dBA)	16.3	21.0	24.8	28.9	32.1	35.5	37.9	39.7	41.7	42.6	42.4	44.0	44.3	44.5	48.5	47.1	47.8	47.8	47.6	47.2	46.3	45.3	42.4	39.9	41.9	33.4	35.1	34.8	58.0
	Background (dBA)	3.7	7.8	12.1	15.0	18.6	23.6	23.6	24.8	26.7	29.1	29.0	29.7	30.2	30.7	31.5	31.6	32.2	31.0	29.6	27.6	25.7	24.0	20.9	18.9	17.8	17.4	17.1	15.7	41.6
	Turbine ON - background adj (dBA)	16.0	20.8	24.6	28.7	31.9	35.2	37.8	39.6	41.5	42.4	42.2	43.8	44.2	44.3	48.4	47.0	47.7	47.7	47.5	47.1	46.3	45.3	42.4	39.9	41.9	33.2	35.0	34.8	57.9
	Signal to noise (dB)	12.5	13.2	12.7	13.9	13.5	11.9	14.4	15.0	14.9	13.5	13.4	14.3	14.1	13.8	17.0	15.5	15.7	16.8	18.1	19.5	20.6	21.3	21.5	21.0	24.1	15.9	18.0	19.1	16.4
9.0	Uncertainty (dB)	1.1	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9	0.9	1.0	0.9	1.5	0.8
	PWL (dBA)	65.0	69.8	73.5	77.6	80.8	84.2	86.7	88.5	90.4	91.3	91.1	92.8	93.1	93.3	97.3	95.9	96.7	96.7	96.5	96.1	95.2	94.2	91.3	88.8	90.8	82.2	84.0	83.7	106.8
	Turbine ON (dBA)	16.0	20.8	24.3	28.3	31.6	35.2	37.3	39.4	41.5	42.4	42.5	44.0	44.5	44.6	48.8	47.3	48.0	48.0	47.7	47.2	46.4	45.5	42.6	40.2	41.8	33.7	35.3	34.6	58.1
	Background (dBA)	6.1	9.7	12.4	15.6	19.6	25.9	24.5	26.2	29.1	31.3	30.9	31.0	30.6	32.4	32.4	32.6	33.5	32.1	30.5	28.5	26.6	24.7	21.8	19.8	18.6	18.5	17.8	16.3	42.9
	Turbine ON - background adj (dBA)	15.5	20.5	24.0	28.0	31.3	34.6	37.1	39.2	41.3	42.1	42.1	43.8	44.3	44.4	48.7	47.1	47.9	47.9	47.6	47.2	46.3	45.5	42.6	40.2	41.8	33.5	35.2	34.5	58.0
9.5	Signal to noise (dB)	9.9	11.2	11.9	12.7	12.0	9.2	12.8	13.2	12.5	11.1	11.5	13.1	13.9	12.3	16.4	14.6	14.5	15.9	17.1	18.7	19.8	20.8	20.8	20.4	23.2	15.2	17.5	18.3	15.3
	Uncertainty (dB)	1.1	1.1	0.8	0.8	0.8	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	0.7
	PWL (dBA)	64.5	69.4	72.9	76.9	80.3	83.6	86.0	88.1	90.2	91.0	91.1	92.7	93.3	93.7	97.0	96.0	96.8	96.8	96.5	96.1	95.2	94.4	91.5	89.1	90.8	82.5	84.1	83.4	106.9
	Turbine ON (dBA)	16.2	21.1	24.8	28.6	32.0	35.3	37.5	39.7	42.2	42.8	42.9	44.6	45.0	45.2	49.6	47.5	48.2	48.2	47.8	47.3	46.5	45.7	42.8	40.5	41.7	34.0	35.4	34.4	58.4
	Background (dBA)	6.5	10.3	12.8	16.1	19.8	25.4	25.8	26.1	28.6	31.2	30.7	30.8	30.3	30.3	31.8	31.7	32.5	32.0	30.5	28.9	27.0	25.6	23.5	22.0	21.1	20.4	19.8	18.2	42.5
10.0	Turbine ON - background adj (dBA)	15.7	20.8	24.5	28.4	31.7	34.9	37.2	39.5	42.0	42.5	42.7	44.4	44.9	45.0	49.5	47.4	48.1	48.1	47.7	47.3	46.4	45.7	42.8	40.5	41.7	33.8	35.2	34.3	58.3
	Signal to noise (dB)	9.7	10.8	11.9	12.5	12.1	9.9	11.7	13.6	13.6	11.6	12.2	13.9	14.7	14.8	17.8	15.9	15.7	16.2	17.2	18.4	19.4	20.2	19.3	18.5	20.7	13.5	15.6	16.2	16.0
	Uncertainty (dB)	1.1	1.1	0.8	0.8	0.8	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.8	1.4	0.7
	PWL (dBA)	64.7	69.7	73.4	77.3	80.6	83.8	86.2	88.5	90.9	91.4	91.6	93.4	93.8	94.0	98.4	96.4	97.0	97.0	96.6	96.2	95.3	94.6	91.7	89.4	90.6	82.7	84.2	83.2	107.3
	Turbine ON (dBA)	17.5	22.5	25.4	29.0	32.2	37.5	37.8	39.8	42.6	42.8	42.9	44.6	44.8	45.0	49.5	47.5	48.1	48.2	47.9	47.5	46.6	45.9	42.9	40.6	41.2	33.9	35.1	33.9	58.5
10.5	Background (dBA)	11.6	15.1	17.2	18.8	21.2	25.5	25.7	29.3	29.5	31.5	31.8	32.8	32.7	32.3	33.5	33.3	33.9	33.2	32.4	31.0	29.5	27.6	24.5	21.9	20.1	19.1	18.3	16.9	44.0
	Turbine ON - background adj (dBA)	16.2	21.6	24.7	28.6	31.9	37.2	37.5	39.4	42.4	42.4	42.6	44.3	44.6	44.7	49.4	47.3	48.0	48.1	47.8	47.4	46.6	45.8	42.8	40.6	41.2	33.7	35.0	33.8	58.3
	Signal to noise (dB)	5.8	7.4	8.2	10.2	11.1	12.0	12.1	10.5	13.1	11.3	11.1	11.8	12.2	12.7	16.0	14.1	14.2	15.0	15.5	16.5	17.2	18.3	18.4	18.7	21.1	14.8	16.7	17.0	14.4
	Uncertainty (dB)	1.6	1.3	1.0	0.9	0.9	1.0	0.8	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.8	1.4	0.7
	PWL (dBA)	65.1	70.5	73.6	77.5	80.8	86.1	86.4	88.3	91.3	91.4	91.5	93.2	93.5	93.7	98.3	96.2	96.9	97.0	96.7	96.3	95.5	94.8	91.8	89.5	90.1	82.7	83.9	82.7	107.2
10.5	Turbine ON (dBA)	16.9	21.6	24.8	28.7	32.1	35.4	37.5	39.7	42.3	42.6	42.7	44.4	44.6	44.8	49.5	47.3	48.1	48.2	47.9	47.5	46.7	45.9	42.8	40.5	41.1	33.9	35.2	33.9	58.4
	Background (dBA)	18.0	21.5	23.7	25.2	25.4	28.3	28.2	31.7	31.1	33.0	33.5	34.6	34.5	34.3	35.3	35.3	36.0	35.2	34.2	33.0	31.6	29.9	26.9	24.0	22.2	20.7	19.3	17.7	46.0
	Turbine ON - background adj (dBA)	[13.9]	[18.6]	[21.8]	26.1	31.1	34.5	37.0	38.9	42.0	42.1	42.1	43.9	44.2	44.4	49.3	47.1	47.8	48.0	47.7	47.3	46.5	45.7	42.7	40.4	41.1	33.7	35.1	33.8	58.1
	Signal to noise (dB)	-1.1	0.1	1.1	3.5	6.8	7.1	9.3	8.0	11.2	9.6	9.1	9.8	10.1	10.5	14.2	12.1	12.1	13.0	13.6	14.5	15.0	16.0	16.0	16.5	18.9	13.2	15.9	16.2	12.4
	Uncertainty (dB)	4.3	3.8	3.4	2.5	1.1	1.0	0.9	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	1.5	0.8
10.5	PWL (dBA)	[62.9]	[67.6]	[70.7]	75.0	80.0	83.4	85.9	87.9	90.9	91.0	91.1	92.8	93.1	93.3	98.2	96.0	96.7	96.9	96.6	96.3	95.4	94.7	91.6	89.3	90.0	82.6	84.0	82.7	107.0

Table C.01 Detailed apparent sound power level data at hub height

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement

Report ID: 13259.00.T38.RP1

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																	Overall											
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800		1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000
11.0	Turbine ON (dBA)	17.7	22.4	25.3	29.0	32.6	35.6	37.7	39.9	42.3	42.7	42.7	44.3	44.0	44.3	49.4	46.9	47.8	48.1	47.9	47.6	46.7	45.8	42.7	40.2	40.2	33.3	34.2	33.0	58.2
	Background (dBA)	19.2	22.7	24.4	26.0	27.5	28.3	29.3	30.2	31.2	32.8	33.2	35.0	34.8	34.5	35.5	35.4	35.9	35.4	34.6	33.4	32.0	30.3	27.3	24.9	25.1	22.0	20.2	18.2	46.2
	Turbine ON - background adj (dBA)	[14.7]	[19.4]	[22.3]	26.0	31.1	34.8	37.1	39.4	41.9	42.2	42.2	43.7	43.5	43.8	49.3	46.6	47.5	47.8	47.6	47.4	46.6	45.7	42.6	40.1	40.1	33.0	34.0	32.8	58.0
	Signal to noise (dB)	-1.5	-0.3	0.9	3.0	5.2	7.3	8.4	9.7	11.0	9.8	9.5	9.3	9.2	9.7	14.0	11.5	11.9	12.6	13.2	14.2	14.7	15.6	15.4	15.3	15.1	11.3	14.0	14.8	12.0
	Uncertainty (dB)	3.2	3.1	2.6	2.4	1.3	1.0	0.9	0.9	0.8	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.8	1.5	0.7
11.5	PWL (dBA)	[63.7]	[68.3]	[71.2]	74.9	80.0	83.7	86.0	88.3	90.8	91.1	91.1	92.7	92.4	92.7	98.2	95.5	96.4	96.7	96.6	96.4	95.5	94.7	91.5	89.0	89.0	81.9	83.0	81.8	106.9
	Turbine ON (dBA)	18.0	22.8	25.5	29.1	32.6	35.9	38.0	39.9	42.3	42.8	42.7	44.4	44.0	44.2	49.3	46.9	47.7	48.0	47.9	47.6	46.8	46.0	42.8	40.3	40.5	33.7	34.7	33.4	58.2
	Background (dBA)	16.8	19.1	21.4	23.0	24.1	27.8	27.5	31.1	31.3	33.4	33.6	34.5	34.3	34.3	35.3	35.1	35.8	35.4	34.5	33.3	31.9	30.0	26.9	24.2	22.9	22.9	21.3	18.5	46.0
	Turbine ON - background adj (dBA)	[15]	20.4	23.4	27.9	32.0	35.2	37.7	39.3	42.0	42.3	42.2	43.9	43.5	43.7	49.1	46.6	47.4	47.8	47.7	47.4	46.6	45.9	42.7	40.2	40.4	33.3	34.5	33.3	58.0
	Signal to noise (dB)	1.2	3.7	4.2	6.2	8.5	8.1	10.6	8.8	11.1	9.4	9.1	9.9	9.7	9.8	14.0	11.8	11.9	12.6	13.3	14.3	14.9	16.0	15.9	16.2	17.6	10.8	13.4	14.9	12.2
12.0	Uncertainty (dB)	3.0	2.3	1.7	1.2	1.0	1.0	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	1.5	0.8
	PWL (dBA)	[64]	69.4	72.4	76.9	80.9	84.1	86.6	88.3	90.9	91.2	91.1	92.8	92.5	92.6	98.1	95.5	96.4	96.7	96.6	96.4	95.6	94.8	91.6	89.2	89.4	82.3	83.4	82.2	106.9
	Turbine ON (dBA)	17.3	22.5	25.3	28.9	33.6	36.4	37.8	39.9	42.2	42.7	42.7	44.2	43.8	43.9	49.2	46.6	47.5	47.9	47.8	47.7	46.9	46.2	42.9	40.6	41.0	34.2	35.3	33.9	58.2
	Background (dBA)	19.5	22.8	23.1	24.8	26.7	28.4	29.6	32.1	32.0	33.3	34.1	35.6	36.0	35.8	37.1	36.7	37.7	37.0	36.1	34.9	33.5	31.6	28.5	25.6	23.5	22.1	20.8	18.9	47.4
	Turbine ON - background adj (dBA)	[14.3]	[19.5]	[22.3]	26.7	32.6	35.6	37.1	39.1	41.8	42.2	42.0	43.6	43.0	43.2	48.9	46.2	47.1	47.6	47.5	47.4	46.7	46.0	42.8	40.5	40.9	33.9	35.1	33.8	57.8
12.5	Signal to noise (dB)	-2.2	-0.3	2.2	4.1	7.0	8.0	8.2	7.8	10.2	9.4	8.6	8.6	7.9	8.1	12.1	9.9	9.8	10.9	11.7	12.8	13.4	14.5	14.5	15.0	17.5	12.0	14.4	15.1	10.8
	Uncertainty (dB)	3.1	3.1	2.5	1.7	1.1	1.0	1.0	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.8	1.5	0.8
	PWL (dBA)	[63.2]	[68.4]	[71.2]	75.7	81.6	84.5	86.0	88.0	90.7	91.1	91.0	92.5	92.0	92.1	97.8	95.1	96.0	96.5	96.5	96.4	95.6	94.9	91.7	89.4	89.8	82.8	84.0	82.7	106.8
	Turbine ON (dBA)	18.8	23.3	26.4	29.5	32.7	35.9	38.0	39.9	42.1	42.7	42.6	44.0	43.7	43.8	49.4	46.5	47.4	47.8	47.8	47.6	46.8	46.0	42.7	40.3	40.7	33.9	34.9	33.7	58.1
	Background (dBA)	20.2	24.3	26.9	28.1	29.3	29.7	31.1	32.0	33.4	34.1	34.9	36.7	36.9	37.0	37.9	37.9	38.7	37.9	37.1	35.9	34.6	32.9	30.0	27.5	25.5	23.9	22.4	20.3	48.5
Turbine ON - background adj (dBA)	[15.8]	[20.3]	[23.4]	[26.5]	30.1	34.8	37.0	39.1	41.5	42.1	41.8	43.1	42.7	42.8	49.1	45.8	46.8	47.3	47.4	47.3	46.5	45.8	42.5	40.1	40.5	33.5	34.7	33.5	57.6	
Signal to noise (dB)	-1.4	-1.0	-0.5	1.4	3.5	6.2	6.9	7.9	8.8	8.6	7.7	7.3	6.8	6.8	11.6	8.5	8.7	9.9	10.7	11.7	12.1	13.1	12.7	12.8	15.2	10.0	12.6	13.4	9.6	
Uncertainty (dB)	2.9	3.0	2.7	2.5	1.9	1.1	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.7	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	1.5	0.8
PWL (dBA)	[64.7]	[69.2]	[72.3]	[75.4]	79.1	83.7	85.9	88.1	90.5	91.0	90.8	92.1	91.6	91.7	98.0	94.8	95.7	96.3	96.3	96.2	95.4	94.7	91.4	89.0	89.5	82.4	83.6	82.4	106.6	

Table C.02 Detailed apparent sound power level data at 10m height

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement

Report ID: 13259.00.T38.RP1

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																			Overall									
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
6.0	Turbine ON (dBA)	15.9	20.6	24.3	28.3	31.6	35.0	37.4	39.3	41.1	42.2	42.1	43.7	44.1	44.3	48.2	46.9	47.7	47.7	47.4	47.0	46.0	45.1	42.2	39.6	41.7	33.0	34.8	34.6	57.8
	Background (dBA)	7.7	10.1	13.1	15.7	19.2	24.7	24.1	25.5	28.0	29.9	29.7	30.0	30.1	31.0	31.6	31.8	32.3	31.0	29.5	27.7	25.7	23.9	21.0	19.2	18.3	18.1	17.9	17.0	41.9
	Turbine ON - background adj (dBA)	15.2	20.2	23.9	28.1	31.3	34.5	37.2	39.1	40.9	42.0	41.8	43.5	43.9	44.1	48.1	46.8	47.6	47.6	47.4	46.9	46.0	45.1	42.2	39.6	41.7	32.8	34.7	34.5	57.7
	Signal to noise (dB)	8.2	10.5	11.2	12.6	12.3	10.3	13.3	13.8	13.2	12.4	12.4	13.6	14.0	13.2	16.6	15.2	15.4	16.6	17.9	19.3	20.3	21.2	21.2	20.4	23.4	14.8	16.9	17.6	15.9
	Uncertainty (dB)	1.6	1.5	1.2	1.1	1.1	1.2	1.1	1.1	1.1	1.1	1.0	1.0	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.1	1.1	1.1	1.1	1.2	1.1	2.0	1.0
7.0	PWL (dBA)	64.1	69.1	72.9	77.0	80.2	83.5	86.2	88.0	89.8	90.9	90.8	92.4	92.8	93.0	97.1	95.7	96.5	96.5	96.3	95.9	94.9	94.0	91.1	88.5	90.6	81.7	83.6	83.5	106.6
	Turbine ON (dBA)	16.7	21.6	24.9	28.7	32.1	36.1	37.6	39.7	42.3	42.7	42.9	44.5	44.9	45.0	49.4	47.5	48.2	48.2	47.8	47.4	46.6	45.8	42.9	40.6	41.5	33.9	35.3	34.2	58.4
	Background (dBA)	12.3	15.7	17.7	19.2	21.5	25.8	25.9	28.1	29.3	31.5	31.7	32.4	32.2	32.6	33.4	33.4	34.2	33.3	32.1	30.7	29.1	27.3	24.6	22.3	20.9	19.9	19.0	17.5	43.9
	Turbine ON - background adj (dBA)	14.7	20.3	24.0	28.2	31.7	35.7	37.3	39.4	42.0	42.4	42.5	44.2	44.6	44.8	49.3	47.3	48.0	48.1	47.7	47.3	46.5	45.7	42.8	40.5	41.5	33.8	35.2	34.1	58.3
	Signal to noise (dB)	4.4	5.9	7.2	9.5	10.6	10.4	11.6	11.6	13.0	11.2	11.2	12.1	12.6	12.4	16.0	14.1	14.0	14.9	15.7	16.8	17.5	18.5	18.3	18.3	20.7	14.0	16.2	16.7	14.5
8.0	Uncertainty (dB)	1.9	1.5	1.0	0.9	0.9	0.9	0.8	0.8	0.8	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.5	0.7
	PWL (dBA)	63.7	69.3	72.9	77.1	80.6	84.6	86.2	88.3	91.0	91.3	91.5	93.2	93.6	93.7	98.3	96.2	96.9	97.0	96.6	96.3	95.4	94.7	91.7	89.4	90.4	82.7	84.1	83.1	107.2
	Turbine ON (dBA)	17.7	22.5	25.3	29.0	32.8	35.8	37.9	39.9	42.3	42.7	42.7	44.4	44.2	44.3	49.4	47.0	47.8	48.1	47.9	47.6	46.7	45.9	42.8	40.4	40.6	33.7	34.7	33.4	58.3
	Background (dBA)	18.4	21.5	23.3	25.0	26.0	28.1	28.6	31.0	31.2	33.1	33.4	34.7	34.5	34.4	35.3	35.2	35.8	35.3	34.5	33.2	31.8	30.0	26.9	24.4	23.8	22.3	20.6	18.3	46.1
	Turbine ON - background adj (dBA)	[14.7]	[19.5]	[22.3]	26.8	31.8	35.0	37.3	39.3	41.9	42.2	42.2	43.9	43.7	43.8	49.2	46.7	47.5	47.8	47.6	47.4	46.6	45.8	42.7	40.2	40.5	33.3	34.5	33.3	58.0
9.0	Signal to noise (dB)	-0.7	0.9	2.0	4.0	6.8	7.7	9.3	8.9	11.0	9.6	9.3	9.6	9.6	9.9	14.1	11.7	12.0	12.7	13.4	14.4	15.0	15.9	15.9	16.0	16.8	11.4	14.0	15.1	12.2
	Uncertainty (dB)	2.6	2.5	2.0	1.4	1.0	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.6	0.7	0.7	0.7	0.7	0.8	0.8	1.4	0.7
	PWL (dBA)	[63.6]	[68.4]	[71.3]	75.7	80.7	83.9	86.2	88.2	90.9	91.2	91.1	92.8	92.6	92.8	98.2	95.6	96.4	96.7	96.6	96.3	95.5	94.7	91.6	89.2	89.4	82.3	83.4	82.2	106.9
	Turbine ON (dBA)	17.9	22.8	25.7	29.1	32.6	36.0	37.9	39.8	42.1	42.7	42.6	44.1	43.6	43.7	49.3	46.5	47.4	47.8	47.8	47.6	46.8	46.1	42.8	40.4	40.8	33.9	35.0	33.7	58.1
	Background (dBA)	20.1	23.6	25.9	27.1	28.5	29.3	30.7	32.5	33.1	34.0	35.0	36.6	36.9	36.8	37.7	37.7	38.5	37.8	36.9	35.8	34.5	32.7	29.6	26.8	24.5	22.9	21.4	19.4	48.3
10.0	Turbine ON - background adj (dBA)	[14.9]	[19.8]	[22.7]	[26.1]	30.5	34.9	37.0	38.9	41.5	42.0	41.8	43.2	42.6	42.7	49.0	45.9	46.8	47.4	47.4	47.3	46.6	45.9	42.6	40.2	40.6	33.6	34.8	33.5	57.7
	Signal to noise (dB)	-2.2	-0.8	-0.2	2.0	4.1	6.6	7.2	7.3	9.0	8.7	7.6	7.4	6.7	6.9	11.6	8.8	8.9	10.1	10.8	11.8	12.4	13.4	13.2	13.6	16.2	11.1	13.6	14.3	9.8
	Uncertainty (dB)	2.6	2.6	2.2	2.1	1.5	1.1	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.8	1.5	0.8
	PWL (dBA)	[63.8]	[68.7]	[71.6]	[75]	79.4	83.9	85.9	87.8	90.5	91.0	90.7	92.1	91.5	91.7	97.9	94.8	95.8	96.3	96.3	96.2	95.5	94.8	91.5	89.1	89.6	82.5	83.7	82.5	106.6
	Turbine ON (dBA)	18.3	23.1	25.8	29.4	32.7	35.9	38.0	39.9	42.2	42.8	42.8	44.2	43.7	43.6	49.4	46.4	47.3	47.8	47.8	47.7	47.0	46.2	42.9	40.4	40.7	33.9	34.8	33.7	58.2
10.0	Background (dBA)	18.2	21.1	24.1	25.0	26.5	28.3	29.8	34.6	33.4	34.3	36.2	37.6	37.9	38.1	38.4	38.0	38.7	37.9	37.2	36.1	34.8	32.9	29.5	26.3	23.2	21.3	19.6	17.7	48.8
	Turbine ON - background adj (dBA)	[15.3]	[20.1]	[22.8]	27.4	31.5	35.1	37.3	38.3	41.6	42.2	41.7	43.2	42.4	42.2	49.1	45.7	46.7	47.3	47.4	47.4	46.7	46.0	42.7	40.3	40.6	33.7	34.7	33.6	57.6
	Signal to noise (dB)	0.1	2.0	1.7	4.4	6.2	7.6	8.2	5.2	8.8	8.5	6.5	6.6	5.8	5.5	11.1	8.4	8.6	9.8	10.6	11.5	12.2	13.3	13.4	14.2	17.5	12.7	15.2	16.0	9.4
	Uncertainty (dB)	2.6	2.7	2.4	1.5	1.1	1.0	0.9	1.2	0.9	0.9	0.9	1.0	1.0	0.7	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	0.8
	PWL (dBA)	[64.3]	[69]	[71.7]	76.4	80.4	84.0	86.2	87.2	90.6	91.1	90.6	92.1	91.3	91.1	98.0	94.6	95.6	96.2	96.3	96.3	95.6	95.0	91.6	89.2	89.6	82.6	83.6	82.5	106.6

Table C.03 Type B measurement uncertainty summary

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
Report ID: 13259.00.T38.RP1

Page 1 of 1
Created on: 1/5/2018

Overall Equipment Uncertainties		
	Typical values	Used values
Calibration	0.2 dB	0.2 dB
Board	0.3 dB	0.3 dB
Distance	0.1 dB	0.1 dB
Air absorption	0 dB	0 dB
Weather	0.5 dB	0.5 dB

1/3 Octave Band Uncertainties		
Frequency (Hz)	Microphone Uncertainty	Overall (including overall equipment Uncertainties)
20	0.8 dB	1 dB
25	0.8 dB	1 dB
31.5	0.5 dB	0.8 dB
40	0.5 dB	0.8 dB
50	0.5 dB	0.8 dB
63	0.5 dB	0.8 dB
80	0.5 dB	0.8 dB
100	0.5 dB	0.8 dB
125	0.5 dB	0.8 dB
160	0.5 dB	0.8 dB
200	0.3 dB	0.7 dB
250	0.3 dB	0.7 dB
315	0.3 dB	0.7 dB
400	0.3 dB	0.7 dB
500	0.3 dB	0.7 dB
630	0.3 dB	0.7 dB
800	0.3 dB	0.7 dB
1000	0.3 dB	0.7 dB
1250	0.3 dB	0.7 dB
1600	0.3 dB	0.7 dB
2000	0.3 dB	0.7 dB
2500	0.5 dB	0.8 dB
3150	0.5 dB	0.8 dB
4000	0.5 dB	0.8 dB
5000	0.5 dB	0.8 dB
6300	0.5 dB	0.8 dB
8000	0.5 dB	0.8 dB
10000	1.3 dB	1.4 dB

Table C.04 Detailed measurement uncertainty at hub height

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 2
 Created on: 1/5/2018

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																	Overall													
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800		1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
8.0	Turbine ON	8.10	6	Average (dBA)	15.6	19.5	23.3	27.2	30.5	34.4	36.2	38.1	40.3	41.5	41.1	43.0	43.3	43.5	46.7	46.4	47.2	47.0	46.9	46.4	45.4	44.4	41.6	38.9	40.8	32.0	33.7	33.8	57.0		
				Uncertainty A (dB)	0.6	0.5	0.3	0.3	0.4	0.3	0.3	0.3	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.5	0.9	0.9	0.9	1.1	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
				Combined Uncertainty (dB)	1.2	1.1	0.9	0.8	0.9	0.9	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9	1.2	1.2	1.2	1.8	
	Background	7.99	13	Average (dBA)	10.6	12.1	14.5	16.6	19.3	23.5	24.1	25.2	27.3	28.6	28.7	29.2	29.6	31.3	31.5	31.8	32.2	30.3	28.6	26.5	24.2	22.5	20.1	18.9	18.6	18.9	19.0	18.7	41.4		
8.5	Turbine ON	8.50	17	Uncertainty A (dB)	1.8	1.3	1.0	0.6	0.6	0.8	0.5	0.4	0.4	0.7	0.5	0.3	0.3	0.7	0.4	0.6	0.7	0.5	0.5	0.5	0.6	0.7	0.5	0.4	0.5	0.5	0.7	0.9			
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
				Combined Uncertainty (dB)	2.1	1.7	1.3	1.0	1.0	1.1	0.9	0.9	0.9	1.1	0.9	0.8	0.8	0.8	0.8	0.9	1.0	0.9	0.8	0.8	0.9	0.9	1.1	1.0	0.9	0.9	1.0	1.0	1.7		
				Background	8.51	11	Average (dBA)	16.3	21.1	24.8	28.9	32.1	35.5	38.0	39.7	41.7	42.6	42.4	44.0	44.3	44.5	48.5	47.1	47.9	47.8	47.6	47.2	46.3	45.3	42.4	39.9	41.9	33.4	35.1	34.8
	9.0	Turbine ON	8.97	37	Uncertainty A (dB)	0.4	0.4	0.3	0.3	0.3	0.3	0.4	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.4	0.5	0.5	0.5	
Uncertainty B (dB)					1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
Combined Uncertainty (dB)					1.1	1.1	0.9	0.9	0.9	0.8	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.9	1.0	0.9	1.5	
Background					8.94	18	Average (dBA)	3.6	7.8	12.1	15.0	18.6	23.6	23.6	24.8	26.7	29.1	29.0	29.7	30.2	30.7	31.5	31.5	32.2	31.0	29.6	27.7	25.8	24.0	20.9	18.9	17.8	17.4	17.0	15.7
9.5		Turbine ON	9.53	41	Uncertainty A (dB)	1.3	1.0	0.7	0.4	0.5	1.1	0.6	0.5	0.6	1.0	0.8	0.7	0.7	0.8	0.7	0.7	0.9	0.9	0.9	1.0	1.2	1.3	0.9	0.6	0.2	0.1	0.1	0.1		
	Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
	Combined Uncertainty (dB)				1.6	1.4	1.1	0.9	0.9	1.4	1.0	0.9	1.0	1.3	1.1	1.0	1.0	1.0	1.0	1.0	1.1	1.2	1.1	1.1	1.2	1.4	1.5	1.2	1.0	0.8	0.8	0.8	1.4		
	Background				9.47	14	Average (dBA)	6.1	9.7	12.4	15.5	19.6	26.0	24.3	26.2	29.1	31.3	31.0	31.0	30.7	32.6	32.5	32.8	33.6	32.1	30.6	28.5	26.5	24.7	21.7	19.6	18.3	18.3	17.6	16.1
	10.0	Turbine ON	9.97	26	Uncertainty A (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4		
Uncertainty B (dB)					1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
Combined Uncertainty (dB)					1.1	1.1	0.9	0.9	0.9	1.0	0.8	0.8	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	1.5
Background					9.96	19	Average (dBA)	6.2	10.0	12.6	15.9	19.8	25.4	25.8	25.9	28.5	31.2	30.6	30.6	30.2	30.2	31.7	31.6	32.4	31.9	30.4	28.8	26.9	25.4	23.4	22.0	21.1	20.5	19.9	18.3
10.0		Turbine ON	9.97	26	Uncertainty A (dB)	0.2	0.1	0.2	0.2	0.2	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.3	0.3	0.3	
	Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
	Combined Uncertainty (dB)				1.7	1.5	1.1	0.9	0.9	1.1	1.2	0.9	0.9	1.1	1.0	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	1.0	1.0	1.0	1.2	1.4	1.5	1.4	1.4	1.3	1.2	1.7	
	Background				9.96	19	Average (dBA)	17.5	22.5	25.5	29.1	32.3	37.6	37.8	39.8	42.6	42.8	42.9	44.6	44.9	45.0	49.5	47.5	48.1	48.2	47.9	47.5	46.6	45.9	42.9	40.6	41.2	33.9	35.1	33.9
	10.0	Turbine ON	9.97	26	Uncertainty A (dB)	0.5	0.4	0.3	0.3	0.3	0.6	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.3	0.4	0.3	0.3	
Uncertainty B (dB)					1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4	
Combined Uncertainty (dB)					1.1	1.1	0.9	0.9	0.9	1.0	0.8	0.8	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	1.5
Background					9.96	19	Average (dBA)	11.1	14.5	16.6	18.3	20.8	25.2	25.4	29.1	29.3	31.4	31.7	32.6	32.5	32.1	33.4	33.2	33.7	33.1	32.2	30.8	29.3	27.4	24.3	21.7	19.9	19.0	18.3	16.8
10.0		Turbine ON	9.97	26	Uncertainty A (dB)	1.7	1.5	1.2	0.9	0.5	0.5	0.5	0.9	0.5	0.7	0.7	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.9	1.1	1.1	0.9	0.7	0.5	0.4	0.3	0.3		
	Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
	Combined Uncertainty (dB)				2.0	1.8	1.4	1.2	0.9	1.0	1.0	1.2	0.9	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.1	1.2	1.3	1.3	1.2	1.1	1.0	0.9	0.9	1.5		
	Background				9.96	19	Average (dBA)	11.1	14.5	16.6	18.3	20.8	25.2	25.4	29.1	29.3	31.4	31.7	32.6	32.5	32.1	33.4	33.2	33.7	33.1	32.2	30.8	29.3	27.4	24.3	21.7	19.9	19.0	18.3	16.8
	10.0	Turbine ON	9.97	26	Uncertainty A (dB)	1.7	1.5	1.2	0.9	0.5	0.5	0.5	0.9	0.5	0.7	0.7	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.9	1.1	1.1	0.9	0.7	0.5	0.4	0.3	0.3		
Uncertainty B (dB)					1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
Combined Uncertainty (dB)					2.0	1.8	1.4	1.2	0.9	1.0	1.0	1.2	0.9	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.1	1.2	1.3	1.3	1.2	1.1	1.0	0.9	0.9	1.5		
Background					9.96	19	Average (dBA)	11.1	14.5	16.6	18.3	20.8	25.2	25.4	29.1	29.3	31.4	31.7	32.6	32.5	32.1	33.4	33.2	33.7	33.1	32.2	30.8	29.3	27.4	24.3	21.7	19.9	19.0	18.3	16.8
10.0		Turbine ON	9.97	26	Uncertainty A (dB)	1.7	1.5	1.2	0.9	0.5	0.5	0.5	0.9	0.5	0.7	0.7	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.9	1.1	1.1	0.9	0.7	0.5	0.4	0.3	0.3		
	Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
	Combined Uncertainty (dB)				2.0	1.8	1.4	1.2	0.9	1.0	1.0	1.2	0.9	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.1	1.2	1.3	1.3	1.2	1.1	1.0	0.9	0.9	1.5		
	Background				9.96	19	Average (dBA)	11.1	14.5	16.6	18.3	20.8	25.2	25.4	29.1	29.3	31.4	31.7	32.6	32.5	32.1	33.4	33.2	33.7	33.1	32.2	30.8	29.3	27.4	24.3	21.7	19.9	19.0	18.3	16.8


Table C.04 Detailed measurement uncertainty at hub height


Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement


Report ID: 13259.00.T38.RP1


Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																Overall														
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630		800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
10.5	Turbine ON	10.47	21	Average (dBA)	16.9	21.6	24.8	28.7	32.1	35.4	37.5	39.7	42.3	42.6	42.7	44.4	44.6	44.8	49.5	47.4	48.1	48.2	47.9	47.5	46.6	45.9	42.8	40.5	41.2	34.0	35.2	33.9	58.4		
				Uncertainty A (dB)	0.5	0.3	0.4	0.3	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.3	0.4	0.4		0.4	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		0.8	1.4
				Combined Uncertainty (dB)	1.1	1.1	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9		0.9	1.5
	Background	10.57	12	Average (dBA)	18.9	22.4	24.6	26.1	25.9	28.7	28.5	32.0	31.3	33.2	33.8	34.9	34.7	34.5	35.5	35.5	36.3	35.4	34.5	33.3	31.9	30.2	27.2	24.3	22.5	20.9	19.4	17.8	46.3		
Uncertainty A (dB)				4.0	3.5	3.2	2.7	1.7	0.7	1.3	1.7	0.9	0.6	0.7	1.0	1.3	1.3	1.2	1.2	1.2	1.1	1.2	1.3	1.5	1.5	1.5	1.4	1.3	1.0	0.7	0.6				
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
Combined Uncertainty (dB)				4.2	3.7	3.3	2.8	1.9	1.0	1.6	1.9	1.2	1.0	1.0	1.2	1.4	1.5	1.4	1.4	1.4	1.3	1.4	1.5	1.6	1.7	1.7	1.6	1.5	1.3	1.1	1.6				
11.0	Turbine ON	11.03	45	Average (dBA)	17.8	22.5	25.3	29.0	32.7	35.7	37.8	39.9	42.3	42.7	42.7	44.3	44.0	44.2	49.4	46.9	47.7	48.0	47.8	47.6	46.7	45.8	42.7	40.2	40.2	33.3	34.2	32.9	58.2		
				Uncertainty A (dB)	0.3	0.2	0.2	0.2	0.2	0.1	0.2	0.2	0.1	0.1	0.1	0.1	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.3	0.3		0.3	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		1.4	
				Combined Uncertainty (dB)	1.1	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9		0.9	1.5
	Background	11.01	23	Average (dBA)	19.2	22.7	24.3	26.0	27.5	28.3	29.4	30.1	31.2	32.8	33.2	35.0	34.8	34.5	35.5	35.4	35.9	35.4	34.6	33.4	32.0	30.3	27.3	24.9	25.2	22.1	20.2	18.2	46.2		
Uncertainty A (dB)				2.3	2.2	2.0	1.8	1.4	0.8	1.0	0.8	0.5	0.5	0.5	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.8	1.0	1.0	1.0	1.0	0.9	1.2	0.8	0.6	0.5				
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
Combined Uncertainty (dB)				2.5	2.4	2.1	1.9	1.6	1.1	1.3	1.1	1.0	1.0	0.9	1.0	1.1	1.1	1.0	1.0	1.0	1.0	1.0	1.1	1.1	1.2	1.3	1.3	1.2	1.5	1.1	1.0	1.5			
11.5	Turbine ON	11.49	77	Average (dBA)	18.1	22.8	25.5	29.1	32.6	35.9	38.1	39.9	42.3	42.8	42.7	44.4	44.0	44.2	49.3	46.9	47.7	48.0	47.9	47.6	46.8	46.0	42.8	40.3	40.5	33.7	34.7	33.4	58.3		
				Uncertainty A (dB)	0.3	0.2	0.2	0.2	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2		0.2	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		1.4	
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		1.5	
	Background	11.51	24	Average (dBA)	16.8	19.0	21.3	22.9	24.0	27.8	27.4	31.1	31.3	33.4	33.6	34.5	34.3	34.3	35.3	35.1	35.8	35.4	34.5	33.3	31.9	30.0	26.9	24.1	22.8	22.9	21.3	18.5	46.0		
Uncertainty A (dB)				2.0	1.7	1.5	1.3	0.8	0.4	0.6	0.8	0.4	0.2	0.3	0.6	0.7	0.7	0.6	0.7	0.6	0.6	0.7	0.8	0.9	0.9	0.9	0.8	0.8	0.9	1.0	0.8	0.6			
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
Combined Uncertainty (dB)				2.2	2.0	1.7	1.5	1.1	0.9	1.0	1.1	0.9	0.8	0.8	0.9	1.0	1.0	0.9	1.0	0.9	0.9	1.0	1.1	1.1	1.1	1.1	1.2	1.2	1.1	1.2	1.3	1.1		1.6	
12.0	Turbine ON	12.01	58	Average (dBA)	17.3	22.5	25.3	28.9	33.6	36.4	37.8	39.9	42.2	42.7	42.7	44.2	43.8	43.9	49.1	46.6	47.5	47.9	47.8	47.7	46.9	46.2	42.9	40.6	41.0	34.2	35.3	33.9	58.2		
				Uncertainty A (dB)	0.3	0.2	0.2	0.2	0.4	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2		0.2	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		1.4	
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.9	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		1.5	
	Background	12.05	13	Average (dBA)	19.8	23.2	23.3	25.0	26.9	28.4	29.8	32.2	32.1	33.3	34.2	35.8	36.1	36.0	37.3	36.9	37.9	37.2	36.3	35.0	33.7	31.8	28.6	25.7	23.5	22.1	20.8	18.9	47.6		
Uncertainty A (dB)				2.4	2.3	1.9	1.6	1.3	0.8	0.9	1.1	0.6	0.5	0.5	0.7	0.9	0.9	0.7	0.7	0.7	0.7	0.8	0.7	0.8	1.0	1.1	1.1	1.0	0.9	0.9	0.8	0.7			
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
Combined Uncertainty (dB)				2.6	2.5	2.1	1.8	1.6	1.1	1.2	1.4	1.0	0.9	0.9	1.0	1.1	1.1	1.0	1.0	1.0	1.0	1.1	1.2	1.3	1.4	1.4	1.3	1.2	1.2	1.1	1.6				
12.5	Turbine ON	12.52	52	Average (dBA)	18.8	23.4	26.4	29.5	32.7	35.9	38.0	39.9	42.1	42.7	42.6	44.0	43.7	43.8	49.4	46.5	47.4	47.8	47.7	47.6	46.8	46.0	42.7	40.3	40.7	33.9	34.9	33.7	58.1		
				Uncertainty A (dB)	0.4	0.3	0.4	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3			
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		1.4	
				Combined Uncertainty (dB)	1.1	1.1	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8		1.5	
	Background	12.50	19	Average (dBA)	20.2	24.3	26.9	28.1	29.3	29.7	31.1	32.0	33.4	34.1	35.0	36.7	36.9	37.0	37.9	37.9	38.7	37.9	37.1	35.9	34.6	32.9	30.0	27.5	25.5	23.9	22.4	20.3	48.5		
Uncertainty A (dB)				1.8	1.9	1.9	1.6	1.2	0.8	0.7	0.7	0.5	0.4	0.4	0.5	0.5	0.6	0.5	0.6	0.6	0.5	0.6	0.6	0.7	0.7	0.7	0.8	0.9	1.1	1.1	1.0	0.9			
Uncertainty B (dB)				1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
Combined Uncertainty (dB)				2.1	2.2	2.1	1.8	1.4	1.1	1.1	1.0	1.0	0.9	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.0	1.1	1.2	1.2	1.3	1.4	1.3		1.7	


Appendix D Tonality Assessment


























Table D.01 Tonality Assessment Table - 8.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 1
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
225	501			30.9	49.9	47.6	-2.2	-2.3	0.1
407	504			30.2	49.2	46.5	-2.6	-2.3	-0.3
71	506			31.2	50.1	47.3	-2.8	-2.3	-0.5
410	507			31.1	50.0	46.3	-3.7	-2.3	-1.4
137	507			29.7	48.7	45.7	-2.9	-2.3	-0.6
145	508			30.0	48.9	44.8	-4.1	-2.3	-1.8
420	508			31.3	50.3	44.5	-5.7	-2.3	-3.4
38	509			30.2	49.2	49.8	0.6	-2.3	2.9
474	509			32.2	51.2	46.9	-4.3	-2.3	-2.0
70	510			30.9	49.9	46.4	-3.5	-2.3	-1.2
579	511			33.0	52.0	40.6	-11.4	-2.3	-9.1
11	511			30.2	49.2	49.5	0.3	-2.3	2.6
136	514			30.8	49.8	47.3	-2.5	-2.3	-0.2
39	517			30.5	49.5	49.0	-0.5	-2.3	1.8
405	518			31.6	50.6	43.7	-6.8	-2.3	-4.5
126	529			31.1	50.1	38.1	-12.0	-2.3	-9.7
Average	511						-3.0	-2.3	-0.6

Table D.02 Tonality Assessment Table - 9 m/s

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 1
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
6	476			30.1	49.0	45.2	-3.8	-2.3	-1.5
732	484			30.3	49.2	43.1	-6.0	-2.3	-3.7
473	487			30.2	49.1	45.6	-3.4	-2.3	-1.1
132	487			30.3	49.2	45.8	-3.4	-2.3	-1.2
69	499			30.7	49.6	45.2	-4.4	-2.3	-2.1
393	502			31.3	50.3	45.4	-4.8	-2.3	-2.5
402	504			31.4	50.3	40.4	-9.9	-2.3	-7.6
449	504			30.3	49.2	49.2	-0.1	-2.3	2.2
578	505			31.9	50.9	43.6	-7.3	-2.3	-5.0
143	506			31.5	50.4	42.0	-8.3	-2.3	-6.0
10	506			30.0	48.9	49.8	0.9	-2.3	3.2
37	506			30.7	49.7	47.3	-2.4	-2.3	-0.1
403	507			31.1	50.1	46.3	-3.8	-2.3	-1.5
394	508			32.0	50.9	49.6	-1.3	-2.3	1.0
418	508			30.2	49.1	49.7	0.6	-2.3	2.9
581	508			32.4	51.3	50.0	-1.4	-2.3	0.9
73	508			31.2	50.2	52.1	1.9	-2.3	4.2
222	508			31.4	50.4	51.5	1.1	-2.3	3.4
476	509			31.8	50.8	47.4	-3.4	-2.3	-1.1
219	509			32.1	51.1	48.1	-2.9	-2.3	-0.6
144	510			30.4	49.4	47.3	-2.1	-2.3	0.2
40	511			30.6	49.5	48.5	-1.0	-2.3	1.3
408	511			31.2	50.2	44.5	-5.7	-2.3	-3.4
409	512			30.6	49.6	50.8	1.2	-2.3	3.5
135	513			31.0	49.9	42.8	-7.1	-2.3	-4.8
Average	504						-2.1	-2.3	0.2

Table D.03 Tonality Assessment Table - 9.5 m/s

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 1
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
24	483			30.7	49.6	46.7	-2.9	-2.3	-0.7
574	483			32.3	51.2	40.5	-10.7	-2.3	-8.4
99	487			31.4	50.3	49.5	-0.8	-2.3	1.5
27	487			31.6	50.5	48.2	-2.4	-2.3	-0.1
60	489			30.2	49.1	48.6	-0.5	-2.3	1.8
34	491			30.9	49.8	45.3	-4.5	-2.3	-2.2
554	493			31.8	50.7	47.4	-3.3	-2.3	-1.0
218	494			31.8	50.7	42.5	-8.2	-2.3	-5.9
390	497			30.9	49.8	45.2	-4.6	-2.3	-2.4
716	501			31.2	50.2	46.0	-4.1	-2.3	-1.8
567	505			32.0	51.0	48.7	-2.3	-2.3	0.1
556	505			32.6	51.5	47.8	-3.8	-2.3	-1.5
448	507			30.6	49.6	48.6	-0.9	-2.3	1.4
9	508			30.1	49.1	53.0	3.9	-2.3	6.2
557	508			32.5	51.4	50.5	-1.0	-2.3	1.3
140	509			31.0	50.0	49.5	-0.4	-2.3	1.9
391	509			32.1	51.0	46.1	-5.0	-2.3	-2.7
422	509			32.2	51.1	54.3	3.1	-2.3	5.4
735	510			31.5	50.5	51.6	1.1	-2.3	3.4
423	511			31.8	50.7	51.6	0.9	-2.3	3.2
134	511			30.9	49.8	49.5	-0.4	-2.3	1.9
84	511			31.0	50.0	47.0	-2.9	-2.3	-0.6
452	512			31.3	50.3	51.7	1.4	-2.3	3.7
417	512			31.1	50.0	49.0	-1.0	-2.3	1.3
Average	501						-1.0	-2.3	1.3

Table D.04 Tonality Assessment Table - 10 m/s

Project: Summerhaven Wind Energy Centre- Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 1
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
76	506			30.9	49.8	51.5	1.7	-2.3	4.0
413	508			29.5	48.4	51.0	2.6	-2.3	4.9
361	509			32.5	51.5	41.1	-10.4	-2.3	-8.1
85	510			30.6	49.6	49.1	-0.5	-2.3	1.8
396	510			32.3	51.3	46.6	-4.7	-2.3	-2.4
75	510			30.9	49.9	49.6	-0.2	-2.3	2.1
61	511			31.4	50.3	49.5	-0.8	-2.3	1.5
411	514			30.4	49.4	49.7	0.2	-2.3	2.6
123	514			31.8	50.7	51.6	0.9	-2.3	3.2
119	515			33.2	52.2	47.3	-4.9	-2.3	-2.6
86	515			31.1	50.1	51.4	1.3	-2.3	3.6
74	516			31.0	50.0	49.5	-0.5	-2.3	1.9
734	517			31.5	50.5	50.1	-0.4	-2.3	1.9
576	518			32.4	51.4	43.8	-7.6	-2.3	-5.3
477	519			32.0	51.0	47.3	-3.7	-2.3	-1.4
568	520			32.2	51.2	48.2	-3.0	-2.3	-0.7
582	522			32.9	51.9	47.1	-4.9	-2.3	-2.5
718	535			32.0	51.1	45.3	-5.7	-2.3	-3.4
Average	515						-1.1	-2.3	1.2

Table D.05 Tonality Assessment Table - 10.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 1
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
118	485			31.0	49.9	50.4	0.6	-2.3	2.9
68	494			30.1	49.0	46.8	-2.2	-2.3	0.1
441	500			30.8	49.8	47.9	-1.8	-2.3	0.5
296	504			32.4	51.3	47.5	-3.8	-2.3	-1.5
569	508			32.3	51.2	47.9	-3.4	-2.3	-1.1
719	508			30.7	49.7	48.7	-0.9	-2.3	1.4
180	508			32.5	51.4	45.7	-5.7	-2.3	-3.4
94	508			30.7	49.6	49.2	-0.5	-2.3	1.8
515	509			31.1	50.1	50.8	0.8	-2.3	3.1
560	510			32.2	51.1	48.0	-3.1	-2.3	-0.8
120	510			30.4	49.4	51.5	2.1	-2.3	4.4
720	513			30.6	49.6	52.6	3.0	-2.3	5.3
721	514			31.5	50.5	47.3	-3.2	-2.3	-0.9
722	514			32.3	51.3	46.3	-4.9	-2.3	-2.6
Average	506						-0.9	-2.3	1.4

Table D.06 Tonality Assessment Table - 11 m/s

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 1
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
430	503			30.1	49.1	49.1	0.0	-2.3	2.3
573	504			31.1	50.0	52.6	2.6	-2.3	4.9
605	506			30.7	49.7	48.4	-1.3	-2.3	1.0
59	507			29.8	48.8	50.7	2.0	-2.3	4.3
657	509			32.1	51.0	50.4	-0.6	-2.3	1.7
22	509			28.5	47.4	53.8	6.4	-2.3	8.7
49	509			30.8	49.8	49.5	-0.3	-2.3	2.1
117	509			29.8	48.8	46.8	-2.0	-2.3	0.3
607	510			30.7	49.7	52.7	3.0	-2.3	5.4
67	511			30.3	49.3	51.3	2.0	-2.3	4.3
464	511			29.8	48.8	49.4	0.6	-2.3	2.9
468	511			30.2	49.1	49.2	0.1	-2.3	2.4
442	511			31.5	50.5	48.9	-1.6	-2.3	0.7
384	511			31.4	50.4	52.1	1.7	-2.3	4.0
95	511			30.6	49.6	50.7	1.1	-2.3	3.4
360	511			31.7	50.7	53.1	2.4	-2.3	4.8
644	512			30.8	49.8	51.0	1.2	-2.3	3.5
611	512			30.4	49.4	51.8	2.4	-2.3	4.7
178	513			31.8	50.8	49.6	-1.1	-2.3	1.2
98	513			31.0	49.9	49.0	-0.9	-2.3	1.4
51	513			29.3	48.3	49.0	0.7	-2.3	3.0
553	513			31.6	50.5	48.6	-1.9	-2.3	0.4
552	513			31.5	50.5	50.1	-0.4	-2.3	1.9
161	514			30.1	49.1	49.0	-0.1	-2.3	2.2
52	515			29.1	48.1	50.1	2.0	-2.3	4.3
115	517			30.1	49.0	50.5	1.4	-2.3	3.8
21	517			30.1	49.0	51.2	2.2	-2.3	4.5
29	517			29.2	48.2	48.5	0.4	-2.3	2.7
637	518			30.3	49.3	47.3	-2.0	-2.3	0.4
416	518			30.4	49.4	48.8	-0.6	-2.3	1.8
106	518			28.8	47.8	48.0	0.2	-2.3	2.5
606	518			30.6	49.6	49.5	-0.1	-2.3	2.2
20	518			30.9	49.9	46.9	-3.0	-2.3	-0.7
114	518			30.4	49.4	48.4	-1.0	-2.3	1.3
3	519			29.0	48.0	49.3	1.3	-2.3	3.6
478	520			29.8	48.8	46.3	-2.5	-2.3	-0.2
677	520			31.8	50.8	48.5	-2.3	-2.3	0.0
102	521			28.7	47.7	46.7	-1.0	-2.3	1.3
454	523			30.3	49.3	43.7	-5.6	-2.3	-3.3
495	524			30.1	49.1	47.7	-1.4	-2.3	1.0
558	525			32.3	51.3	49.2	-2.1	-2.3	0.3
176	526			32.9	51.9	41.1	-10.7	-2.3	-8.4
141	528			31.3	50.3	45.8	-4.5	-2.3	-2.2
Average	515						0.4	-2.3	2.7

Table D.07 Tonality Assessment Table - 11.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 2
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
48	500			29.8	48.8	48.7	-0.1	-2.3	2.2
387	503			31.0	49.9	49.7	-0.2	-2.3	2.1
444	504			29.9	48.8	47.0	-1.8	-2.3	0.5
112	505			28.9	47.8	50.9	3.1	-2.3	5.4
681	506			30.8	49.8	50.8	1.0	-2.3	3.3
676	507			31.0	49.9	52.2	2.3	-2.3	4.6
593	508			31.1	50.1	48.2	-1.9	-2.3	0.4
532	508			30.3	49.2	51.6	2.3	-2.3	4.6
400	508			29.5	48.4	50.0	1.5	-2.3	3.8
603	508			31.1	50.1	45.0	-5.1	-2.3	-2.8
159	508			28.4	47.3	47.1	-0.2	-2.3	2.1
306	508			33.3	52.3	45.0	-7.2	-2.3	-4.9
533	508			31.8	50.7	51.0	0.3	-2.3	2.6
388	508			32.0	50.9	48.5	-2.4	-2.3	-0.1
594	508			31.8	50.7	50.0	-0.7	-2.3	1.6
5	509			29.4	48.4	49.9	1.5	-2.3	3.8
32	510			29.9	48.9	49.0	0.1	-2.3	2.4
514	510			31.0	50.0	44.0	-6.0	-2.3	-3.7
512	510			31.7	50.7	51.9	1.2	-2.3	3.5
217	510			31.7	50.7	53.7	3.0	-2.3	5.3
323	510			30.6	49.5	45.6	-3.9	-2.3	-1.6
104	512			28.2	47.2	50.9	3.7	-2.3	6.0
435	512			28.8	47.8	50.7	3.0	-2.3	5.3
262	512			30.2	49.2	51.2	2.0	-2.3	4.3
426	512			31.6	50.5	48.2	-2.3	-2.3	0.0
493	512			29.2	48.1	49.3	1.1	-2.3	3.4
33	512			29.9	48.8	48.7	-0.1	-2.3	2.2
182	513			31.5	50.5	50.3	-0.1	-2.3	2.2
600	513			30.7	49.7	48.7	-1.0	-2.3	1.4
544	513			30.5	49.5	51.1	1.6	-2.3	4.0
295	513			32.6	51.5	48.7	-2.8	-2.3	-0.5
456	513			28.5	47.5	49.0	1.5	-2.3	3.8
728	513			32.0	50.9	50.4	-0.5	-2.3	1.8
297	514			32.3	51.3	52.3	1.0	-2.3	3.3
157	514			28.7	47.7	50.4	2.7	-2.3	5.0
19	514			30.1	49.1	48.4	-0.7	-2.3	1.6
428	514			29.7	48.7	51.1	2.5	-2.3	4.8
56	514			29.1	48.1	50.4	2.3	-2.3	4.6
111	515			29.0	47.9	48.2	0.3	-2.3	2.6
443	515			29.8	48.8	47.9	-0.9	-2.3	1.4
507	515			29.9	48.9	49.7	0.9	-2.3	3.2
54	515			29.1	48.1	51.4	3.4	-2.3	5.7
216	516			31.3	50.2	52.0	1.8	-2.3	4.1
294	516			32.1	51.1	49.5	-1.7	-2.3	0.7
66	516			29.7	48.7	46.5	-2.2	-2.3	0.1
383	516			30.8	49.7	50.0	0.3	-2.3	2.6
398	516			29.9	48.8	47.9	-0.9	-2.3	1.4
612	516			30.2	49.2	49.7	0.5	-2.3	2.8
57	517			28.8	47.7	51.2	3.5	-2.3	5.8
647	517			30.6	49.6	50.8	1.2	-2.3	3.5
725	517			30.3	49.3	47.1	-2.3	-2.3	0.1
255	518			30.9	49.9	49.8	-0.1	-2.3	2.2
377	518			30.3	49.2	48.5	-0.7	-2.3	1.6
724	518			30.2	49.1	49.9	0.8	-2.3	3.1
177	518			32.5	51.5	48.6	-2.8	-2.3	-0.5
308	518			32.3	51.3	48.4	-2.9	-2.3	-0.6
655	518			31.7	50.7	46.0	-4.7	-2.3	-2.4
652	519			32.0	51.0	46.4	-4.6	-2.3	-2.3
90	519			28.4	47.3	47.9	0.5	-2.3	2.9
682	519			32.6	51.6	48.7	-2.9	-2.3	-0.6
673	520			31.7	50.7	47.3	-3.4	-2.3	-1.1
190	520			30.3	49.3	48.0	-1.3	-2.3	1.1
18	521			31.3	50.3	51.1	0.8	-2.3	3.1
87	521			30.3	49.3	47.6	-1.6	-2.3	0.7
307	521			32.1	51.1	49.1	-2.0	-2.3	0.4
379	522			31.2	50.2	47.9	-2.2	-2.3	0.1
671	522			30.8	49.8	48.0	-1.8	-2.3	0.5

Table D.07 Tonality Assessment Table - 11.5 m/s

Project: Summerhaven Wind Energy Centre- Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 2 of 2
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
707	522			30.8	49.7	47.4	-2.3	-2.3	0.0
96	523			31.1	50.1	49.4	-0.7	-2.3	1.6
50	523			29.9	48.9	44.7	-4.2	-2.3	-1.9
17	524			31.1	50.1	48.9	-1.2	-2.3	1.1
101	525			30.7	49.7	46.7	-3.0	-2.3	-0.6
41	527			30.2	49.2	46.7	-2.4	-2.3	-0.1
471	527			29.0	48.0	47.5	-0.5	-2.3	1.9
465	527			30.2	49.2	49.2	0.0	-2.3	2.3
Average	515						0.1	-2.3	2.4

Table D.08 Tonality Assessment Table - 12 m/s

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 1
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
91	504			28.6	47.5	47.1	-0.4	-2.3	1.9
324	505			30.5	49.4	50.0	0.6	-2.3	2.9
536	506			29.6	48.5	49.6	1.1	-2.3	3.4
193	508			29.8	48.7	49.9	1.2	-2.3	3.5
149	508			29.2	48.1	51.1	3.0	-2.3	5.3
46	508			28.9	47.8	47.9	0.1	-2.3	2.4
429	508			30.8	49.7	52.7	3.0	-2.3	5.3
610	508			30.4	49.3	50.5	1.2	-2.3	3.5
648	508			30.3	49.3	53.1	3.8	-2.3	6.1
462	510			31.0	50.0	45.4	-4.5	-2.3	-2.2
113	510			30.4	49.3	50.2	0.9	-2.3	3.2
467	510			29.2	48.2	49.8	1.7	-2.3	4.0
713	510			31.3	50.2	50.7	0.5	-2.3	2.8
4	512			29.0	47.9	50.3	2.3	-2.3	4.7
58	512			28.6	47.5	49.3	1.8	-2.3	4.1
267	512			31.4	50.4	50.9	0.5	-2.3	2.8
726	512			30.5	49.5	45.5	-4.0	-2.3	-1.7
378	512			30.3	49.2	52.7	3.5	-2.3	5.8
160	512			29.3	48.3	48.2	-0.1	-2.3	2.2
382	512			29.5	48.4	50.7	2.3	-2.3	4.6
660	512			30.1	49.1	48.7	-0.3	-2.3	2.0
527	512			30.0	49.0	47.5	-1.5	-2.3	0.8
130	513			30.1	49.0	50.9	1.9	-2.3	4.2
739	513			29.5	48.5	51.4	2.9	-2.3	5.2
741	513			29.7	48.7	50.3	1.6	-2.3	3.9
414	513			29.8	48.7	50.5	1.8	-2.3	4.1
737	514			30.8	49.8	46.8	-2.9	-2.3	-0.6
731	514			31.2	50.2	48.4	-1.9	-2.3	0.5
53	515			28.7	47.6	48.5	0.9	-2.3	3.2
659	515			30.1	49.1	51.0	1.9	-2.3	4.2
729	516			29.7	48.7	44.3	-4.4	-2.3	-2.1
590	516			32.0	51.0	42.9	-8.1	-2.3	-5.7
626	517			30.6	49.6	49.5	-0.1	-2.3	2.2
447	517			30.8	49.8	47.5	-2.2	-2.3	0.1
608	518			30.7	49.7	50.4	0.6	-2.3	3.0
463	518			29.6	48.6	51.0	2.4	-2.3	4.8
399	518			29.6	48.6	47.5	-1.1	-2.3	1.2
592	518			30.6	49.5	47.1	-2.5	-2.3	-0.2
184	518			30.4	49.3	48.8	-0.6	-2.3	1.8
715	519			31.8	50.8	50.1	-0.6	-2.3	1.7
723	519			29.6	48.6	46.2	-2.4	-2.3	0.0
658	519			31.1	50.1	46.7	-3.4	-2.3	-1.1
480	520			29.4	48.4	47.6	-0.8	-2.3	1.5
584	521			31.3	50.3	46.5	-3.8	-2.3	-1.4
309	521			31.0	50.0	48.3	-1.6	-2.3	0.7
431	521			31.0	50.0	49.6	-0.4	-2.3	1.9
562	521			30.9	49.9	50.5	0.6	-2.3	2.9
128	522			31.2	50.2	49.9	-0.3	-2.3	2.0
683	522			30.5	49.5	49.1	-0.4	-2.3	1.9
129	524			30.0	49.0	48.4	-0.6	-2.3	1.7
436	524			29.0	48.0	50.4	2.4	-2.3	4.7
415	525			30.4	49.4	46.7	-2.7	-2.3	-0.4
621	526			31.7	50.7	51.8	1.1	-2.3	3.4
181	526			32.1	51.1	38.2	-12.9	-2.3	-10.6
427	528			30.8	49.8	46.9	-2.8	-2.3	-0.5
Average	515						0.3	-2.3	2.6

Table D.09 Tonality Assessment Table - 12.5 m/s

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 1
 Created on: 1/5/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
313	502			31.4	50.3	47.0	-3.4	-2.3	-1.1
320	504			30.9	49.9	49.0	-0.9	-2.3	1.4
472	504			30.0	48.9	50.2	1.3	-2.3	3.6
191	506			32.1	51.0	49.4	-1.6	-2.3	0.7
266	507			31.2	50.1	48.0	-2.1	-2.3	0.2
529	507			29.8	48.7	52.5	3.8	-2.3	6.1
357	507			29.1	48.1	49.1	1.1	-2.3	3.4
376	508			29.6	48.5	52.5	4.0	-2.3	6.3
566	508			31.2	50.2	52.7	2.6	-2.3	4.9
672	508			30.5	49.4	50.7	1.2	-2.3	3.5
434	509			28.7	47.7	50.5	2.9	-2.3	5.2
509	509			30.6	49.5	51.6	2.1	-2.3	4.4
189	509			30.9	49.8	51.2	1.4	-2.3	3.7
23	509			29.5	48.4	49.8	1.4	-2.3	3.7
80	510			28.2	47.1	50.2	3.1	-2.3	5.4
712	510			30.9	49.9	47.6	-2.3	-2.3	0.0
679	510			32.6	51.5	46.9	-4.6	-2.3	-2.3
479	511			29.4	48.4	48.8	0.4	-2.3	2.7
645	511			30.8	49.8	51.3	1.5	-2.3	3.8
572	511			30.5	49.5	51.2	1.7	-2.3	4.0
110	511			29.1	48.0	50.5	2.5	-2.3	4.8
669	512			31.8	50.8	45.7	-5.1	-2.3	-2.8
381	512			29.1	48.1	50.0	1.9	-2.3	4.2
268	512			30.1	49.1	47.4	-1.7	-2.3	0.6
273	513			30.5	49.4	48.6	-0.9	-2.3	1.5
401	513			30.3	49.3	49.9	0.6	-2.3	2.9
299	513			31.5	50.5	41.6	-8.9	-2.3	-6.6
542	513			29.3	48.3	51.2	3.0	-2.3	5.3
638	513			30.2	49.2	48.8	-0.4	-2.3	1.9
103	513			28.2	47.2	48.3	1.1	-2.3	3.4
505	514			30.0	49.0	51.1	2.1	-2.3	4.4
633	514			30.8	49.7	50.6	0.8	-2.3	3.1
738	514			29.3	48.2	47.8	-0.4	-2.3	1.9
358	514			29.9	48.8	48.8	0.0	-2.3	2.3
109	515			27.9	46.9	50.8	3.9	-2.3	6.2
730	515			30.4	49.3	50.4	1.1	-2.3	3.4
162	517			30.5	49.4	51.2	1.8	-2.3	4.1
492	517			29.4	48.4	50.7	2.3	-2.3	4.6
304	517			31.2	50.2	49.8	-0.3	-2.3	2.0
30	518			29.0	48.0	49.4	1.4	-2.3	3.7
64	518			28.6	47.6	50.7	3.1	-2.3	5.5
711	518			30.2	49.2	49.8	0.7	-2.3	3.0
675	518			30.9	49.9	52.0	2.2	-2.3	4.5
79	518			28.2	47.2	48.2	1.0	-2.3	3.3
599	519			31.1	50.1	47.4	-2.7	-2.3	-0.3
528	520			29.6	48.6	47.1	-1.5	-2.3	0.8
667	522			30.7	49.7	46.4	-3.3	-2.3	-1.0
634	523			30.5	49.5	48.1	-1.5	-2.3	0.9
545	524			29.8	48.8	51.4	2.6	-2.3	4.9
744	526			30.2	49.2	47.8	-1.4	-2.3	0.9
25	527			31.3	50.3	47.8	-2.5	-2.3	-0.2
Average	513						0.9	-2.3	3.2

Appendix E Measurement Data

Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 5
 Created on: 1/5/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
1	13.0	56.8	2233	270.5	262.5	5.5	15.5	11.9	9.7	8	97567.7	53
2	13.0	57.3	2236	270.5	262.4	3.6	15.5	11.7	8.0	8	97567.2	53
3	10.8	57.1	2231	270.5	262.5	2.3	15.5	9.8	9.3	8	97566.1	53
4	12.1	57.1	2231	270.5	262.4	2.7	15.5	11.0	10.7	8	97565.1	53
5	11.4	57.2	2221	270.5	262.5	0.3	15.4	10.4	9.5	8	97564.4	53
6	9.1	56.8	1641	270.5	262.4	-1.8	14.6	7.7	9.4	8	97559.6	53
7	8.2	57.2	1211	270.5	263.1	-2.5	15.0	8.2	9.3	8	97155.8	53
8	8.8	57.7	1513	270.5	265.3	-2.3	15.6	8.2	9.0	8	97240.0	53
9	9.7	57.9	1877	270.5	266.1	-1.8	15.5	8.5	8.8	8	97347.8	53
10	9.9	57.3	1563	270.5	265.2	-2.4	15.2	9.0	8.0	8	97501.1	53
11	8.7	57.4	1440	270.5	268.3	-2.5	15.3	8.6	8.6	8	97563.6	53
12	8.1	56.2	1162	270.5	266.3	-2.5	14.8	8.1	8.3	8	97566.1	53
13	8.0	56.8	1148	270.5	266.3	-2.5	14.8	7.5	6.5	8	97566.2	53
14	8.9	58.1	1567	270.5	266.3	-2.4	15.6	9.0	6.7	8	97564.0	54
15	9.4	57.4	1771	270.5	268.3	-2.2	15.6	9.1	7.2	8	97565.0	54
16	10.4	58.3	2067	270.5	268.3	-1.3	15.6	9.8	7.6	8	97564.6	54
17	11.4	58.2	2235	270.5	266.3	-0.6	15.7	10.5	7.2	8	97564.0	54
18	11.3	58.8	2237	270.5	266.3	0.0	15.7	10.4	8.3	8	97564.3	54
19	11.3	58.0	2235	270.5	266.3	-0.4	15.5	10.3	9.3	8	97563.7	54
20	10.9	58.1	2245	270.5	266.3	0.4	15.6	10.0	11.0	8	97539.5	52
21	11.0	57.9	2235	270.5	266.3	1.6	15.5	10.1	11.5	8	97540.4	52
22	11.1	57.6	2230	270.5	266.3	2.9	15.5	10.2	10.9	8	97541.1	52
23	12.3	57.6	2236	270.5	266.3	1.3	15.4	11.3	10.7	8	97541.2	52
24	9.7	57.4	1900	270.5	266.3	-1.7	14.8	9.1	11.2	8	97541.3	52
25	12.3	58.2	2170	270.5	266.4	1.6	15.8	11.3	11.1	8	97541.6	52
26	13.1	57.6	2227	270.5	266.5	0.8	15.4	12.0	12.2	8	97552.5	51
27	9.5	57.9	1762	270.5	266.4	-1.3	14.9	9.3	11.7	8	97550.0	51
28	10.8	57.1	2209	270.5	266.4	0.0	15.9	9.6	9.8	8	97442.3	51
29	10.8	57.1	2230	270.5	266.4	4.5	15.8	9.9	9.2	8	96283.3	51
30	12.3	56.9	2229	270.5	266.4	2.7	15.5	11.2	8.4	8	96213.7	51
31	11.5	57.4	2221	270.5	263.8	1.2	15.5	9.4	10.9	8	96203.8	51
32	11.5	57.1	2226	270.5	264.5	0.2	15.5	10.5	8.0	8	96131.5	53
33	11.5	57.4	2222	270.5	263.7	0.0	15.4	10.5	8.3	8	95982.7	53
34	9.5	57.4	1814	270.5	266.7	-1.9	14.8	8.7	8.7	8	95246.1	53
35	9.8	58.8	1488	270.5	263.7	-2.4	14.1	8.8	9.9	8	95300.0	53
36	9.3	58.0	1727	270.5	264.7	-2.2	15.6	8.2	9.0	8	97380.1	53
37	8.8	57.6	1527	270.5	267.3	-2.5	15.3	9.6	9.8	8	97562.8	53
38	8.3	57.7	1289	270.5	268.6	-2.5	15.2	8.6	10.4	8	97507.2	51
39	8.6	57.8	1422	270.5	268.7	-2.4	15.5	8.9	9.4	8	97380.6	51
40	8.9	58.2	1571	270.5	269.1	-2.3	15.7	8.7	9.0	8	97412.0	51
41	11.6	58.1	2169	270.5	271.1	1.2	15.9	10.6	8.0	8	97369.7	51
42	13.0	56.9	2234	270.5	273.1	1.4	15.6	9.8	8.5	8	97016.0	51
43	13.0	56.9	2237	270.5	273.4	5.6	15.8	11.9	7.5	8	96942.7	52
44	12.8	56.6	2221	270.5	273.4	6.6	15.4	11.7	9.0	8	97079.7	53
45	13.5	56.6	2235	270.5	273.4	4.6	15.5	12.4	9.3	8	96989.9	53
46	12.2	57.0	2232	270.5	273.4	2.9	15.4	11.2	9.8	8	97049.5	53
47	12.9	57.5	2221	270.5	273.4	0.4	15.4	11.8	10.3	8	97106.8	53
48	11.5	57.4	2181	270.5	273.4	-0.9	15.2	10.5	10.1	8	97218.0	53
49	11.1	58.1	2203	270.5	273.4	-0.9	15.3	10.2	9.1	8	97203.4	53
50	11.6	57.3	2238	270.5	273.5	2.2	15.8	10.7	8.2	8	97147.3	52
51	10.8	57.2	2224	270.5	273.5	1.3	15.6	9.9	9.4	8	97061.5	52
52	11.2	57.1	2240	270.5	273.5	2.4	15.6	10.2	8.4	8	97253.7	52
53	12.2	56.8	2238	270.5	273.4	3.4	15.6	11.1	7.2	8	97409.1	52
54	11.5	57.3	2227	270.5	273.5	3.5	15.4	10.5	7.5	8	96678.9	52
55	11.6	57.0	2227	270.5	273.4	4.5	15.5	9.8	7.6	8	96844.4	52
56	11.6	57.0	2227	270.5	273.4	3.1	15.5	10.6	8.2	8	96891.2	53
57	11.7	57.0	2231	270.5	272.0	3.5	15.5	10.7	7.7	8	97063.0	53
58	11.8	56.8	2226	270.5	270.0	3.0	15.4	10.8	7.8	8	97572.8	53
59	11.0	57.4	2202	270.5	269.9	0.0	15.3	10.0	9.7	8	97574.1	53
60	9.6	56.9	1640	270.5	269.8	-1.9	14.9	9.4	14.8	8	97574.1	53
61	9.8	58.0	1915	270.5	268.2	-1.7	15.4	9.3	10.9	8	97573.9	53
62	10.3	58.1	2053	270.5	266.1	-1.4	15.5	10.4	10.6	8	97574.2	51
63	12.9	57.6	2240	270.5	266.7	1.0	15.9	11.8	10.6	8	97574.2	51
64	12.6	57.3	2236	270.5	265.7	4.4	15.7	11.5	10.6	8	97574.2	51
65	13.3	56.8	2070	270.5	265.7	2.9	15.4	12.1	8.4	8	97574.1	51
66	11.4	57.3	2232	270.5	265.7	1.8	15.5	10.4	10.1	8	97574.0	51
67	11.1	57.7	2225	270.5	265.7	-0.1	15.4	10.2	10.4	8	97573.1	51
68	10.5	57.1	2085	270.5	265.7	-1.1	15.0	10.5	10.8	8	97569.9	50
69	9.0	57.8	1578	270.5	265.7	-2.4	15.0	10.0	10.7	8	97569.3	50
70	8.4	58.0	1333	270.5	265.7	-2.5	15.2	7.6	10.4	8	97559.2	50
71	8.3	58.4	1260	270.5	266.4	-2.4	15.2	7.2	10.6	8	97559.4	50
72	9.0	58.4	1588	270.5	268.5	-2.3	15.7	8.6	9.1	8	97560.2	50
73	9.2	58.2	1702	270.5	269.3	-2.2	15.4	8.7	9.7	8	97560.1	50
74	9.8	58.2	1929	270.5	269.3	-1.7	15.6	9.1	10.4	8	97559.9	51
75	10.2	57.8	2047	270.5	269.4	-1.3	15.5	9.0	11.6	8	97560.1	51
76	10.0	57.9	1994	270.5	269.4	-1.5	15.4	9.3	11.4	8	97560.9	51
77	11.9	57.9	2226	270.5	269.4	-1.6	15.0	10.8	10.8	8	97561.0	51
78	13.1	56.9	2238	270.5	269.4	4.9	15.6	12.0	10.5	8	97560.8	51
79	12.7	56.8	2236	270.5	269.5	4.7	15.6	11.6	9.0	8	97560.4	51
80	12.7	56.8	2229	270.5	269.5	4.2	15.4	11.6	9.3	8	97560.8	50
81	9.9	57.9	2238	270.5	269.5	1.6	15.5	9.7	7.2	8	97560.0	50
82	9.9	57.4	2231	270.5	269.6	-0.1	15.5	9.6	8.8	8	97560.1	50
83	9.9	57.4	1971	270.5	269.5	-1.5	14.9	9.9	9.2	8	97561.0	50
84	9.4	57.9	1776	270.5	269.5	-2.1	15.2	9.9	10.7	8	97561.0	50
85	9.9	58.0	1949	270.5	269.5	-1.6	15.5	9.1	9.9	8	97560.7	50
86	10.1	58.2	2019	270.5	269.5	-1.5	15.5	8.9	17.4	8	97561.0	50
87	11.6	57.9	2232	270.5	269.6	0.6	15.8	10.6	10.0	8	97560.8	50
88	11.6	57.9	2242	270.5	269.6	1.6	15.7	9.8	10.4	8	97561.0	50

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
89	11.3	57.3	2227	270.5	269.8	3.1	15.6	10.4	9.7	8	97560.9	50
90	11.6	57.0	2239	270.5	270.3	4.4	15.6	10.6	9.7	8	97561.6	51
91	12.0	56.9	2207	270.5	272.5	2.6	15.3	11.0	9.8	8	97561.6	51
92	11.2	57.5	2235	270.5	273.0	2.0	15.6	10.3	9.1	8	97561.5	51
93	10.7	57.5	2208	270.5	273.0	0.4	15.3	8.2	10.0	8	97561.7	51
94	10.7	57.5	2129	270.5	273.0	-1.0	15.1	7.3	10.1	8	97561.6	51
95	11.0	58.0	2169	270.5	272.3	1.0	15.3	10.1	9.6	8	97561.1	51
96	11.5	58.2	2242	270.5	270.8	-0.2	15.7	10.5	9.6	8	97561.7	51
97	11.0	57.8	2231	270.5	270.7	1.5	15.6	9.3	10.6	8	97561.7	51
98	11.0	57.8	2227	270.5	270.7	-0.6	15.5	10.1	11.3	8	97561.7	51
99	9.7	57.9	1898	270.5	270.6	-1.7	15.0	7.8	10.7	8	97562.0	51
100	11.0	58.0	2226	270.5	269.							

Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 2 of 5
 Created on: 1/5/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
177	11.7	59.3	2241	270.5	260.1	0.2	15.7	10.7	11.7	8	97530.6	68
178	11.2	59.2	2220	270.5	260.1	2.3	15.5	10.2	11.5	8	97530.9	68
179			2212	270.5	260.1	-0.4	15.3	9.1	12.1	8	97530.3	69
180	10.7	58.8	2126	270.5	260.1	-1.0	15.2	8.9	11.7	8	97530.7	69
181	11.8	58.8	2239	270.5	260.1	2.8	15.8	10.8	11.0	8	97531.0	69
182	11.3	59.1	2229	270.5	260.1	1.3	15.5	10.3	10.9	8	97530.9	69
183			2245	270.5	260.1	2.4	15.7	9.2	11.8	8	97530.9	69
184	12.0	58.4	2233	270.5	260.1	4.6	15.6	11.0	12.8	8	97530.9	69
185	13.6	58.7	2230	270.5	260.1	5.5	15.4	12.4	14.5	8	97531.0	69
186	14.5	58.7	2237	270.5	260.1	7.9	15.8	13.3	13.5	8	97531.1	69
187	14.0	58.2	2232	270.5	260.1	8.8	15.5	12.8	11.9	8	97530.9	69
188	13.2	57.8	2218	270.5	260.1	6.5	15.3	12.1	13.1	8	97531.0	69
189	12.3	58.6	2220	270.5	260.1	4.4	15.5	11.2	12.1	8	97530.9	69
190	11.3	58.5	2231	270.5	260.3	6.3	15.6	10.3	11.5	8	97530.3	69
191	10.7	59.2	2191	270.5	260.3	2.0	15.2	11.6	10.4	8	97530.5	70
192	14.2	59.5	2228	270.5	260.3	6.6	16.0	13.0	13.0	8	97531.3	70
193	12.2	58.3	2220	270.5	260.3	8.9	15.4	11.2	9.5	8	97531.1	70
194	15.2	58.7	2231	270.5	260.6	9.2	15.5	13.9	10.0	8	97529.8	70
195	15.2	59.3	2230	270.5	262.7	9.7	15.6	13.9	9.9	8	97529.7	70
196	16.1	58.7	2229	270.5	263.9	10.6	15.5	14.7	9.3	7	97535.9	70
197	17.3	58.2	2216	270.5	263.9	10.4	15.8	10.8	7	97543.2	71	
198	14.1	58.1	2227	270.5	264.0	8.2	15.5	12.9	10.8	7	97544.5	71
199	14.5	58.7	2220	270.5	264.0	7.8	15.4	13.4	8.3	7	97544.6	71
200	14.6	58.6	2240	270.5	264.2	8.1	15.6	13.4	8.9	7	97544.6	71
201	13.5	58.8	2220	270.5	264.4	7.9	15.4	12.4	8.4	7	97544.5	71
202	14.8	58.3	2227	270.5	264.3	7.5	15.4	13.5	9.0	7	97544.5	71
203	14.4	58.6	2227	270.5	264.3	10.5	15.1	12.1	9.0	7	97544.7	71
204	13.4	58.1	2235	270.5	264.3	7.9	15.6	12.2	12.2	7	97544.6	71
205	15.5	58.9	2233	270.5	264.3	9.5	15.6	14.2	12.9	7	97543.6	71
206	15.3	58.5	2227	270.5	264.3	8.4	15.4	14.0	11.4	7	97543.5	71
207	13.9	58.9	2231	270.5	264.3	6.2	15.4	12.7	8.7	7	97542.7	71
208	12.8	58.5	2236	270.5	264.3	4.2	15.5	11.7	10.6	7	97542.6	71
209	13.3	58.2	2233	270.5	264.3	5.4	15.6	12.2	8.5	7	97543.4	71
210	13.3	58.2	2234	270.5	264.3	4.6	15.5	12.1	8.5	7	97544.7	71
211	14.3	58.7	2228	270.5	264.3	3.8	15.4	13.1	10.9	7	97544.6	71
212	12.8	58.9	2236	270.5	264.2	1.0	15.4	11.7	8.0	7	97544.9	71
213			2222	270.5	264.2	0.3	15.5	9.2	9.4	7	97544.6	72
214			2218	270.5	264.2	-0.5	15.4	9.6	9.3	7	97543.4	73
215			2238	270.5	264.2	2.3	15.6	9.6	8.3	7	97543.3	73
216	11.6	58.9	2225	270.5	264.2	1.5	15.5	10.7	8.0	7	97544.1	73
217	11.6	59.1	2220	270.5	264.2	0.6	15.4	10.6	7.4	7	97544.7	73
218	9.7	57.9	1877	270.5	264.2	-1.6	14.8	8.8	8.2	7	97544.8	73
219	9.0	58.4	1595	270.5	264.2	-2.4	15.2	7.9	7.8	7	97548.0	73
220	9.3	59.0	1726	270.5	264.2	-2.0	15.4	7.8	8.3	7	97538.7	73
221	9.5	59.1	1804	270.5	264.2	-2.0	15.4	9.0	8.0	7	97556.7	73
222	8.9	58.7	1552	270.5	264.2	-2.4	15.3	8.2	10.0	7	97556.1	73
223	9.6	59.1	1834	270.5	264.2	-2.0	15.7	9.2	9.4	7	97556.6	73
224	9.5	58.7	1808	270.5	264.2	-1.9	15.3	8.6	11.9	7	97556.6	73
225	8.5	58.3	1383	270.5	264.2	-2.5	15.2	8.1	11.2	7	97554.8	73
226	8.8	58.7	1494	270.5	264.2	-2.4	15.5	8.2	11.2	7	97545.1	73
227	9.6	59.0	1862	270.5	264.2	-1.9	15.7	9.1	11.1	7	97545.1	73
228	12.8	58.7	2225	270.5	264.2	2.8	16.0	11.7	10.6	7	97545.1	73
229	13.6	58.1	2229	270.5	264.2	5.1	15.8	12.4	9.8	7	97544.9	73
230	15.2	58.5	2245	270.5	264.2	9.4	15.8	13.9	9.2	7	97544.3	73
231	18.8	59.2	2239	270.5	264.2	12.0	15.7	17.2	9.6	7	97545.6	73
232	17.6	59.1	2234	270.5	264.2	11.7	15.5	16.1	8.9	7	97555.5	74
233	16.5	58.6	2207	270.5	264.2	10.1	15.4	15.1	8.4	7	97555.0	74
234	16.8	58.7	2240	270.5	264.2	11.9	15.7	15.4	8.7	7	97554.9	74
235	17.2	58.2	2223	270.5	264.2	11.7	15.4	15.8	10.4	7	97554.7	74
236	18.0	58.6	2240	270.5	264.2	12.0	15.5	16.5	9.7	7	97556.5	74
237	18.9	58.1	2247	270.5	264.2	13.7	15.7	17.3	8.7	7	97556.9	74
238	18.0	57.8	2203	270.5	264.2	12.4	15.3	16.4	8.2	7	97555.8	74
239	17.3	58.6	2234	270.5	264.2	12.3	15.6	15.8	10.2	7	97555.3	74
240	17.5	58.0	2206	270.5	264.2	13.5	15.5	16.0	11.2	7	97555.0	74
241	15.8	57.7	2192	270.5	264.2	9.2	15.2	14.4	12.0	7	97555.4	74
242	13.5	58.2	2227	270.5	264.2	7.1	15.6	12.4	12.6	7	97556.1	74
243	14.0	58.3	2212	270.5	264.1	5.4	15.4	12.8	14.4	7	97552.0	73
244	14.4	59.0	2233	270.5	264.1	6.4	15.9	13.2	14.4	7	97532.0	70
245	14.6	58.2	2237	270.5	264.2	6.8	15.5	13.4	12.2	7	97531.7	70
246	13.6	57.8	2224	270.5	264.3	7.0	15.4	12.5	11.8	7	97531.2	70
247	15.4	58.6	2233	270.5	264.2	8.7	15.5	14.1	10.3	7	97531.7	70
248	14.1	58.0	2206	270.5	264.2	7.1	15.3	12.9	10.6	7	97531.5	70
249	15.6	59.0	2238	270.5	264.2	7.8	15.8	14.3	11.8	7	97530.7	70
250	15.3	58.0	2224	270.5	264.2	9.2	15.4	11.0	11.0	7	97529.9	71
251	14.1	57.9	2226	270.5	264.2	8.3	15.4	12.9	9.6	7	97529.9	71
252	14.9	58.3	2229	270.5	264.2	6.9	15.4	13.6	8.8	7	97530.9	71
253	15.3	58.3	2239	270.5	264.2	6.9	15.4	14.0	9.5	7	97532.1	71
254	13.0	58.6	2230	270.5	264.2	4.3	15.5	11.9	9.0	7	97532.1	71
255	11.5	58.3	2235	270.5	264.2	3.9	15.5	10.6	9.0	7	97542.0	71
256	12.9	58.5	2225	270.5	264.2	6.8	15.7	11.8	9.5	7	97543.1	71
257	14.1	58.1	2229	270.5	264.2	5.7	15.4	12.9	10.1	7	97542.9	71
258	13.9	58.4	2229	270.5	264.2	8.1	15.7	12.7	9.1	7	97544.1	71
259	13.5	58.3	2207	270.5	264.2	5.1	15.3	12.4	8.8	7	97543.6	71
260	13.7	58.3	2232	270.5	264.2	7.6	15.7	12.6	9.1	7	97544.6	71
261	15.4	58.3	2226	270.5	264.2	8.5	15.4	14.1	10.6	7	97532.7	72
262	11.6	58.3	2228	270.5	264.2	5.8	15.4	10.7	9.0	7	97531.4	72
263	13.5	58.3	2238	270.5	264.2	5.7	15.6	12.4	9.5	7	97530.4	72
264	13.6	58.1	2240	270.5	264.2	6.1	15.6	12.4	9.4	7	97530.3	72

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
265	14.1	58.1	2230	270.5	264.2	6.7	15.4	12.9	11.3	7	97531.1	72
266	12.3	58.3	2219	270.5	264.1	4.1	15.4	11.2	9.6	7	97531.3	72
267	12.1	58.9	2241	270.5	262.1	4.0	15.6	11.1	10.6	7	97532.8	72
268	12.3	57.9	2230	270.5	261.2	6.5	15.6	11.2	12.2	7	97532.1	72
269	13.6	57.9	2239	270.5	261.1	6.7	15.5	12.5	11.8	7	97532.0	72
270	13.8	58.0	2226	270.5	261.2	6.0	15.4	12.6	12.1	7	97532.1	72
271	14.6	58.6	2233	270.5	261.2	5.1	15.4	13.4	13.1	7	97532.2	72
272	13.6	58.6	2230	270.5	261.2	4.6	15.6	12.4	10.6	7	97530.7	72
273	12.7	58.4	2229	270.5	261.2	5.4	15.4	11.6	10.0	7	97542.2	71
274	13.1	58.8	2237	270.5	261.2	4.9	15.5	12.0	11.6	7	97544.0	71
275	13.4	59.2	2235	2								

Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 3 of 5
 Created on: 1/5/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
353	14.3	57.9	2242	270.5	265.3	8.4	15.6	13.1	8.5	7	97558.5	75
354	15.1	57.7	2230	270.5	265.4	-1.4	15.5	13.8	9.2	7	97558.9	75
355	15.8	57.8	2227	270.5	265.3	9.9	15.5	14.5	9.0	7	97558.3	75
356	15.7	57.1	2227	270.5	265.3	8.3	15.4	14.4	8.6	7	97556.6	75
357	12.6	57.4	2216	270.5	265.3	6.3	15.4	11.5	10.1	7	97556.7	75
358	12.4	57.9	2229	270.5	265.3	6.1	15.5	11.3	10.1	7	97558.4	75
359	13.8	58.4	2216	270.5	265.3	3.1	15.4	12.6	10.1	7	97558.9	75
360	10.9	58.9	2230	270.5	265.3	-0.1	15.4	9.9	11.8	7	97558.5	75
361	10.1	58.6	2030	270.5	265.1	-1.4	15.0	9.8	10.7	7	97558.6	75
362	58.0	1987	270.5	265.4	-1.4	15.2	9.0	12.1	11.1	7	97544.2	74
363	12.4	59.0	2179	270.5	263.0	2.6	16.0	11.4	12.0	7	97531.5	74
364	13.9	58.3	2235	270.5	262.7	7.7	15.8	12.7	11.8	7	97533.5	74
365	15.3	57.8	2243	270.5	262.5	8.8	15.6	14.0	11.9	7	97533.2	74
366	14.6	58.0	2208	270.5	262.6	7.6	15.3	13.4	10.8	7	97532.5	74
367	14.3	57.9	2208	270.5	262.6	7.8	15.4	13.1	11.5	7	97531.5	74
368	13.9	58.0	2237	270.5	262.7	6.9	15.6	12.8	11.4	7	97533.0	75
369	13.5	58.2	2219	270.5	264.3	5.9	15.4	12.3	10.9	7	97531.8	75
370	13.0	58.6	2249	270.5	264.7	6.8	15.6	11.9	9.3	7	97531.7	75
371	12.8	58.2	2231	270.5	264.8	6.4	15.4	11.8	9.7	7	97531.6	75
372	13.4	57.7	2241	270.5	265.0	7.9	15.6	12.3	10.4	7	97531.8	75
373	15.4	57.6	2226	270.5	265.0	9.0	15.5	14.1	11.9	7	97532.7	75
374	15.0	58.3	2231	270.5	265.1	8.0	15.4	13.7	11.1	7	97532.6	75
375	13.4	58.4	2229	270.5	265.1	6.5	15.5	12.3	12.2	7	97533.6	75
376	12.6	58.1	2224	270.5	265.1	3.8	15.4	11.5	13.1	7	97533.4	75
377	11.7	58.4	2232	270.5	265.1	3.0	15.6	10.7	12.0	7	97533.5	75
378	11.8	58.4	2232	270.5	265.0	2.9	15.5	10.8	11.7	7	97533.4	75
379	11.3	58.6	2235	270.5	265.0	2.5	15.6	10.3	10.2	7	97537.2	75
380	13.0	58.7	2241	270.5	265.0	5.2	15.5	11.9	9.6	7	97546.4	75
381	12.7	57.8	2238	270.5	265.0	5.5	15.5	11.7	9.9	7	97546.8	75
382	12.1	57.9	2216	270.5	265.0	4.6	15.3	11.1	9.5	7	97545.8	75
383	13.4	58.4	2239	270.5	265.0	10.4	15.4	10.4	11.4	7	97546.3	75
384	11.1	58.7	2219	270.5	265.0	0.2	15.3	10.1	11.6	7	97546.9	75
385	9.7	58.3	1874	270.5	265.0	-1.8	14.9	8.6	12.2	7	97543.0	76
386	11.3	58.1	2205	270.5	265.0	-0.7	15.7	9.1	12.8	7	97532.7	76
387	11.3	58.1	2163	270.5	265.0	-1.0	15.3	10.4	11.5	7	97532.7	76
388	11.3	58.5	2144	270.5	265.0	-1.0	15.4	10.4	10.3	7	97533.6	76
389	9.5	57.8	2229	270.5	265.0	-0.3	15.7	9.0	10.4	7	97533.7	76
390	9.5	57.8	1787	270.5	265.0	-1.9	15.0	7.8	12.2	7	97533.7	76
391	9.5	58.8	1804	270.5	265.0	-2.1	15.5	7.8	10.1	7	97532.8	76
392	10.4	58.6	2079	270.5	265.0	-1.2	15.5	8.7	9.9	7	97532.9	76
393	9.1	58.1	1630	270.5	265.0	-2.3	15.1	8.0	10.2	7	97532.3	76
394	9.0	58.8	1597	270.5	265.0	-2.4	15.4	8.2	9.8	7	97532.7	76
395	9.5	59.1	1807	270.5	265.0	-2.0	15.5	8.8	9.4	7	97533.4	76
396	8.8	58.0	2036	270.5	265.0	-0.4	15.8	8.6	9.4	7	97533.8	76
397	13.4	57.9	2234	270.5	265.0	3.8	15.8	12.1	11.4	7	97541.8	77
398	11.6	57.6	2234	270.5	265.0	2.4	15.6	10.6	8.3	7	97557.5	77
399	12.1	57.7	2240	270.5	265.0	3.4	15.7	11.1	10.4	7	97557.4	77
400	11.5	57.9	2222	270.5	264.3	2.8	15.4	10.5	11.1	7	97557.4	77
401	12.3	58.1	2198	270.5	262.5	-0.1	15.3	11.2	9.8	7	97557.3	77
402	9.1	57.7	1636	270.5	262.3	-2.2	14.8	8.2	9.7	7	97557.8	77
403	8.8	58.4	1498	270.5	262.9	-2.5	15.2	8.7	9.1	7	97555.8	78
404	8.1	57.5	1176	270.5	264.9	-2.5	14.8	6.9	9.2	7	97547.2	78
405	8.5	58.2	1363	270.5	265.3	-2.4	15.4	7.2	9.1	7	97545.5	78
406	9.2	58.5	1670	270.5	265.4	-2.4	15.6	8.9	8.3	7	97544.5	78
407	8.7	57.8	1448	270.5	265.5	-2.5	15.2	8.6	7.1	7	97545.7	78
408	8.9	58.3	1544	270.5	265.5	-2.4	15.6	8.8	7.0	7	97546.9	78
409	8.9	58.3	1550	270.5	265.5	-1.8	15.3	7.9	7.2	7	97546.2	80
410	8.7	57.9	1476	270.5	266.0	-1.4	15.5	7.6	7.5	7	97546.2	80
411	10.1	58.3	2030	270.5	267.4	-0.4	15.7	8.9	6.7	7	97546.8	80
412	10.2	57.8	2161	270.5	267.4	0.0	15.4	8.9	7.4	7	97546.2	80
413	10.2	57.8	2036	270.5	267.5	-0.4	15.3	10.2	7.2	7	97545.3	80
414	12.0	57.9	2185	270.5	267.6	0.0	15.4	11.0	6.9	7	97547.1	80
415	12.1	58.1	2243	270.5	267.7	0.2	15.7	11.1	7.7	7	97545.3	79
416	11.2	58.0	2215	270.5	267.8	-0.6	15.5	10.3	8.7	7	97546.6	79
417	9.6	58.0	1865	270.5	267.7	-1.9	15.1	9.8	8.2	7	97546.1	79
418	9.1	57.8	1657	270.5	267.7	-2.1	15.1	9.3	6.9	7	97546.9	79
419	8.1	57.4	1163	270.5	267.7	-2.5	14.8	7.2	7.0	7	97545.4	79
420	8.3	58.3	1281	270.5	267.7	-2.5	15.3	8.5	7.1	7	97548.1	79
421	9.6	58.6	1851	270.5	267.7	-1.8	15.8	9.4	7.2	7	97547.4	80
422	9.4	59.2	1771	270.5	267.7	-2.1	15.4	8.7	7.3	6	97557.3	80
423	9.4	58.8	1783	270.5	267.7	-2.1	15.4	8.5	8.2	6	97557.8	80
424	9.5	58.7	1806	270.5	267.7	-2.0	15.5	8.3	8.0	6	97559.1	80
425	11.5	58.5	2146	270.5	267.7	-1.0	15.6	9.2	7.7	6	97558.8	80
426	11.5	58.5	2148	270.5	266.6	-1.0	15.4	10.3	7.7	6	97559.0	80
427	12.2	58.3	2235	270.5	264.9	1.8	15.9	11.2	7.1	6	97558.9	80
428	11.6	58.0	2236	270.5	264.7	2.4	15.9	10.7	7.6	6	97558.2	80
429	11.8	58.5	2209	270.5	265.6	1.6	15.3	10.9	8.1	6	97558.6	80
430	10.9	57.8	2205	270.5	264.7	-0.9	15.3	10.0	8.2	6	97558.7	80
431	12.2	58.7	2237	270.5	264.7	0.0	15.7	11.2	8.3	6	97558.3	80
432	12.8	57.4	2239	270.5	264.7	2.3	15.7	9.4	8.0	6	97558.9	80
433	12.6	57.5	2221	270.5	266.1	3.1	15.4	11.7	6.9	6	97558.8	79
434	12.6	57.5	2221	270.5	266.1	3.1	15.4	11.5	6.9	6	97558.7	79
435	11.3	57.6	2231	270.5	267.2	3.7	15.5	10.4	6.7	6	97558.8	79
436	12.1	57.5	2237	270.5	267.2	5.9	15.7	11.1	6.4	6	97559.1	79
437	12.8	57.2	2214	270.5	267.2	5.4	15.3	11.7	6.2	6	97559.1	79
438	13.2	57.8	2237	270.5	267.3	4.5	15.6	12.1	5.8	6	97559.0	79
439	12.0	57.9	2227	270.5	267.4	3.8	15.4	12.1	6.3	6	97558.7	81
440	12.0	57.9	2227	270.5	267.3	2.2	15.5	9.7	7.8	6	97558.7	81

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
441	10.3	58.0	2063	270.5	267.3	-1.2	15.0	8.6	9.2	6	97558.6	81
442	10.9	58.8	2207	270.5	267.3	0.7	15.7	10.0	9.1	6	97557.9	81
443	11.7	57.9	2226	270.5	267.3	2.1	15.6	10.7	8.8	6	97559.0	81
444	11.5	57.6	2212	270.5	267.3	2.4	15.5	10.5	9.3	6	97557.7	80
445	9.9	57.9	2193	270.5	266.3	-0.9	15.2	9.8	8.5	6	97546.8	77
446	11.8	58.3	2151	270.5	264.9	-1.0	15.6	10.8	9.5	6	97546.7	77
447	11.8	58.3	2151	270.5	264.9	-1.0	15.6	10.8	9.5	6	97546.7	77
448	9.8	57.9	2183	270.5	265.0	-1.5	15.0	8.8	8.3	6	97547.0	77
449	9.0	57.9	1614	270.5	264.9	-2.4	15.2	9.1	9.8	6	97544.8	77
450	9.2	58.4	1684	270.5	264.8	-2.4	15.5	9.6	11.4	6	97533.4	78
451	9.6	58.6	1640	270.5	264.8							

Table E.01 Measurement data - Turbine ON

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 4 of 5
 Created on: 1/5/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
529	12.4	58.1	2219	270.5	263.7	4.3	15.4	11.4	11.6	6	97546.6	81
530	12.8	58.5	2225	270.5	263.7	-4.3	15.6	11.7	11.6	6	97547.0	81
531	13.3	58.4	2241	270.5	263.7	5.3	15.5	12.2	11.4	6	97546.7	81
532	11.5	58.5	2224	270.5	263.7	3.9	15.4	10.5	10.7	6	97539.6	81
533	11.7	58.9	2216	270.5	263.5	1.2	15.5	10.7	9.9	6	97533.8	81
534	13.1	58.4	2239	270.5	261.9	4.7	15.6	12.0	8.8	6	97533.8	81
535	13.0	58.0	2235	270.5	261.4	5.4	15.5	11.9	9.5	6	97533.8	81
536	12.1	57.8	2221	270.5	261.4	3.3	15.3	11.0	8.8	6	97533.7	81
537	13.4	57.9	2226	270.5	261.4	5.0	15.7	12.3	8.2	6	97533.2	81
538	12.7	58.5	2227	270.5	261.3	-4.3	15.5	12.4	8.7	6	97543.1	82
539	13.9	57.9	2233	270.5	261.3	6.3	15.5	12.7	8.6	6	97546.4	82
540	13.5	57.3	2233	270.5	261.3	6.0	15.4	12.4	9.2	6	97547.0	82
541	14.0	58.1	2218	270.5	261.3	5.5	15.4	12.8	9.2	6	97546.7	82
542	12.4	57.5	2235	270.5	261.3	4.2	15.5	11.3	8.0	6	97547.1	82
543	12.8	58.1	2239	270.5	261.3	3.3	15.4	11.7	8.3	6	97547.1	82
544	11.6	58.4	2239	270.5	261.3	2.7	15.5	10.6	8.4	6	97547.0	82
545	12.4	58.4	2233	270.5	261.2	5.5	15.7	11.3	7.9	6	97546.9	82
546	14.6	57.9	2241	270.5	261.2	8.2	15.7	13.4	8.2	6	97547.2	82
547	16.4	57.7	2234	270.5	261.2	9.9	15.5	15.0	9.0	6	97546.9	82
548	15.7	57.4	2223	270.5	261.2	8.6	15.4	14.4	9.0	6	97547.1	82
549	14.9	57.9	2214	270.5	261.2	6.7	15.3	13.6	7.7	6	97546.2	82
550	13.7	58.0	2221	270.5	261.2	5.9	15.5	12.6	7.6	6	97546.6	82
551	12.9	58.5	2215	270.5	261.9	2.2	15.4	11.8	7.2	6	97546.9	82
552	11.2	58.5	2246	270.5	263.4	0.8	15.5	10.3	8.5	6	97547.2	82
553	11.1	58.5	2215	270.5	263.5	-0.7	15.3	10.2	9.6	6	97546.2	82
554	9.5	58.4	1823	270.5	263.6	-1.9	14.9	8.4	9.0	6	97545.9	82
555	9.5	180.7	2045	270.5	263.6	2.1	15.4	8.8	8.3	6	97546.5	82
556	9.7	58.9	1877	270.5	263.7	-1.7	15.4	9.4	9.4	6	97538.2	81
557	9.5	59.0	1797	270.5	263.7	-2.1	15.5	8.7	9.0	6	97533.0	80
558	10.8	59.0	2219	270.5	263.6	0.8	15.9	8.9	8.3	6	97533.0	80
559	10.3	58.6	2061	270.5	263.6	0.3	15.4	9.7	8.0	6	97532.0	80
560	10.3	58.6	2061	270.5	263.7	-1.3	15.2	8.9	9.1	6	97532.8	80
561	11.8	58.9	2238	270.5	263.7	1.9	15.9	10.8	10.5	6	97533.7	80
562	11.9	58.9	2227	270.5	263.6	4.3	15.7	10.9	10.6	6	97533.6	80
563	13.0	57.8	2234	270.5	263.7	1.5	15.9	11.9	10.9	6	97533.6	80
564			2213	270.5	263.8	0.8	15.4	9.8	10.0	6	97533.4	80
565			2236	270.5	262.3	1.3	15.6	9.8	9.3	6	97532.5	80
566	12.7	58.8	2200	270.5	260.2	-0.7	15.3	11.7	10.4	6	97532.0	80
567	9.5	58.7	1786	270.5	262.0	-2.1	15.3	9.4	10.2	6	97531.7	80
568	10.2	58.2	2047	270.5	261.2	1.3	15.6	10.9	10.2	6	97531.1	80
569	10.3	58.7	2061	270.5	260.3	-1.0	15.6	9.7	11.0	6	97532.1	80
570	13.6	58.3	2234	270.5	260.3	3.0	15.9	12.5	10.1	6	97532.4	80
571	13.9	58.4	2222	270.5	260.3	4.4	15.6	12.7	13.2	6	97533.4	80
572	12.7	58.3	2237	270.5	260.3	2.5	15.6	11.6	11.6	6	97533.6	79
573	11.2	58.7	2222	270.5	260.3	1.3	15.4	10.2	13.6	6	97533.6	79
574	9.4	58.4	1758	270.5	260.4	-1.9	14.8	7.5	12.4	7	97533.7	78
575	10.6	59.7	2107	270.5	262.2	-1.2	15.7	10.2	11.8	7	97533.5	78
576	9.9	186.8	1966	270.5	263.7	-1.5	15.1	9.2	11.8	7	97533.5	78
577	9.6	59.0	1846	270.5	263.8	-1.9	15.3	10.1	11.2	7	97533.4	78
578	8.8	58.5	1504	270.5	263.9	-2.4	15.2	8.6	12.2	7	97533.9	78
579	8.5	59.2	1388	270.5	263.9	-2.4	15.4	7.6	13.2	7	97533.6	78
580	9.2	59.0	1670	270.5	264.0	-2.3	15.6	8.8	12.6	7	97532.3	77
581	9.0	59.0	1612	270.5	265.7	-2.4	15.4	8.2	12.2	7	97532.3	77
582	10.0	59.5	2012	270.5	267.3	-1.4	15.8	8.2	11.1	7	97532.3	77
583			2230	270.5	267.4	2.7	15.9	9.4	9.6	7	97533.4	77
584	12.0	58.7	2234	270.5	267.6	3.5	15.6	10.9	10.5	7	97533.6	77
585	13.0	58.6	2234	270.5	267.6	3.2	15.6	11.9	12.7	7	97533.4	77
586	12.9	58.4	2244	270.5	267.5	3.5	15.5	11.8	12.4	7	97533.4	77
587			2227	270.5	267.6	3.7	15.4	9.7	11.5	7	97533.5	77
588			2186	270.5	267.5	-0.1	15.2	10.2	10.2	7	97533.6	77
589			2216	270.5	267.6	0.0	15.4	7.4	9.8	7	97533.7	77
590	12.0	59.1	2232	270.5	269.0	2.3	15.7	11.0	9.4	7	97533.6	77
591	13.8	58.8	2219	270.5	271.6	0.7	15.4	12.6	8.4	7	97539.6	78
592	12.1	58.2	2248	270.5	273.8	3.3	15.6	11.1	10.7	7	97545.7	79
593	11.5	58.5	2213	270.5	274.2	1.5	15.4	10.6	9.5	7	97546.7	79
594	11.4	59.0	2221	270.5	274.2	0.0	15.4	10.4	10.3	7	97545.7	79
595			2144	270.5	274.2	-1.0	15.1	8.9	9.6	7	97546.3	79
596			2228	270.5	274.2	-0.4	15.5	8.9	10.6	7	97546.9	79
597	13.9	58.2	2224	270.5	274.2	1.4	16.0	12.8	10.8	7	97533.7	79
598	12.9	57.9	2213	270.5	274.2	5.2	15.3	11.8	9.2	7	97558.3	76
599	12.6	58.6	2230	270.5	274.2	5.1	15.6	11.5	8.2	7	97558.4	76
600	11.3	58.3	2219	270.5	274.2	1.8	15.4	10.3	8.8	7	97558.6	76
601			2241	270.5	274.2	1.5	15.7	9.1	10.2	7	97558.3	76
602			2228	270.5	274.2	4.9	15.5	9.5	9.4	7	97558.3	76
603	11.4	58.4	2213	270.5	274.0	2.0	15.3	10.5	10.2	7	97556.6	76
604	11.2	58.4	2228	270.5	274.0	2.5	15.6	8.6	11.2	7	97556.8	76
605	11.2	58.4	2219	270.5	272.5	1.5	15.5	10.3	9.9	7	97558.2	76
606	11.2	58.5	2240	270.5	270.2	3.3	15.6	10.3	9.2	7	97558.4	76
607	10.8	58.7	2229	270.5	269.9	2.4	15.4	9.9	10.6	7	97557.9	76
608	12.2	58.3	2233	270.5	269.8	4.8	15.7	11.2	10.1	7	97557.0	76
609	14.3	57.8	2246	270.5	269.8	5.8	15.5	13.1	8.5	7	97556.9	76
610	11.0	58.2	2218	270.5	269.8	4.4	15.4	10.8	9.8	7	97556.8	76
611	11.0	58.3	2239	270.5	269.8	2.9	15.5	10.1	11.6	7	97557.0	76
612	11.3	58.3	2232	270.5	269.8	5.0	15.7	10.4	11.9	7	97558.0	76
613	15.0	58.4	2233	270.5	269.8	8.9	15.6	13.8	12.1	7	97558.2	76
614	15.2	59.0	2228	270.5	269.8	8.3	15.4	13.9	14.2	7	97552.4	75
615	14.4	58.8	2236	270.5	269.5	8.5	15.6	13.2	12.1	7	97545.3	74
616	16.8	58.4	2223	270.5	269.5	9.2	15.4	15.4	13.3	7	97546.2	74

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Ureq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
617	14.0	58.2	2215	270.5	269.5	6.6	15.4	12.8	12.2	7	97545.5	74
618	13.8	58.1	2229	270.5	269.5	6.4	15.6	12.6	13.3	7	97546.2	74
619	14.3	58.3	2235	270.5	269.5	7.5	15.5	13.1	13.0	7	97546.4	74
620	14.9	58.0	2209	270.5	269.0	5.2	15.3	13.7	14.1	7	97539.9	74
621	12.2	59.1	2243	270.5	267.3	5.6	15.7	11.2	13.3	7	97533.0	74
622	14.8	58.9	2231	270.5	267.1	7.8	15.5	13.5	13.1	7	97532.4	74
623	14.6	58.3	2225	270.5	267.1	6.7	15.4	13.4	13.0	7	97533.2	74
624	13.2	58.1	2231	270.5	267.1	7.0	15.5	12.1	12.8	7	97533.3	74
625	13.3	58.6	2226	270.5	267.1	5.5	15.4	12.2	12.8	7	97533.3	74
626	11.8	58.4	2241	270.5	267.1	6.9	15.7	10.8	12.6	7	97538.7	74
627	14.7	58.1	2235	270.5	267.1	7.4	15.5	13.5	13.2	7	9754	

Table E.02 Measurement data - Background

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

Page 1 of 2
 Created on: 1/5/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (kPa)	Relative Humidity (%)
1	10.2	42.4	0.0	10.0	9	97540.8	50
2	10.1	42.7	0.0	9.9	9	97549.5	51
3	11.5	42.5	0.0	11.2	9	97553.0	51
4	11.0	43.3	0.0	10.7	9	97553.4	51
5	10.6	42.1	0.0	10.4	9	97553.2	51
6	10.6	42.3	0.0	10.4	9	97553.3	51
7	10.8	42.7	0.0	10.5	9	97552.7	51
8	9.9	42.2	0.0	9.7	9	97552.4	51
9	9.8	42.3	0.0	9.6	9	97552.2	50
10	9.4	42.9	0.0	9.2	9	97552.0	50
11	9.0	43.0	0.0	8.8	9	97551.5	50
12	10.7	43.7	0.0	10.5	9	97551.0	50
13	11.5	44.1	0.0	11.2	9	97550.0	50
14	12.3	43.4	0.0	12.0	9	97539.2	51
15	11.7	43.5	0.0	11.5	9	97534.7	51
16	11.6	43.9	0.0	11.4	9	97527.0	51
17	11.5	43.3	0.0	11.2	9	96429.5	51
18	9.9	44.4	0.0	8.7	9	96133.2	51
19	11.2	43.0	0.0	10.9	9	96282.4	51
20	10.9	42.0	0.0	10.6	9	96399.0	51
21	8.3	42.7	0.0	8.1	9	96490.6	50
22	9.1	43.0	0.0	8.9	9	96638.0	50
23	9.5	42.9	0.0	9.3	9	96787.9	50
24	9.9	42.6	0.0	9.7	9	96599.4	50
25	9.8	41.9	0.0	9.5	9	96687.1	50
26	10.6	42.8	0.0	10.4	9	96788.6	51
27	11.2	42.6	0.0	11.0	9	96821.8	51
28	11.3	42.4	0.0	11.1	9	96877.1	51
29	11.3	42.1	0.0	11.0	9	96902.7	51
30	12.2	42.4	0.0	11.9	9	96926.1	51
31	11.4	43.0	0.0	11.2	9	96854.5	51
32	11.4	43.2	0.0	11.2	9	96960.9	50
33	11.3	42.5	0.0	11.0	9	96929.3	50
34	9.6	41.5	0.0	9.4	9	96884.3	50
35	8.9	41.9	0.0	8.7	9	96884.2	50
36	8.2	42.2	0.0	8.0	9	96906.6	50
37	8.8	43.4	0.0	8.6	9	96941.0	50
38	9.9	43.6	0.0	9.6	9	96942.2	51
39	9.1	42.7	0.0	8.9	9	96981.1	51
40	8.7	42.7	0.0	8.5	9	96923.7	51
41	7.7	42.1	0.0	7.5	9	96861.5	51
42	8.1	42.6	0.0	7.9	9	96909.4	51
43	8.5	42.4	0.0	8.2	9	96950.6	51
44	8.9	41.3	0.0	8.7	9	97041.3	51
45	10.0	40.4	0.0	9.8	9	97056.5	51
46	10.4	40.6	0.0	10.2	9	96998.2	51
47	11.7	41.0	0.0	11.4	9	97050.6	51
48	10.7	41.0	0.0	10.4	9	97117.9	51
49	9.6	41.5	0.0	9.3	9	97072.5	51
50	8.8	42.5	0.0	8.6	9	96993.8	51
51	9.3	41.9	0.0	9.1	9	96997.4	51
52	9.6	42.9	0.0	9.3	9	97043.9	51
53	11.7	43.7	0.0	11.4	9	97034.6	51
54	11.6	44.0	0.0	11.4	9	96998.7	51
55	11.5	43.3	0.0	11.2	9	97055.9	51
56	10.8	40.9	0.0	10.5	9	97055.7	50
57	9.5	40.8	0.0	9.2	9	97068.5	50
58	11.0	40.8	0.0	10.7	9	97138.3	50
59	10.0	42.1	0.0	9.8	9	97072.1	50
60	9.9	40.4	0.0	9.6	9	97078.5	50
61	9.8	40.0	0.0	9.5	9	97120.1	50
62	9.4	40.0	0.0	9.2	9	97096.8	51
63	9.4	39.1	0.0	9.2	9	97073.6	51
64	10.1	39.4	0.0	9.9	9	97073.6	51
65	9.0	40.1	0.0	8.8	9	97051.3	51
66	8.5	39.7	0.0	8.3	9	97103.8	51
67	7.3	40.4	0.0	7.2	9	97042.2	51
68	7.4	40.7	0.0	7.4	9	97056.4	51
69	7.8	43.1	0.0	7.6	9	97139.4	51
70	7.3	41.2	0.0	7.1	9	97080.5	51
71	7.5	40.1	0.0	7.3	9	97049.6	51
72	7.2	40.6	0.0	7.0	9	97040.7	51
73	7.7	40.7	0.0	7.5	9	96976.6	51
74	6.9	40.8	0.0	6.7	9	97266.0	52
75	7.9	41.2	0.0	7.7	9	97524.7	52
76	7.8	40.5	0.0	7.6	9	97526.1	52
77	7.9	39.1	0.0	7.7	9	97526.6	52
78	7.9	39.7	0.0	7.4	9	97527.5	52
79	8.8	39.7	0.0	8.6	9	97524.6	52
80	7.7	39.4	0.0	7.6	9	97519.3	51
81	8.6	38.8	0.0	8.4	9	97492.3	51
82	9.4	39.6	0.0	9.2	9	97279.4	51
83	8.7	40.9	0.0	8.5	9	97190.7	51

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (kPa)	Relative Humidity (%)
84	8.2	40.0	0.0	8.0	9	97236.4	51
85	8.0	39.2	0.0	7.8	9	97513.0	51
86	8.1	40.1	0.0	7.9	9	97528.9	51
87	6.9	39.5	0.0	6.8	9	97528.5	51
88	6.7	40.1	0.0	6.6	9	97528.5	51
89	7.5	40.4	0.0	7.3	9	97528.4	51
90	7.9	39.5	0.0	7.7	9	97528.4	51
91	8.7	38.9	0.0	8.5	9	97528.4	51
92	8.7	38.4	0.0	8.4	9	97528.9	52
93	8.3	39.2	0.0	8.1	9	97528.9	52
94	8.9	40.0	0.0	8.7	9	97529.0	52
95	9.2	39.6	0.0	9.0	9	97529.8	52
96	9.6	39.4	0.0	9.4	9	97530.2	52
97	8.1	40.7	0.0	7.9	9	97530.1	52
98	10.2	39.8	0.0	10.0	9	97529.4	52
99	9.1	41.3	0.0	8.9	9	97528.9	52
100	7.8	43.6	0.0	7.6	9	97529.0	52
101	8.0	43.0	0.0	7.8	9	97529.4	52
102	7.6	46.9	0.0	7.4	9	97529.0	52
103	9.3	45.8	0.0	9.1	9	97529.0	52
104	9.8	43.4	0.0	9.6	9	97528.9	52
105	9.6	43.0	0.0	9.4	9	97529.1	52
106	10.0	42.2	0.0	9.7	9	97529.3	52
107	8.9	42.3	0.0	8.6	9	97529.1	52
108	8.3	43.5	0.0	8.1	9	97529.1	52
109	10.2	43.1	0.0	10.0	9	97528.8	52
110	8.8	42.5	0.0	8.6	9	97529.0	52
111	10.9	41.1	0.0	10.7	9	97529.4	52
112	11.1	42.3	0.0	10.9	9	97529.7	52
113	10.8	42.2	0.0	10.5	9	97529.0	52
114	8.9	43.3	0.0	8.7	9	97529.1	52
115	9.5	44.2	0.0	9.3	9	97529.8	52
116	12.3	42.6	0.0	12.0	9	97529.7	53
117	12.8	45.1	0.0	12.5	9	97529.3	53
118	12.5	45.9	0.0	12.2	9	97529.4	53
119	10.7	45.5	0.0	10.5	9	97528.2	53
120	10.0	45.5	0.0	9.7	9	97528.3	53
121	11.1	46.1	0.0	10.9	9	97529.2	53
122	11.0	46.4	0.0	10.8	9	97528.7	53
123	10.6	45.8	0.0	10.3	9	97528.7	53
124	11.4	46.5	0.0	11.1	9	97528.2	53
125	11.4	44.7	0.0	11.1	9	97528.7	53
126	11.2	46.4	0.0	10.9	9	97528.5	53
127	10.8	46.2	0.0	10.5	9	97530.2	53
128	8.3	45.7	0.0	8.1	9	97542.8	54
129	9.0	45.1	0.0	8.8	9	97541.9	54
130	10.5	46.5	0.0	10.2	9	97542.0	54
131	11.1	50.4	0.0	10.8	9	97542.0	54
132	12.5	45.8	0.0	12.2	9	97542.0	54
133	12.5	45.9	0.0	12.2	9	97541.4	54
134	12.1	48.3	0.0	11.8	9	97528.8	54
135	11.9	45.1	0.0	11.6	9	97528.6	54
136	12.2	45.2	0.0	11.9	9	97528.7	54
137	12.2	45.8	0.0	11.9	9	97528.2	54
138	12.6	46.9	0.0	12.3	9	97528.5	54
139	12.6	50.2	0.0	12.3	9	97529.2	54
140	11.9	48.4	0.0	11.6	9	97530.1	54
141	11.2	49.3	0.0	11.0	9	97529.5	54
142	9.8	46.5	0.0	9.5	9	97529.1	54
143	11.8	48.2	0.0	11.5	9	97528.8	54
144	11.2	49.1	0.0	10.9	9	97528.9	54
145	12.6	47.8	0.0	12.3	9	97530.5	54
146	13.5	47.5	0.0	13.2	9	97530.2	56
147	13.4	47.5	0.0	13.1	9	97529.2	56
148	13.2	46.2	0.0	12.8	9	97528.6	56
149	12.1	47.0	0.0	11.9	9	97528.8	56
150	13.0	48.1	0.0	12.7	9	97529.0	56
151	12.4	46.4	0.0	12.1	9	97529.4	56
152	12.7	47.6	0.0	12.4	9	97530.2	56
153	14.2	49.7	0.0	13.8	9	97529.9	56
154	14.9	49.4	0.0	14.6	9	97529.9	56
155	13.0	49.3	0.0	12.7	9	97529.4	56
156	13.7	47.6	0.0	13.4	9	97529.9	56
157	14.1	46.4	0.0	13.8	9	97530.7	56
158	14.8	46.0	0.0	14.4	9	97530.4	55
159	14.8	45.5	0.0	14.5	9	97529.2	55
160	12.6	45.4	0.0	12.2	9	97528.9	55
161	14.5	46.0	0.0	14.2	9	97529.9	55
162	13.7	45.9	0.0	13.3	9	97529.6	55
163	13.1	45.5	0.0	12.8	9	97528.9	56
164	11.3	45.6	0.0	11.0	9	97529.0	56
165	11.1	46.5	0.0	10.9	9	97528.8	56
166	11.6	47.4	0.0				

Table E.02 Measurement data - Background

Project: Summerhaven Wind Energy Centre - Turbine T38 - IEC 61400-11 Measurement
 Report ID: 13259.00.T38.RP1

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording.

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
250							
251							
252							
253							
254							
255							
256							
257							
258							
259							
260							
261							
262							
263							
264							
265							
266							
267							
268							
269							
270							
271							
272							
273							
274							
275							
276							
277							
278							
279							
280							
281							
282							
283							
284							
285							
286							
287							
288							
289							
290							
291							
292							
293							
294							
295							
296							
297							
298							
299							
300							
301							
302							
303							
304							
305							
306							
307							
308							
309							
310							
311							
312							
313							
314							
315							
316							
317							
318							
319							
320							
321							
322							
323							
324							
325							
326							
327							
328							
329							
330							
331							
332							

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording.

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
333							
334							
335							
336							
337							
338							
339							
340							
341							
342							
343							
344							
345							
346							
347							
348							
349							
350							
351							
352							
353							
354							
355							
356							
357							
358							
359							
360							
361							
362							
363							
364							
365							
366							
367							
368							
369							
370							
371							
372							
373							
374							
375							
376							
377							
378							
379							
380							
381							
382							
383							
384							
385							
386							
387							
388							
389							
390							
391							
392							
393							
394							
395							
396							
397							
398							
399							
400							
401							
402							
403							
404							
405							
406							
407							
408							
409							
410							
411							
412							
413							
414							
415							

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording.

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
416							
417							
418							
419							
420							
421							
422							
423							
424							
425							
426							
427							
428							
429							
430							
431							
432							
433							
434							
435							
436							
437							
438							
439							
440							
441							
442							
443							
444							
445							
446							
447							
448							
449							
450							
451							
452							
453							
454							
455							
456							
457							
458							
459							
460							
461							
462							
463							
464							
465							
466							
467							
468							
469							
470							
471							
472							
473							
474							
475							
476							
477							
478							
479							
480							
481							
482							
483							
484							
485							
486							
487							
488							
489							
490							
491							
492							
493							
494							
495							
496							
497							
498							

End of Report
